

**Wabush ATB Renovation – Wabush Airport, Wabush, NL
EC015-180072/A**

AMENDMENT # 6

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY.
THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

Addendum #4

Drawings

1. Reference Drawing E6 - Level 1 Lighting:

- 1.1 Replace fixture Type M with fixture Type N.

2. Reference Drawing E13 - Communication Riser and Details:

- 1.1 Reference Detail 5/E13/E3 - Clarification wiring to speakers is to be two conductor, 18AWG. Note category 6 as noted.

1.2 Reference Detail 5/E13/E3 - The following equipment

- 1. Speakers - Ceiling mount TOA #PC-580RU.
- 2. Multi Channel Power Amplifier - TOA #DA-250FH or equal.
- 3. Provide IP Intercom Exchange in the rack - TOA #N-8000EX
- 4. Audio Interface Unit - TOA #N-8000AF
- 5. PA Handsets to be TOA #N-8000MS

3. Reference Drawing E14 - Security Risers & Details:

- 1.1 Reference Detail 4/E14/E14 - Access System Riser - Refer to floor plans for correct quantities of reader controllers and doors requiring access control.

By submission of its tender, the Tenderer confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

All other terms & conditions remain unchanged.
