

Part 1 General

1.1 SECTION INCLUDES

- .1 Board insulation as required to provide thermal barrier for building elements and spaces.

1.2 REFERENCE STANDARDS

- .1 American Society for Testing and Materials (ASTM)
 - .1 ASTM C260, Standard Specification for Air-Entraining Admixtures for Concrete.
 - .2 ASTM C309, Standard Specification for Liquid Membrane-Forming Compounds for Curing Concrete.
 - .3 ASTM C494/C494M, Standard Specification for Chemical Admixtures for Concrete.
- .2 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-51.34, Vapour Barrier, Polyethylene Sheet for Use in Building Construction.
- .3 Canadian Standards Association (CSA)
 - .1 CSA-A23.1/A23.2, Concrete Materials and Methods of Concrete Construction/Methods of Test and Standard Practices for Concrete.
 - .2 CAN3-A266.4, Guidelines for the Use of Admixtures in concrete.
 - .3 CAN/CSA-A3000, Cementitious Materials Compendium (Consists of A3001, A3002, A3003, A3004 and A3005).
 - .4 CSA-A3001, Cementitious Materials for Use in Concrete.

1.3 DESIGN REQUIREMENTS

- .1 Concrete materials and methods of construction: to CAN/CSA-3-A23.1/A23.2 unless otherwise specified.

Part 2 PRODUCTS

2.1 MATERIALS

- .1 Portland cement: to CAN/CSA-A3001, Type GU.
- .2 Water: to CAN/CSA-A23.1.
- .3 Aggregates: to CSA-A23.1.
- .4 Coarse aggregates to be normal density to CSA-A23.1/A23.2.
- .5 Admixtures:
 - .1 Air entraining admixture: to ASTM C260.
 - .2 Chemical admixtures: to ASTM C494, Owner's Representative to approve accelerating or set retarding admixtures during cold and hot weather placing.
- .6 Non premixed dry pack grout: composition of non metallic aggregate Portland cement with sufficient water for the mixture to retain its shape when made into a ball by hand and capable of developing compressive strength of 50 MPa at 28 days.

- .7 Ribbed waterstops: extruded PVC of sizes indicated shop welded corner and intersecting pieces.
 - .1 Tensile strength: to ASTM D412, method A, Die "C".
 - .2 Elongation: to ASTM D412, method A, Die "C", minimum 275%.
 - .3 Tear resistance: to ASTM D624, method A, Die "B".
- .8 Premoulded joint fillers:
 - .1 Bituminous impregnated fiber board: to ASTM D1751.
- .9 Polyethylene film: minimum 0.25 mm thickness to ASTM C171.
- .10 Bonding adhesive: as approved by Owner's Representative.

2.2 MIXES

- .1 Proportion normal density concrete in accordance with CSA-A23.1/A23.2, Alternative 1 to give following quality and yield for all concrete.
 - .1 Cement:
 - .1 Type GU Portland cement.
 - .2 Minimum compressive strength at 28 days: for structural design.
 - .3 Minimum cement content: 300 kg/m³ of concrete.
 - .4 Class of exposure: N.
 - .5 Nominal size of coarse aggregate: 20 mm.
 - .6 Slump at time and point of discharge: 75 to 100 mm.
 - .7 Air content: 5 to 8 %.
 - .8 Chemical admixtures: admixtures in accordance with ASTM C494.

Part 3 EXECUTION

3.1 PREPARATION

- .1 Obtain Owner's Representative approval before placing concrete. Provide two (2) working days notice prior to placing of concrete.
- .2 Place concrete reinforcing in accordance with Section 03 20 00 - Concrete Reinforcing.
- .3 During concreting operations:
 - .1 Development of cold joints not allowed.
 - .2 Ensure concrete delivery and handling facilitates placing with minimum of re-handling, and without damage to existing structure or Work.
- .4 Pumping of concrete is permitted only after approval of equipment and mix.
- .5 Ensure reinforcement and inserts are not disturbed during concrete placement.
- .6 Prior to placing of concrete obtain Owner's Representative approval of proposed method for protection of concrete during placing and curing in adverse weather.
- .7 Protect previous Work from staining.
- .8 Clean and remove stains prior to application for concrete finishes.

- .9 Maintain accurate records of poured concrete items to indicate date, location of pour, quality, air temperature and test samples taken.
- .10 Do not place load upon new concrete until authorized by Owner's Representative.

3.2 CONSTRUCTION

- .1 Do cast-in-place concrete work in accordance with CSA-A23.1/A23.2.
- .2 Sleeves and inserts.
 - .1 No sleeves, ducts, pipes or other openings shall pass through joists, beams, column capitals or columns, except where indicated or approved by Owner's Representative.
 - .2 Where approved by Owner's Representative, set sleeves, ties, pipe hangers and other inserts and openings as indicated or specified elsewhere. Sleeves and openings greater than 100 x 100 mm not indicated, must be approved by Owner's Representative.
 - .3 Do not eliminate or displace reinforcement to accommodate hardware. If inserts cannot be located as specified, obtain approval of modifications from Owner's Representative before placing of concrete.
 - .4 Check locations and sizes of sleeves and openings shown on drawings.
 - .5 Set special inserts for strength testing as indicated and as required by non-destructive method of testing concrete.
- .3 Anchor bolts.
 - .1 Set anchor bolts to templates under supervision of appropriate trade prior to placing concrete.
 - .2 With approval of Owner's Representative, grout anchor bolts in preformed holes or holes drilled after concrete has set. Formed holes to be minimum 100 mm diameter. Drilled holes to be manufacturers's recommendations.
 - .3 Protect anchor bolt holes from water accumulations, snow and ice build-ups.
 - .4 Set bolts and fill holes with shrinkage compensating grout.
 - .5 Locate anchor bolts used in connection with expansion shoes, rollers and rockers with due regard to ambient temperature at time of erection.
- .4 Grout under base plates using procedures in accordance with manufacturer's recommendations which result in 100 % contact over grouted area.
- .5 Finishing.
 - .1 Finish concrete in accordance with CSA-A23.1/A23.2.
 - .2 Use procedures acceptable to Owner's Representative or those noted in CSA-A23.1/A23.2, to remove excess bleed water. Ensure surface is not damaged.
 - .3 Wet cure using polyethylene sheets placed over sufficiently hardened concrete to prevent damage. Overlap adjacent edges 150 mm and tightly seal with sand on wood planks. Weigh sheets down to maintain close contact with concrete during the entire curing period.
 - .4 Where burlap is used for moist curing, place two prewetted layers on concrete surface and keep continuously wet during curing period.
 - .5 Finish concrete floor to meet requirements of CSA-A23.1/A23.2.
 - .6 Concrete floor to have finish hardness equal or greater than Mohs hardness in accordance with CSA-A23.1/A23.2.

- .7 Provide swirl-trowelled finish for exterior walks, ramps, pads.
- .8 Provide float finish for interior floor slabs.
- .9 Rub exposed sharp edges of concrete with carborundum to produce 3 mm radius edges unless otherwise indicated.
- .6 Waterstops.
 - .1 Install waterstops to provide continuous water seal.
 - .2 Do not distort or pierce waterstop in such a way as to hamper performance.
 - .3 Do not displace reinforcement when installing waterstops.
 - .4 Use equipment to manufacturer's requirements to field splice waterstops.
 - .5 Tie waterstops rigidly in place.
 - .6 Use only straight heat sealed butt joints in field.
 - .7 Use factory welded corners and intersections unless otherwise approved by Owner's Representative.
- .7 Joint fillers.
 - .1 Furnish filler for each joint in single piece for depth and width required for joint, unless otherwise authorized by Owner's Representative.
 - .2 When more than one piece is required for a joint, fasten abutting ends and hold securely to shape by stapling or other positive fastening.
 - .3 Locate and form, isolation, construction and expansion joints as indicated. Install joint filler.
 - .4 Use 12 mm thick joint filler to separate slabs-on-grade from vertical surfaces and extend joint filler from bottom of slab to within 12 mm of finished slab surface unless indicated otherwise.
- .8 Dampproof membrane.
 - .1 Install dampproof membrane under concrete slabs-on-grade inside building.
 - .2 Lap dampproof membrane minimum 150 mm at joints and seal.
 - .3 Seal punctures in dampproof membrane before placing concrete. Use patching material at least 150 mm larger than puncture and seal.

3.3 SITE TOLERANCE

- .1 Concrete slab tolerances in accordance with CSA-A23.1/A23.2, F-number Method, FF =25, FL = 20.
- .2 Finish all interior exposed concrete slabs to a tight consistent steel trowel appearance without burnishing the surface.

3.4 DEFECTIVE WORK

- .1 Repairs and classification of unacceptable concrete to be in accordance with CAN/CSA-A23.1.
- .2 Remove defective concrete and embedded debris and repair as directed by Owner's Representative.
- .3 Remove to bare concrete curing compounds detrimental to application of specified finishes.
- .4 Concrete to be supplied at the minimum strength requirement at 28 days. Tests indicating strengths lower than specified will necessitate further testing as required by the Owner's

Representative. Cost for such testing to be at the Contractor's expense. Should further tests confirm low values, the Owner's Representative has the right to require strengthening of the affected area or removal and replacing of the weak concrete all to the Contractor's expense.

- .5 Repair all shrinkage cracks in the completed slab-on-grade to remain exposed employing a suitable epoxy injection technique acceptable to Owner's Representative to completely seal all such cracks, all to the Contractor's expense.

END OF SECTION

