



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

AMENDMENT / MODIFICATION

004

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Water and Wastewater Controls Replacement Prince Albert National Park		
Solicitation No. - No. de l'invitation 5P420-17-5122/A	Date: July 11, 2017	
GETS Reference No. - No de reference de SEAG PW-17-00782424	Amendment No. - N° de la modif. 004	
Solicitation Closes:		
at - à 02:00 PM	on - le July 20, 2017	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à :		
Jen Maheu		
Telephone No. - No de téléphone	Fax No. - No de FAX:	
(403) 292-8502	(403) 292-4475	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:		
See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone:	_____
Facsimile No. - N° de télécopieur:	_____
Signature	Date

Amendment 04

This amendment is being raised to distribute answers to bidder questions.

A) BID CLOSING DATE

The closing date for tender 5P420-17-5122/A, titled *Water and Wastewater Controls Replacement – Prince Albert National Park*, is extended from July 11, 2017 until July 20, 2017 at 2:00PM Mountain Daylight Time (MDT).

B) BIDDER QUESTIONS

Q1 Section D5050 2.10.1 FactoryTalk SE is available in display counts of 25,100 and 250 displays. Which is required?

A1 For Section D5050 2.10.1 FactoryTalk SE must be supplied with capacity of 100 displays.

Q2 Section D5050 2.10.2 – Historian packages are available in tag counts of 250,500 and 100. Which is required?

A2 For Section D5050 2.10.2 Historian must be supplied in tag count of 100.

All other terms and conditions remain unchanged.