



**Fisheries and Oceans  
Canada**

**Pêches et Océans  
Canada**

**Canada**

**FISHERIES AND OCEANS CANADA**

**REAL PROPERTY, SAFETY AND SECURITY**

**PACIFIC REGION**

**WEST VANCOUVER LABORATORY, WEST VANCOUVER, BC**

**BOILER PLANT UPGRADE**

MARCH 2016

F1700-174079/A

**Fisheries and Oceans Canada, Pacific Region, 4160 Marine Drive, West Vancouver, BC, V7V 1N6**

**DRAWINGS:**

**MECHANICAL:**

Drawing Number	Drawing Title
M100	Cover Sheet and Site Plan
M201D	Existing Mechanical Schematic Demolition Plan
M202	Proposed Mechanical Schematic
M301D	Boiler Room Demolition Plan And Sections
M302	Boiler Room Plan And Sections
M400	Mechanical Equipment Schedules
M500	Mechanical Details

**ELECTRICAL:**

Drawing Number	Drawing Title
E100	Legend And Abbreviations
E101	General Notes
E105	Site Plan – Boiler Room
E106	Details – MCCE1 Electrical
E107	VFD And Boiler System Control Wiring

**SPECIFICATIONS:**

Section Number	Section Title	No. of Pages
<b>Division 01</b>		
01 11 00	Summary of Work	3
01 31 19	Project Meetings	3
01 33 00	Submittal Procedures	4
01 35 30	Health and Safety Requirements	3
01 41 00	Regulatory Requirements	1
01 45 00	Quality Control	3
01 61 00	Common Product Requirements	4
01 74 11	Cleaning	2
01 74 21	Construction/Demolition Waste Management and Disposal	9
01 78 00	Closeout Submittals	8
01 79 00	Demonstration And Training	2
01 91 13	General Commissioning (CX) Requirements	8
01 91 31	Commissioning (CX) Plan	8
01 91 33	Commissioning Forms	3
<b>Division 23</b>		
23 05 00	Common Work Results for HVAC	4
23 05 05	Installation Of Pipework	4

23 05 19	Thermometers and Pressure Gauges	4
23 05 23.01	Valves – Bronze	4
23 05 23.02	Valves – Cast Iron	5
23 05 24	Mechanical Identification	6
23 05 29	Hangers and Supports for HVAC Piping and Equipment	7
23 05 48	Vibration And Seismic Controls for HVAC Piping And Equipment	6
23 05 93	Testing, Adjusting and Balancing for HVAC	6
23 07 15	Thermal Insulation for Piping	6
23 08 00	Commissioning of Mechanical Systems	2
23 08 01	Performance Verification Mechanical Piping Systems	3
23 08 02	Cleaning and Start-up of Mechanical Piping Systems	4
23 11 23	Facility Natural Gas Piping	4
23 21 13.02	Hydronic Systems: Steel	5
23 21 14	Hydronic Specialties	4
23 21 23	Hydronic Pumps	5
23 51 00	Breeching, Chimneys and Stacks	3
23 52 00	Heating Boilers	7
<b>Division 26</b>		
26 05 00	Common Work Results for Electrical	7
26 05 20	Wire and Box Connectors (0-1000 V)	3
26 05 21	Wires and Cables (0-1000 V)	4
26 05 22	Connectors and Terminations	2
26 05 29	Hangers and Supports for Electrical Systems	2
26 05 31	Splitters, Junction, Pull Boxes and Cabinets	3
26 05 34	Conduits, Conduit Fastening and Conduit Fitting	4
26 05 44	Installation of Cables in Ducts	3
26 28 21	Moulded Case Circuit Breakers	2

**END OF SECTION**

**Part 1            General**

**1.1                WORK COVERED BY CONTRACT DOCUMENTS**

- .1        Work of this Contract comprises and shall be further identified as “the Work” and shall include the following:
  - .1        Remove the existing boilers comprising the two exiting boilers and provide 2 new condensing boilers and all appurtenances as indicated in the contract drawings and specifications.
  - .2        Provide new variable frequency driven hot water pumps as indicated in the contract drawings and specifications.

**1.2                WORK SEQUENCE**

- .1        Construct Work in a single stage to accommodate Owner's continued use of premises during construction.
- .2        Co-ordinate Progress Schedule and co-ordinate with Owner Occupancy during construction.
- .3        Maintain fire access/control.

**1.3                CONTRACTOR USE OF PREMISES**

- .1        Unrestricted use of site until Substantial Performance.
- .2        Co-ordinate use of premises under direction of Departmental Representative.
- .3        Obtain and pay for use of additional storage or work areas needed for operations under this Contract.

**1.4                OWNER OCCUPANCY**

- .1        Owner will occupy premises during entire construction period for execution of normal operations.
- .2        Co-operate with Owner in scheduling operations to minimize conflict and to facilitate Owner usage.

**1.5                EXISTING SERVICES**

- .1        Notify, Departmental Representative and utility companies of intended interruption of services and obtain required permission.
- .2        Where Work involves breaking into or connecting to existing services, give Departmental Representative 72 hours notice for necessary interruption of mechanical or electrical service throughout course of work. Minimize duration of interruptions. Carry out work at times as directed by governing authorities with minimum disturbance to vehicular traffic and tenant operations.
- .3        Provide alternative routes for personnel and vehicular traffic.

- .4 Establish location and extent of service lines in area of work before starting Work. Notify Departmental Representative of findings.
- .5 Submit schedule to and obtain approval from Departmental Representative for any shut-down or closure of active service or facility including power and communications services. Adhere to approved schedule and provide notice to affected parties.
- .6 Provide temporary services when directed by Departmental Representative to maintain critical building and tenant systems.
- .7 Where unknown services are encountered, immediately advise Departmental Representative and confirm findings in writing.
- .8 Protect, relocate or maintain existing active services. When inactive services are encountered, cap off in manner approved by authorities having jurisdiction.
- .9 Record locations of maintained, re-routed and abandoned service lines.

**1.6 DOCUMENTS REQUIRED**

- .1 Maintain at job site, one copy each document as follows:
  - .1 Contract Drawings.
  - .2 Specifications.
  - .3 Addenda.
  - .4 Reviewed Shop Drawings.
  - .5 List of Outstanding Shop Drawings.
  - .6 Change Orders.
  - .7 Other Modifications to Contract.
  - .8 Field Test Reports.
  - .9 Copy of Approved Work Schedule.
  - .10 Health and Safety Plan and Other Safety Related Documents.
  - .11 Other documents as specified.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not used.

**Part 3 Execution**

**3.1 COMPLETION DATE**

- .1 OCTOBER 15 2017

**END OF SECTION**

**Part 1            General**

**1.1                ADMINISTRATIVE**

- .1     Schedule and administer project meetings throughout the progress of the work at the call of Departmental Representative.
- .2     Prepare agenda for meetings.
- .3     Distribute written notice of each meeting four days in advance of meeting date to Departmental Representative.
- .4     Provide physical space and make arrangements for meetings.
- .5     Preside at meetings.
- .6     Record the meeting minutes. Include significant proceedings and decisions. Identify actions by parties.
- .7     Reproduce and distribute copies of minutes within three days after meetings and transmit to meeting participants and, affected parties not in attendance and Departmental Representative.
- .8     Representative of Contractor, Subcontractor and suppliers attending meetings will be qualified and authorized to act on behalf of party each represents.

**1.2                PRECONSTRUCTION MEETING**

- .1     Within 15 days after award of Contract, request a meeting of parties in contract to discuss and resolve administrative procedures and responsibilities.
- .2     Departmental Representative, Contractor, major Subcontractors, field inspectors and supervisors will be in attendance.
- .3     Establish time and location of meeting and notify parties concerned minimum days before meeting.
- .4     Incorporate mutually agreed variations to Contract Documents into Agreement, prior to signing.
- .5     Agenda to include:
  - .1     Appointment of official representative of participants in the Work.
  - .2     Schedule of submission of shop drawings. Submit submittals in accordance with Section 01 33 00 - Submittal Procedures.
  - .3     Delivery schedule of specified equipment.
  - .4     Proposed changes, change orders, procedures, approvals required, mark-up percentages permitted, time extensions, overtime, administrative requirements.
  - .5     Owner provided products.
  - .6     Record drawings in accordance with Section 01 33 00 - Submittal Procedures.
  - .7     Maintenance manuals in accordance with Section 01 78 00 - Closeout Submittals.

- .8 Take-over procedures, acceptance, warranties in accordance with Section 01 78 00 - Closeout Submittals.
- .9 Monthly progress claims, administrative procedures, photographs, hold backs.
- .10 Appointment of inspection and testing agencies or firms.
- .11 Insurances, transcript of policies.

**1.3 PROGRESS MEETINGS**

- .1 During course of Work and one week prior to project completion, schedule progress meetings.
- .2 Contractor, major Subcontractors involved in Work Departmental Representative are to be in attendance.
- .3 Notify parties minimum four days prior to meetings.
- .4 Record minutes of meetings and circulate to attending parties and affected parties not in attendance within three days after meeting.
- .5 Agenda to include the following:
  - .1 Review, approval of minutes of previous meeting.
  - .2 Review of Work progress since previous meeting.
  - .3 Field observations, problems, conflicts.
  - .4 Problems which impede construction schedule.
  - .5 Review of off-site fabrication delivery schedules.
  - .6 Corrective measures and procedures to regain projected schedule.
  - .7 Revision to construction schedule.
  - .8 Progress schedule, during succeeding work period.
  - .9 Review submittal schedules: expedite as required.
  - .10 Maintenance of quality standards.
  - .11 Review proposed changes for affect on construction schedule and on completion date.
  - .12 Other business.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not Used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not Used.



**END OF SECTION**

**Part 1            General**

**1.1                ADMINISTRATIVE**

- .1        Submit to Departmental Representative submittals listed for review. Submit promptly and in orderly sequence to not cause delay in Work. Failure to submit in ample time is not considered sufficient reason for extension of Contract Time and no claim for extension by reason of such default will be allowed.
- .2        Do not proceed with Work affected by submittal until review is complete.
- .3        Present shop drawings, product data, samples and mock-ups in SI Metric units.
- .4        Where items or information is not produced in SI Metric units converted values are acceptable.
- .5        Review submittals prior to submission to Departmental Representative. This review represents that necessary requirements have been determined and verified, or will be, and that each submittal has been checked and co-ordinated with requirements of Work and Contract Documents. Submittals not stamped, signed, dated and identified as to specific project will be returned without being examined and considered rejected.
- .6        Notify Departmental Representative, in writing at time of submission, identifying deviations from requirements of Contract Documents stating reasons for deviations.
- .7        Verify field measurements and affected adjacent Work are co-ordinated.
- .8        Contractor's responsibility for errors and omissions in submission is not relieved by Departmental Representative review of submittals.
- .9        Contractor's responsibility for deviations in submission from requirements of Contract Documents is not relieved Departmental Representative review.
- .10       Keep one reviewed copy of each submission on site.

**1.2                SHOP DRAWINGS AND PRODUCT DATA**

- .1        The term "shop drawings" means drawings, diagrams, illustrations, schedules, performance charts, brochures and other data which are to be provided by Contractor to illustrate details of a portion of Work.
- .2        Submit drawings stamped and signed by professional engineer registered or licensed in British Columbia of Canada.
- .3        Indicate materials, methods of construction and attachment or anchorage, erection diagrams, connections, explanatory notes and other information necessary for completion of Work. Where articles or equipment attach or connect to other articles or equipment, indicate that such items have been co-ordinated, regardless of Section under which adjacent items will be supplied and installed. Indicate cross references to design drawings and specifications.
- .4        Allow 15 days for Departmental Representative review of each submission.

- .5 Adjustments made on shop drawings by Departmental Representative are not intended to change Contract Price. If adjustments affect value of Work, state such in writing to Departmental Representative prior to proceeding with Work.
- .6 Make changes in shop drawings as Departmental Representative may require, consistent with Contract Documents. When resubmitting, notify Departmental Representative in writing of revisions other than those requested.
- .7 Accompany submissions with transmittal letter, containing:
  - .1 Date.
  - .2 Project title and number.
  - .3 Contractor's name and address.
  - .4 Identification and quantity of each shop drawing, product data and sample.
  - .5 Other pertinent data.
- .8 Submissions include:
  - .1 Date and revision dates.
  - .2 Project title and number.
  - .3 Name and address of:
    - .1 Subcontractor.
    - .2 Supplier.
    - .3 Manufacturer.
  - .4 Contractor's stamp, signed by Contractor's authorized representative certifying approval of submissions, verification of field measurements and compliance with Contract Documents.
  - .5 Details of appropriate portions of Work as applicable:
    - .1 Fabrication.
    - .2 Layout, showing dimensions, including identified field dimensions, and clearances.
    - .3 Setting or erection details.
    - .4 Capacities.
    - .5 Performance characteristics.
    - .6 Standards.
    - .7 Operating weight.
    - .8 Wiring diagrams.
    - .9 Single line and schematic diagrams.
    - .10 Relationship to adjacent work.
- .9 After Departmental Representative review, distribute copies.
- .10 Submit electronic copy and 6 prints of shop drawings for each requirement requested in specification Sections and as Departmental Representative may reasonably request.

- .11 Submit 6 electronic copies of product data sheets or brochures for requirements requested in specification Sections and as requested by Departmental Representative where shop drawings will not be prepared due to standardized manufacture of product.
- .12 Submit 6 copies of test reports for requirements requested in specification Sections and as requested by Departmental Representative.
  - .1 Report signed by authorized official of testing laboratory that material, product or system identical to material, product or system to be provided has been tested in accord with specified requirements.
  - .2 Testing must have been within 3 years of date of contract award for project.
- .13 Submit 6 copies of certificates for requirements requested in specification Sections and as requested by Departmental Representative.
  - .1 Statements printed on manufacturer's letterhead and signed by responsible officials of manufacturer of product, system or material attesting that product, system or material meets specification requirements.
  - .2 Certificates must be dated after award of project contract complete with project name.
- .14 Submit 6 copies of manufacturers instructions for requirements requested in specification Sections and as requested by Departmental Representative.
  - .1 Pre-printed material describing installation of product, system or material, including special notices and Material Safety Data Sheets concerning impedances, hazards and safety precautions.
- .15 Submit 6 copies of Manufacturer's Field Reports for requirements requested in specification Sections and as requested by Departmental Representative.
- .16 Documentation of the testing and verification actions taken by manufacturer's representative to confirm compliance with manufacturer's standards or instructions.
- .17 Submit 3 copies and electronic copy of Operation and Maintenance Data for requirements requested in specification Sections and as requested by Departmental Representative.
- .18 Delete information not applicable to project.
- .19 Supplement standard information to provide details applicable to project.
- .20 If upon review by Departmental Representative, no errors or omissions are discovered or if only minor corrections are made, copies will be returned and fabrication and installation of Work may proceed. If shop drawings are rejected, noted copy will be returned and resubmission of corrected shop drawings, through same procedure indicated above, must be performed before fabrication and installation of Work may proceed.
- .21 The review of shop drawings by Public Works and Government Services Canada (PWGSC) is for sole purpose of ascertaining conformance with general concept.
  - .1 This review shall not mean that PWGSC approves detail design inherent in shop drawings, responsibility for which shall remain with Contractor submitting same, and such review shall not relieve Contractor of responsibility for errors or

omissions in shop drawings or of responsibility for meeting requirements of construction and Contract Documents.

- .2 Without restricting generality of foregoing, Contractor is responsible for dimensions to be confirmed and correlated at job site, for information that pertains solely to fabrication processes or to techniques of construction and installation and for co-ordination of Work of sub-trades.

### **1.3 PHOTOGRAPHIC DOCUMENTATION**

- .1 Submit electronic copy of colour digital photography in jpg format, standard resolution monthly with progress statement as directed by Departmental Representative.
- .2 Project identification: name and number of project and date of exposure indicated.

### **1.4 CERTIFICATES AND TRANSCRIPTS**

- .1 Immediately after award of Contract, submit Workers' Compensation Board status.
- .2 Submit transcription of insurance immediately after award of Contract.

## **Part 2 Products**

### **2.1 NOT USED**

- .1 Not Used.

## **Part 3 Execution**

### **3.1 NOT USED**

- .1 Not Used.

**END OF SECTION**

**Part 1            General**

**1.1                RELATED REQUIREMENTS**

- .1            Section 01 33 00 – Submittal Procedures

**1.2                REFERENCES**

- .1            Canada Labour Code, Part 2, Canada Occupational Safety and Health Regulations.
- .2            Health Canada/Workplace Hazardous Materials Information System (WHMIS)
  - .1            Material Safety Data Sheets (MSDS).
- .3            Province of British Columbia
  - .1            Workers Compensation Act, RSBC 1996 - Updated 2012.

**1.3                SUBMITTALS**

- .1            Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2            Submit site-specific Health and Safety Plan: Within 7 days after date of Notice to Proceed and prior to commencement of Work. Health and Safety Plan must include:
  - .1            Results of site specific safety hazard assessment.
  - .2            Results of safety and health risk or hazard analysis for site tasks and operation.
- .3            Submit 3 copies of Contractor's authorized representative's work site health and safety inspection reports Departmental Representative and authority having jurisdiction.
- .4            Submit copies of reports or directions issued by Federal, Provincial and Territorial health and safety inspectors.
- .5            Submit copies of incident and accident reports.
- .6            Submit WHMIS MSDS - Material Safety Data Sheets.
- .7            Departmental Representative will review Contractor's site-specific Health and Safety Plan and provide comments to Contractor within 15 days after receipt of plan. Revise plan as appropriate and resubmit plan to Departmental Representative within 10 days after receipt of comments from Departmental Representative.
- .8            Departmental Representative review of Contractor's final Health and Safety plan should not be construed as approval and does not reduce the Contractor's overall responsibility for construction Health and Safety.
- .9            Medical Surveillance: where prescribed by legislation, regulation or safety program, submit certification of medical surveillance for site personnel prior to commencement of Work, and submit additional certifications for any new site personnel to Departmental Representative.
- .10          On-site Contingency and Emergency Response Plan: address standard operating procedures to be implemented during emergency situations.

---

**1.4 FILING OF NOTICE**

- .1 File Notice of Project with Provincial authorities prior to beginning of Work.

**1.5 SAFETY ASSESSMENT**

- .1 Perform site specific safety hazard assessment related to project.

**1.6 MEETINGS**

- .1 Schedule and administer Health and Safety meeting with Departmental Representative prior to commencement of Work.

**1.7 GENERAL REQUIREMENTS**

- .1 Develop written site-specific Health and Safety Plan based on hazard assessment prior to beginning site Work and continue to implement, maintain, and enforce plan until final demobilization from site. Health and Safety Plan must address project specifications.
- .2 Departmental Representative may respond in writing, where deficiencies or concerns are noted and may request re-submission with correction of deficiencies or concerns.

**1.8 RESPONSIBILITY**

- .1 Be responsible for health and safety of persons on site, safety of property on site and for protection of persons adjacent to site and environment to extent that they may be affected by conduct of Work.
- .2 Comply with and enforce compliance by employees with safety requirements of Contract Documents, applicable federal, provincial, territorial and local statutes, regulations, and ordinances, and with site-specific Health and Safety Plan.

**1.9 COMPLIANCE REQUIREMENTS**

- .1 Comply with Workers Compensation Act, B.C. Reg.
- .2 Comply with Canada Labour Code, Canada Occupational Safety and Health Regulations.

**1.10 UNFORSEEN HAZARDS**

- .1 When unforeseen or peculiar safety-related factor, hazard, or condition occur during performance of Work, follow procedures in place for Employee's Right to Refuse Work in accordance with Acts and Regulations of British Columbia having jurisdiction and advise Departmental Representative verbally and in writing.

**1.11 HEALTH AND SAFETY CO-ORDINATOR**

- .1 Employ and assign to Work, competent and authorized representative as Health and Safety Co-ordinator. Health and Safety Co-ordinator must:
  - .1 Have site-related working experience specific to activities associated with construction.
  - .2 Have working knowledge of occupational safety and health regulations.

- .3 Be responsible for completing Contractor's Health and Safety Training Sessions and ensuring that personnel not successfully completing required training are not permitted to enter site to perform Work.
- .4 Be responsible for implementing, enforcing daily and monitoring site-specific Contractor's Health and Safety Plan.
- .5 Be on site during execution of Work and report directly to and be under direction site supervisor.

**1.12 POSTING OF DOCUMENTS**

- .1 Ensure applicable items, articles, notices and orders are posted in conspicuous location on site in accordance with Acts and Regulations of Province having jurisdiction, and in consultation with Departmental Representative.

**1.13 CORRECTION OF NON-COMPLIANCE**

- .1 Immediately address health and safety non-compliance issues identified by authority having jurisdiction or by Departmental Representative.
- .2 Provide Departmental Representative with written report of action taken to correct non-compliance of health and safety issues identified.
- .3 Departmental Representative may stop Work if non-compliance of health and safety regulations is not corrected.

**1.14 WORK STOPPAGE**

- .1 Give precedence to safety and health of public and site personnel and protection of environment over cost and schedule considerations for Work.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not used.

**END OF SECTION**



**Part 1 General**

**1.1 REFERENCES AND CODES**

- .1 Perform Work in accordance with National Building Code of Canada (NBC) including amendments up to tender closing date and other codes of provincial or local application provided that in case of conflict or discrepancy, more stringent requirements apply.
- .2 Meet or exceed requirements of:
  - .1 Contract documents.
  - .2 Specified standards, codes and referenced documents.

**1.2 HAZARDOUS MATERIAL DISCOVERY**

- .1 Asbestos: demolition of spray or trowel-applied asbestos is hazardous to health. Stop work immediately when material resembling spray or trowel-applied asbestos is encountered during demolition work. Notify Departmental Representative.
- .2 Mould: stop work immediately when material resembling mould is encountered during demolition work. Notify Departmental Representative.

**1.3 BUILDING SMOKING ENVIRONMENT**

- .1 Comply with smoking restrictions and municipal by-laws.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not Used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not Used.

**END OF SECTION**

**Part 1            General**

**1.1                INSPECTION**

- .1      Allow Departmental Representative access to Work. If part of Work is in preparation at locations other than Place of Work, allow access to such Work whenever it is in progress.
- .2      Give timely notice requesting inspection if Work is designated for special tests, inspections or approvals by Departmental Representative instructions, or law of Place of Work.
- .3      If Contractor covers or permits to be covered Work that has been designated for special tests, inspections or approvals before such is made, uncover such Work, have inspections or tests satisfactorily completed and make good such Work.
- .4      Departmental Representative will order part of Work to be examined if Work is suspected to be not in accordance with Contract Documents. If, upon examination such work is found not in accordance with Contract Documents, correct such Work and pay cost of examination and correction. If such Work is found in accordance with Contract Documents, Departmental Representative shall pay cost of examination and replacement.

**1.2                INDEPENDENT INSPECTION AGENCIES**

- .1      Independent Inspection/Testing Agencies will be engaged by Departmental Representative for purpose of inspecting and/or testing portions of Work. Cost of such services will be borne by Departmental Representative.
- .2      Provide equipment required for executing inspection and testing by appointed agencies.
- .3      Employment of inspection/testing agencies does not relax responsibility to perform Work in accordance with Contract Documents.
- .4      If defects are revealed during inspection and/or testing, appointed agency will request additional inspection and/or testing to ascertain full degree of defect. Correct defect and irregularities as advised by Departmental Representative Pay costs for retesting and reinspection.

**1.3                ACCESS TO WORK**

- .1      Allow inspection/testing agencies access to Work, off site manufacturing and fabrication plants.
- .2      Co-operate to provide reasonable facilities for such access.

**1.4                PROCEDURES**

- .1      Notify appropriate agency and Departmental Representative in advance of requirement for tests, in order that attendance arrangements can be made.

- .2 Submit samples and/or materials required for testing, as specifically requested in specifications. Submit with reasonable promptness and in orderly sequence to not cause delays in Work.
- .3 Provide labour and facilities to obtain and handle samples and materials on site. Provide sufficient space to store and cure test samples.

**1.5 REJECTED WORK**

- .1 Remove defective Work, whether result of poor workmanship, use of defective products or damage and whether incorporated in Work or not, which has been rejected by Departmental Representative as failing to conform to Contract Documents. Replace or re-execute in accordance with Contract Documents.
- .2 Make good other Contractor's work damaged by such removals or replacements promptly.

**1.6 REPORTS**

- .1 Submit 4 copies of inspection and test reports to Departmental Representative.

**1.7 MOCK-UPS**

- .1 Prepare mock-ups for Work specifically requested in specifications. Include for Work of Sections required to provide mock-ups.
- .2 Construct in locations acceptable to Departmental Representative.
- .3 Prepare mock-ups for Departmental Representative review with reasonable promptness and in orderly sequence, to not cause delays in Work.
- .4 Failure to prepare mock-ups in ample time is not considered sufficient reason for extension of Contract Time and no claim for extension by reason of such default will be allowed.
- .5 If requested, Departmental Representative will assist in preparing schedule fixing dates for preparation.
- .6 Remove mock-up at conclusion of Work or when acceptable to Departmental Representative.
- .7 Mock-ups may remain as part of Work.
- .8 Specification section identifies whether mock-up may remain as part of Work or if it is to be removed and when.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not Used.

---

**Part 3            Execution**

**3.1                NOT USED**

.1                Not Used.

**END OF SECTION**

**Part 1            General**

**1.1                REFERENCES**

- .1        Conform to these reference standards, in whole or in part as specifically requested in specifications.
- .2        If there is question as to whether products or systems are in conformance with applicable standards, Departmental Representative reserves right to have such products or systems tested to prove or disprove conformance.
- .3        Cost for such testing will be born by Departmental Representative in event of conformance with Contract Documents or by Contractor in event of non-conformance.

**1.2                QUALITY**

- .1        Products, materials, equipment and articles incorporated in Work shall be new, not damaged or defective, and of best quality for purpose intended. If requested, furnish evidence as to type, source and quality of products provided.
- .2        Procurement policy is to acquire, in cost effective manner, items containing highest percentage of recycled and recovered materials practicable consistent with maintaining satisfactory levels of competition. Make reasonable efforts to use recycled and recovered materials and in otherwise utilizing recycled and recovered materials in execution of work.
- .3        Defective products, whenever identified prior to completion of Work, will be rejected, regardless of previous inspections. Inspection does not relieve responsibility, but is precaution against oversight or error. Remove and replace defective products at own expense and be responsible for delays and expenses caused by rejection.
- .4        Should disputes arise as to quality or fitness of products, decision rests strictly with Departmental Representative based upon requirements of Contract Documents.
- .5        Unless otherwise indicated in specifications, maintain uniformity of manufacture for any particular or like item throughout building.
- .6        Permanent labels, trademarks and nameplates on products are not acceptable in prominent locations, except where required for operating instructions, or when located in mechanical or electrical rooms.

**1.3                AVAILABILITY**

- .1        Immediately upon signing Contract, review product delivery requirements and anticipate foreseeable supply delays for items. If delays in supply of products are foreseeable, notify Departmental Representative of such, in order that substitutions or other remedial action may be authorized in ample time to prevent delay in performance of Work.
- .2        In event of failure to notify Departmental Representative at commencement of Work and should it subsequently appear that Work may be delayed for such reason,

Departmental Representative reserves right to substitute more readily available products of similar character, at no increase in Contract Price or Contract Time.

#### **1.4 STORAGE, HANDLING AND PROTECTION**

- .1 Handle and store products in manner to prevent damage, adulteration, deterioration and soiling and in accordance with manufacturer's instructions when applicable.
- .2 Store packaged or bundled products in original and undamaged condition with manufacturer's seal and labels intact. Do not remove from packaging or bundling until required in Work.
- .3 Store products subject to damage from weather in weatherproof enclosures.
- .4 Remove and replace damaged products at own expense and to satisfaction of Departmental Representative.
- .5 Touch-up damaged factory finished surfaces to Departmental Representative satisfaction. Use touch-up materials to match original. Do not paint over name plates.

#### **1.5 TRANSPORTATION**

- .1 Pay costs of transportation of products required in performance of Work.
- .2 Transportation cost of products supplied by Owner will be paid for by Departmental Representative. Unload, handle and store such products.

#### **1.6 MANUFACTURER'S INSTRUCTIONS**

- .1 Unless otherwise indicated in specifications, install or erect products in accordance with manufacturer's instructions. Do not rely on labels or enclosures provided with products. Obtain written instructions directly from manufacturers.
- .2 Notify Departmental Representative in writing, of conflicts between specifications and manufacturer's instructions, so that Departmental Representative will establish course of action.
- .3 Improper installation or erection of products, due to failure in complying with these requirements, authorizes Departmental Representative to require removal and re-installation at no increase in Contract Price or Contract Time.

#### **1.7 QUALITY OF WORK**

- .1 Ensure Quality of Work is of highest standard, executed by workers experienced and skilled in respective duties for which they are employed. Immediately notify Departmental Representative if required Work is such as to make it impractical to produce required results.
- .2 Do not employ anyone unskilled in their required duties. Departmental Representative reserves right to require dismissal from site, workers deemed incompetent or careless.
- .3 Decisions as to standard or fitness of Quality of Work in cases of dispute rest solely with Departmental Representative, whose decision is final.

**1.8 CO-ORDINATION**

- .1 Ensure co-operation of workers in laying out Work. Maintain efficient and continuous supervision.
- .2 Be responsible for coordination and placement of openings, sleeves and accessories.

**1.9 CONCEALMENT**

- .1 In finished areas conceal pipes, ducts and wiring in floors, walls and ceilings, except where indicated otherwise.
- .2 Before installation inform Departmental Representative if there is interference. Install as directed by Departmental Representative.

**1.10 REMEDIAL WORK**

- .1 Perform remedial work required to repair or replace parts or portions of Work identified as defective or unacceptable. Co-ordinate adjacent affected Work as required.
- .2 Perform remedial work by specialists familiar with materials affected. Perform in a manner to neither damage nor put at risk any portion of Work.

**1.11 LOCATION OF FIXTURES**

- .1 Consider location of fixtures, outlets, and mechanical and electrical items indicated as approximate.
- .2 Inform Departmental Representative of conflicting installation. Install as directed.

**1.12 FASTENINGS**

- .1 Provide metal fastenings and accessories in same texture, colour and finish as adjacent materials, unless indicated otherwise.
- .2 Prevent electrolytic action between dissimilar metals and materials.
- .3 Use non-corrosive hot dip galvanized steel fasteners and anchors for securing exterior work, unless stainless steel or other material is specifically requested in affected specification Section.
- .4 Space anchors within individual load limit or shear capacity and ensure they provide positive permanent anchorage. Wood, or any other organic material plugs are not acceptable.
- .5 Keep exposed fastenings to a minimum, space evenly and install neatly.
- .6 Fastenings which cause spalling or cracking of material to which anchorage is made are not acceptable.

**1.13 FASTENINGS - EQUIPMENT**

- .1 Use fastenings of standard commercial sizes and patterns with material and finish suitable for service.
- .2 Use heavy hexagon heads, semi-finished unless otherwise specified. Use No. 304 stainless steel for exterior areas.

- .3 Bolts may not project more than one diameter beyond nuts.
- .4 Use plain type washers on equipment, sheet metal and soft gasket lock type washers where vibrations occur. Use resilient washers with stainless steel.

**1.14 PROTECTION OF WORK IN PROGRESS**

- .1 Prevent overloading of parts of building. Do not cut, drill or sleeve load bearing structural member, unless specifically indicated without written approval of Departmental Representative.

**1.15 EXISTING UTILITIES**

- .1 When breaking into or connecting to existing services or utilities, execute Work at times directed by local governing authorities, with minimum of disturbance to Work, and/or building occupants.
- .2 Protect, relocate or maintain existing active services. When services are encountered, cap off in manner approved by authority having jurisdiction. Stake and record location of capped service.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not Used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not Used.

**END OF SECTION**



**Part 1            General**

**1.1                PROJECT CLEANLINESS**

- .1      Maintain Work in tidy condition, free from accumulation of waste products and debris, including that caused by Owner or other Contractors.
- .2      Remove waste materials from site at daily regularly scheduled times or dispose of as directed by Departmental Representative. Do not burn waste materials on site.
- .3      Make arrangements with and obtain permits from authorities having jurisdiction for disposal of waste and debris.
- .4      Provide and use marked separate bins for recycling. Refer to Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .5      Clean interior areas prior to start of finishing work, and maintain areas free of dust and other contaminants during finishing operations.
- .6      Store volatile waste in covered metal containers, and remove from premises at end of each working day.
- .7      Provide adequate ventilation during use of volatile or noxious substances. Use of building ventilation systems is not permitted for this purpose.
- .8      Use only cleaning materials recommended by manufacturer of surface to be cleaned, and as recommended by cleaning material manufacturer.
- .9      Schedule cleaning operations so that resulting dust, debris and other contaminants will not fall on wet, newly painted surfaces nor contaminate building systems.

**1.2                FINAL CLEANING**

- .1      When Work is Substantially Performed remove surplus products, tools, construction machinery and equipment not required for performance of remaining Work.
- .2      Remove waste products and debris other than that caused by others, and leave Work clean and suitable for occupancy.
- .3      Prior to final review remove surplus products, tools, construction machinery and equipment.
- .4      Remove waste products and debris including that caused by Owner or other Contractors.
- .5      Remove waste materials from site at regularly scheduled times or dispose of as directed by Departmental Representative. Do not burn waste materials on site.
- .6      Make arrangements with and obtain permits from authorities having jurisdiction for disposal of waste and debris.
- .7      Remove stains, spots, marks and dirt from decorative work, electrical and mechanical fixtures, furniture fitments, walls and floors.
- .8      Wax, seal, shampoo or prepare floor finishes, as recommended by manufacturer.

- .9 Inspect finishes, fitments and equipment and ensure specified workmanship and operation.
- .10 Broom clean and wash exterior walks, steps and surfaces; rake clean other surfaces of grounds.

**1.3 WASTE MANAGEMENT AND DISPOSAL**

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management And Disposal.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not Used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not Used.

**END OF SECTION**

---

**Part 1            General**

**1.1                WASTE MANAGEMENT GOALS**

- .1        Prior to start of Work conduct meeting with Departmental Representative to review and discuss Fisheries and Ocean's and PWGSC's waste management goal and Contractor's proposed Waste Reduction Workplan for Construction, Renovation and /or Demolition (CRD) waste to be project generated.
- .2        Minimize amount of non-hazardous solid waste generated by project and accomplish maximum source reduction, reuse and recycling of solid waste produced by CRD activities.
- .3        Protect environment and prevent environmental pollution damage.

**1.2                REFERENCES**

- .1        Definitions:
  - .1        Approved/Authorized recycling facility: waste recycler approved by applicable provincial authority or other users of material for recycling approved by the Departmental Representative.
  - .2        Class III: non-hazardous waste - construction renovation and demolition waste.
  - .3        Construction, Renovation and/or Demolition (CRD) Waste: Class III solid, non-hazardous waste materials generated during construction, demolition, and/or renovation activities
  - .4        Cost/Revenue Analysis Workplan (CRAW): based on information from Waste Reduction Workplan, and intended as financial tracking tool for determining economic status of waste management practices (Schedule E).
  - .5        Inert Fill: inert waste - exclusively asphalt and concrete.
  - .6        Waste Source Separation Program (WSSP): implementation and co-ordination of ongoing activities to ensure designated waste materials will be sorted into pre-defined categories and sent for recycling and reuse, maximizing diversion and potential to reduce disposal costs.
  - .7        Recyclable: ability of product or material to be recovered at end of its life cycle and re-manufactured into new product for reuse.
  - .8        Recycle: process by which waste and recyclable materials are transformed or collected for purpose of being transferred into new products.
  - .9        Recycling: process of sorting, cleansing, treating and reconstituting solid waste and other discarded materials for purpose of using in altered form. Recycling does not include burning, incinerating, or thermally destroying waste.
  - .10      Reuse: repeated use of product in same form but not necessarily for same purpose. Reuse includes:

- .1 Salvaging reusable materials from re-modelling projects, before demolition stage, for resale, reuse on current project or for storage for use on future projects.
- .2 Returning reusable items including pallets or unused products to vendors.
- .11 Salvage: removal of structural and non-structural materials from deconstruction/disassembly projects for purpose of reuse or recycling.
- .12 Separate Condition: refers to waste sorted into individual types.
- .13 Source Separation: act of keeping different types of waste materials separate beginning from the point they became waste.

### **1.3 DOCUMENTS**

- .1 Post and maintain in visible and accessible area at job site, one copy of following documents:
  - .1 Waste Audit (Schedule A).
  - .2 Waste Reduction Workplan (Schedule B).
  - .3 Schedules A B completed for project.

### **1.4 ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Prepare and submit following prior to project start-up:
  - .1 1 copy and 1 electronic copy of completed Waste Audit (WA): Schedule A.
  - .2 1 copy and 1 electronic copy of completed Waste Reduction Workplan (WRW): Schedule B.
  - .3 1 copy and 1 electronic copy of Waste Source Separation Program (WSSP).
- .3 Prepare and submit at intervals agreed to by Departmental Representative the following:
  - .1 Receipts, scale tickets, waybills, and/or waste disposal receipts that show quantities and types of materials reused, recycled, or disposed of.
  - .2 Written monthly summary report detailing cumulative amounts of waste materials reused, recycled and landfilled, and brief status of ongoing waste management activities.
- .4 Submit prior to final payment the following:
  - .1 Waste Diversion Report, indicating final quantities in tones by material types salvaged for reuse, recycling or disposal in landfill and recycling centres, re-use depots, landfills and other waste processors that received waste materials.
  - .2 Provide receipts, scale tickets, waybills, waste disposal receipts that confirm quantities and types of materials reused, recycled or disposed of and destination.

---

**1.5 WASTE AUDIT (WA)**

- .1 Departmental Representative will prepare WA prior to project start-up. WA will be provided with bid documentation (see Schedule A).
- .2 WA provides detailed inventory, estimated quantities and types of waste materials that will be generated as well as their potential to be reused and/or recycled and project's waste diversion goals and objectives.
- .3 After award of contract, contractor to review WA and confirm that anticipated quantities of waste generated are accurate and goals achievable.
- .4 If after review, contractor determines that indicated quantities or opportunities in WA are not accurate or achievable, contractor to provide written details of discrepancies and revised quantities for areas of concern. Contractor to meet with Departmental Representative to review and justify revisions.
- .5 Post on-site WA where contractor and sub-contractors are able to review content.

**1.6 WASTE REDUCTION WORKPLAN (WRW)**

- .1 Prepare and submit WRW (Schedule B) at least 10 days prior to project start-up.
- .2 WRW identifies strategies to optimize diversion through reduction, reuse, and recycling of materials and comply with applicable regulations, based on information acquired from WA.
- .3 WRW should include but not limited to:
  - .1 Applicable regulations.
  - .2 Specific goals for waste reduction, identify existing barriers and develop strategies to overcome them.
  - .3 Destination of materials identified.
  - .4 Deconstruction/disassembly techniques and schedules.
  - .5 Methods to collect, separate, and reduce generated wastes.
  - .6 Location of waste bins on-site.
  - .7 Security of on-site stock piles and waste bins.
  - .8 Protection of personnel, sub-contractors.
  - .9 Clear labelling of storage areas.
  - .10 Training plan for contractor and sub-contractors.
  - .11 Methods to track and report results reliably.
  - .12 Details on materials handling and removal procedures.
  - .13 Recycler and reclaimer requirements.
  - .14 Quantities of materials to be salvaged for reuse or recycled and materials sent to landfill.
  - .15 Requirements for monitoring on-site wastes management activities.
- .4 Structure WRW to prioritize actions and follow 3R's hierarchy, with Reduction as first priority, followed by Reuse, then Recycle.

- .5 Post WRW or summary where workers at site are able to review content.
- .6 Monitor and report on waste reduction by documenting total volume (in tonnes) and cost of actual waste removed from project.

### **1.7 WASTE SOURCE SEPARATION PROGRAM (WSSP)**

- .1 As part of Waste Reduction Workplan, prepare WSSP prior to project start-up.
- .2 WSSP will detail methodology and planned on-site activities for separation of reusable and recyclable materials from waste intended for landfill.
- .3 Provide list and drawings of locations that will be made available for sorting, collection, handling and storage of anticipated quantities of reusable and recyclable materials.
- .4 Provide sufficient on-site facilities and containers for collection, handling, and storage of anticipated quantities of reusable and recyclable materials.
- .5 Locate containers to facilitate deposit of materials without hindering daily operations.
- .6 Provide training for contractor in handling and separation of materials for reuse and/or recycling.
- .7 Locate separated materials in areas which minimizes material damage.
- .8 Clearly and securely label containers to identify types/conditions of materials accepted and assist contractor in separating materials accordingly.
- .9 Monitor on-site waste management activities by conducting periodic site inspections to verify: state of signage, contamination levels, bin locations and condition, personnel participation, use of waste tracking forms and collection of waybills, receipts and invoices.
- .10 On-site sale of salvaged materials is not permitted unless authorized in writing by Departmental Representative and provided that site safety regulations and security requirements are adhered to.

### **1.8 USE OF SITE AND FACILITIES**

- .1 Execute Work with minimal interference and disturbance to normal use of premises.
- .2 Maintain security measures established by facility provide temporary security measures reviewed by Departmental Representative.

### **1.9 WASTE PROCESSING SITES**

- .1 Contractor is responsible to research and locate waste diversion resources and service providers. Salvaged materials are to be transported off site to approved and/or authorized recycling facilities or to users of material for recycling.

---

**1.10 QUALITY ASSURANCE**

- .1 After award of Contract, a mandatory site examination will be held for this Project for Contractor responsible for construction, renovation demolition/deconstruction waste management.
  - .1 Date, time and location will be arranged by Departmental Representative.
- .2 Waste Management Meeting: Waste Management Co-ordinator is to provide an update on status of waste diversion and management activities at each meeting. Written monthly Waste Diversion Report summary to be provided by the Waste Management Coordinator.

**1.11 STORAGE, HANDLING AND PROTECTION**

- .1 Store, materials to be reused, recycled and salvaged in locations as directed by Departmental Representative.
- .2 Unless specified otherwise, materials for removal do not become Contractor's property.
- .3 Protect, stockpile, store and catalogue salvaged items.
- .4 Separate non-salvageable materials from salvaged items. Transport and deliver non-salvageable items to licensed disposal facility.
- .5 Protect structural components not removed and salvaged materials from movement or damage.
- .6 Support affected structures. If safety of building is endangered, cease operations and immediately notify Departmental Representative.
- .7 Protect surface drainage, mechanical and electrical from damage and blockage.
- .8 Provide on-site facilities and containers for collection and storage of reusable and recyclable materials.
- .9 Separate and store materials produced during project in designated areas.
- .10 Prevent contamination of materials to be salvaged and recycled and handle materials in accordance with requirements for acceptance by designated processing facilities.
  - .1 On-site source separation is recommended.
  - .2 Remove co-mingled materials to off site processing facility for separation.
  - .3 Obtain waybills, receipts and/or scale tickets for separated materials removed from site.
  - .4 Materials reused on-site are considered to be diverted from landfill and as such are to be included in all reporting.

**1.12 DISPOSAL OF WASTES**

- .1 Do not bury rubbish or waste materials.

- .2 Do not dispose of waste, volatile materials, mineral spirits, oil or paint thinner into waterways, storm, or sanitary sewers.
- .3 Keep records of construction waste including:
  - .1 Number and size of bins.
  - .2 Waste type of each bin.
  - .3 Total tonnage generated.
  - .4 Tonnage reused or recycled.
  - .5 Reused or recycled waste destination.
- .4 Remove materials on-site as Work progresses.
- .5 Prepare project summary to verify destination and quantities on a material-by-material basis as identified in the waste audit.

### **1.13 SCHEDULING**

- .1 Co-ordinate Work with other activities at site to ensure timely and orderly progress of Work.

## **Part 2 Products**

### **2.1 NOT USED**

- .1 Not Used.

## **Part 3 Execution**

### **3.1 APPLICATION**

- .1 Do Work in compliance with WSSP.
- .2 Handle waste materials not reused, salvaged, or recycled in accordance with appropriate regulations and codes.

### **3.2 CLEANING**

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
  - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
  - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.
  - .2 Source separate materials to be reused/recycled into specified sort areas.



**3.3 DIVERSION OF MATERIALS**

- .1 Separate materials from general waste stream and stockpile in separate piles or containers, as reviewed by Departmental Representative, and consistent with applicable fire regulations.
  - .1 Mark containers or stockpile areas.
  - .2 Provide instruction on disposal practices.
- .2 On-site sale of salvaged, recovered, reusable or recyclable materials is not permitted.

**3.4 WASTE DIVERSION REPORT**

- .1 At completion of Project, prepare a written Waste Diversion Report indicating quantities of materials reused, recycled or disposed of as well as the following:
  - .1 Identify final diversion results and measure success against goals from Waste Reduction Workplan.
  - .2 Compare final quantities/percentages diverted with initial projections in Waste Audit and Waste Reduction Workplan and explain variances.
    - .1 Supporting documentation.
    - .2 Waybills and tracking forms.
    - .3 Description of issues, resolutions and lessons learned.

**3.5 WASTE AUDIT (WA)**

- .1 Schedule A - Waste Audit (WA)

(1) Material Category	(2) Material Quantity Unit	(3) Estimated Waste %	(4) Total Quantity of Waste (unit)	(5) Generation Point	(6) % Recycled	(7) % Reused
Wood and Plastics Material Description						
Off-cuts						
Warped Pallet Forms						
Plastic Packaging						
Cardboard Packaging						
Other						
Metal						
Other						
Insulation						
Masonry						
Concrete						

Other						
-------	--	--	--	--	--	--

**3.6 WASTE REDUCTION WORKPLAN (WRW)**

.1 Schedule B

(1) Material Category	(2) Person(s) Respon- sible	(3) Total Quantity of Waste (unit)	(4) Reused Amount (units) Projected	Actual	(5) Recycled Amount (unit) Projected	Actual	(6) Material(s) Destina- tion
Wood and Plastics Material Description							
Chutes							
Warped Pallet Forms							
Plastic Packaging							
Card- board Packaging							
Other							
Wood							
Metal							
Other							
Insulation							
Masonry							
Concrete							
Other							

**3.7 CANADIAN GOVERNMENTAL DEPARTMENTS CHIEF RESPONSIBILITY FOR THE ENVIRONMENT**

.1 Schedule G - Government Chief Responsibility for the Environment:

Province	Address	General Inquires	Fax
British Columbia	Ministry of Environment Lands and Parks 810 Blanshard Street, 4 th Floor Victoria BC V8V 1X4	604-387-1161	604-356-6464
	Waste Reduction Commission Soils and Hazardous Waste 770	604-660-9550	604-660-9596

	South Pacific Blvd, Suite 303 Vancouver BC V6B 5E7		
--	--	--	--

**3.8 SCHEDULES**

- .1 Following Schedules are attached to this Specification:
  - .1 Waste Audit - Schedule A.
  - .2 Waste Reduction Workplan Form - Schedule B.
  - .3 Government Chief Responsibility for the Environment – Schedule G.

**END OF SECTION**

**Part 1            General**

**1.1                ADMINISTRATIVE REQUIREMENTS**

- .1    Pre-warranty Meeting:
  - .1    Convene meeting one week prior to contract completion with Departmental Representative, in accordance with Section 01 31 19 - Project Meetings to:
    - .1    Verify Project requirements.
    - .2    Review warranty requirements and manufacturer's installation instructions.
  - .2    Departmental Representative to establish communication procedures for:
    - .1    Notifying construction warranty defects.
    - .2    Determine priorities for type of defects.
    - .3    Determine reasonable response time.
  - .3    Contact information for bonded and licensed company for warranty work action: provide name, telephone number and address of company authorized for construction warranty work action.
  - .4    Ensure contact is located within local service area of warranted construction, is continuously available, and is responsive to inquiries for warranty work action.

**1.2                ACTION AND INFORMATIONAL SUBMITTALS**

- .1    Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2    Two weeks prior to Substantial Performance of the Work, submit to the Departmental Representative, four final copies of operating and maintenance manuals in English.
- .3    Provide spare parts, maintenance materials and special tools of same quality and manufacture as products provided in Work.
- .4    Provide evidence, if requested, for type, source and quality of products supplied.

**1.3                FORMAT**

- .1    Organize data as instructional manual.
- .2    Binders: vinyl, hard covered, 3 'D' ring, loose leaf 219 x 279 mm with spine and face pockets.
- .3    When multiple binders are used correlate data into related consistent groupings.
  - .1    Identify contents of each binder on spine.
- .4    Cover: identify each binder with type or printed title 'Project Record Documents'; list title of project and identify subject matter of contents.
- .5    Arrange content by systems, under Section numbers and sequence of Table of Contents.
- .6    Provide tabbed fly leaf for each separate product and system, with typed description of product and major component parts of equipment.

- .7 Text: manufacturer's printed data, or typewritten data.
- .8 Drawings: provide with reinforced punched binder tab.
  - .1 Bind in with text; fold larger drawings to size of text pages.
- .9 Provide 1:1 scaled CAD files in dwg format on USB Stick in each binder and operation and maintenance manual with hard copies of as-built drawings in each binder.

#### **1.4 CONTENTS - PROJECT RECORD DOCUMENTS**

- .1 Table of Contents for Each Volume: provide title of project;
  - .1 Date of submission; names.
  - .2 Addresses, and telephone numbers of Consultant and Contractor with name of responsible parties.
  - .3 Schedule of products and systems, indexed to content of volume.
- .2 For each product or system:
  - .1 List names, addresses and telephone numbers of subcontractors and suppliers, including local source of supplies and replacement parts.
- .3 Product Data: mark each sheet to identify specific products and component parts, and data applicable to installation; delete inapplicable information.
- .4 Drawings: supplement product data to illustrate relations of component parts of equipment and systems, to show control and flow diagrams.
- .5 Typewritten Text: as required to supplement product data.
  - .1 Provide logical sequence of instructions for each procedure, incorporating manufacturer's instructions specified in Section 01 45 00 - Quality Control.
- .6 Training: refer to Section 01 79 00 - Demonstration and Training.

#### **1.5 AS -BUILT DOCUMENTS AND SAMPLES**

- .1 Maintain, at site for Departmental Representative record copy of:
  - .1 Contract Drawings.
  - .2 Specifications.
  - .3 Addenda.
  - .4 Change Orders and other modifications to Contract.
  - .5 Reviewed shop drawings, product data, and samples.
  - .6 Field test records.
  - .7 Inspection certificates.
  - .8 Manufacturer's certificates.
- .2 Store record documents and samples in field office apart from documents used for construction.
  - .1 Provide files, racks, and secure storage.

- .3 Label record documents and file in accordance with Section number listings in List of Contents of this Project Manual.
  - .1 Label each document "PROJECT RECORD" in neat, large, printed letters.
- .4 Maintain record documents in clean, dry and legible condition.
  - .1 Do not use record documents for construction purposes.
- .5 Keep record documents and samples available for inspection by Departmental Representative.

## **1.6 RECORDING INFORMATION ON PROJECT RECORD DOCUMENTS**

- .1 Record information on set of black line opaque drawings, provided by Departmental Representative.
- .2 Use felt tip marking pens, maintaining separate colours for each major system, for recording information.
- .3 Record information concurrently with construction progress.
  - .1 Do not conceal Work until required information is recorded.
- .4 Contract Drawings and shop drawings: mark each item to record actual construction, including:
  - .1 Measured locations of internal utilities and appurtenances, referenced to visible and accessible features of construction.
  - .2 Field changes of dimension and detail.
  - .3 Changes made by change orders.
  - .4 Details not on original Contract Drawings.
  - .5 References to related shop drawings and modifications.
- .5 Specifications: mark each item to record actual construction, including:
  - .1 Manufacturer, trade name, and catalogue number of each product actually installed, particularly optional items and substitute items.
  - .2 Changes made by Addenda and change orders.
- .6 Other Documents: maintain manufacturer's certifications, inspection certifications, field test records, required by individual specifications sections.
- .7 Provide digital photos, if requested, for site records.

## **1.7 EQUIPMENT AND SYSTEMS**

- .1 For each item of equipment and each system include description of unit or system, and component parts.
  - .1 Give function, normal operation characteristics and limiting conditions.
  - .2 Include performance curves, with engineering data and tests, and complete nomenclature and commercial number of replaceable parts.

- .2 Panel board circuit directories: provide electrical service characteristics, controls, and communications.
- .3 Include installed colour coded wiring diagrams.
- .4 Operating Procedures: include start-up, break-in, and routine normal operating instructions and sequences.
  - .1 Include regulation, control, stopping, shut-down, and emergency instructions.
  - .2 Include summer, winter, and any special operating instructions.
- .5 Maintenance Requirements: include routine procedures and guide for trouble-shooting; disassembly, repair, and reassembly instructions; and alignment, adjusting, balancing, and checking instructions.
- .6 Provide servicing and lubrication schedule, and list of lubricants required.
- .7 Include manufacturer's printed operation and maintenance instructions.
- .8 Include sequence of operation by controls manufacturer.
- .9 Provide original manufacturer's parts list, illustrations, assembly drawings, and diagrams required for maintenance.
- .10 Provide installed control diagrams by controls manufacturer.
- .11 Provide Contractor's co-ordination drawings, with installed colour coded piping diagrams.
- .12 Provide charts of valve tag numbers, with location and function of each valve, keyed to flow and control diagrams.
- .13 Provide list of original manufacturer's spare parts, current prices, and recommended quantities to be maintained in storage.
- .14 Include test and balancing reports as specified in Section 01 45 00 - Quality Control and 01 91 13 - General Commissioning (Cx) Requirements.
- .15 Additional requirements: as specified in individual specification sections.

## **1.8 MATERIALS AND FINISHES**

- .1 Building products, applied materials, and finishes: include product data, with catalogue number, size, composition, and colour and texture designations.
  - .1 Provide information for re-ordering custom manufactured products.
- .2 Instructions for cleaning agents and methods, precautions against detrimental agents and methods, and recommended schedule for cleaning and maintenance.
- .3 Moisture-protection and weather-exposed products: include manufacturer's recommendations for cleaning agents and methods, precautions against detrimental agents and methods, and recommended schedule for cleaning and maintenance.
- .4 Additional requirements: as specified in individual specifications sections.

---

**1.9 MAINTENANCE MATERIALS**

- .1 Spare Parts:
  - .1 Provide spare parts, in quantities specified in individual specification sections.
  - .2 Provide items of same manufacture and quality as items in Work.
  - .3 Deliver to location as directed; place and store.
  - .4 Receive and catalogue items.
    - .1 Submit inventory listing to Departmental Representative.
    - .2 Include approved listings in Maintenance Manual.
  - .5 Obtain receipt for delivered products and submit prior to final payment.
- .2 Extra Stock Materials:
  - .1 Provide maintenance and extra materials, in quantities specified in individual specification sections.
  - .2 Provide items of same manufacture and quality as items in Work.
  - .3 Deliver to location as directed; place and store.
  - .4 Receive and catalogue items.
    - .1 Submit inventory listing Departmental Representative.
    - .2 Include approved listings in Maintenance Manual.
  - .5 Obtain receipt for delivered products and submit prior to final payment.
- .3 Special Tools:
  - .1 Provide special tools, in quantities specified in individual specification section.
  - .2 Provide items with tags identifying their associated function and equipment.
  - .3 Deliver to location as directed; place and store.
  - .4 Receive and catalogue items.
    - .1 Submit inventory listing to Departmental Representative.
    - .2 Include approved listings in Maintenance Manual.

**1.10 DELIVERY, STORAGE AND HANDLING**

- .1 Store spare parts, maintenance materials, and special tools in manner to prevent damage or deterioration.
- .2 Store in original and undamaged condition with manufacturer's seal and labels intact.
- .3 Store components subject to damage from weather in weatherproof enclosures.
- .4 Store paints and freezable materials in a heated and ventilated room.
- .5 Remove and replace damaged products at own expense and for review by Departmental Representative.

**1.11 WARRANTIES AND BONDS**

- .1 Develop warranty management plan to contain information relevant to Warranties.



- .2 Submit warranty management plan, 30 days before planned pre-warranty conference, to Departmental Representative approval.
- .3 Warranty management plan to include required actions and documents to assure that Departmental Representative receives warranties to which it is entitled.
- .4 Provide plan in narrative form and contain sufficient detail to make it suitable for use by future maintenance and repair personnel.
- .5 Submit, warranty information made available during construction phase, to Departmental Representative for approval prior to each monthly pay estimate.
- .6 Assemble approved information in binder, submit upon acceptance of work and organize binder as follows:
  - .1 Separate each warranty or bond with index tab sheets keyed to Table of Contents listing.
  - .2 List subcontractor, supplier, and manufacturer, with name, address, and telephone number of responsible principal.
  - .3 Obtain warranties and bonds, executed in duplicate by subcontractors, suppliers, and manufacturers, within [ten] days after completion of applicable item of work.
  - .4 Verify that documents are in proper form, contain full information, and are notarized.
  - .5 Co-execute submittals when required.
  - .6 Retain warranties and bonds until time specified for submittal.
- .7 Except for items put into use with Owner's permission, leave date of beginning of time of warranty until Date of Substantial Performance is determined.
- .8 Include information contained in warranty management plan as follows:
  - .1 Roles and responsibilities of personnel associated with warranty process, including points of contact and telephone numbers within the organizations of Contractors, subcontractors, manufacturers or suppliers involved.
  - .2 Listing and status of delivery of Certificates of Warranty for extended warranty items, to include HVAC balancing, pumps, motors, commissioned systems, alarm systems, lightning protection systems,.
  - .3 Provide list for each warranted equipment, item, feature of construction or system indicating:
    - .1 Name of item.
    - .2 Model and serial numbers.
    - .3 Location where installed.
    - .4 Name and phone numbers of manufacturers or suppliers.
    - .5 Names, addresses and telephone numbers of sources of spare parts.
    - .6 Warranties and terms of warranty: include one-year overall warranty of construction. Indicate items that have extended warranties and show separate warranty expiration dates.
    - .7 Cross-reference to warranty certificates as applicable.

- .8 Starting point and duration of warranty period.
- .9 Summary of maintenance procedures required to continue warranty in force.
- .10 Cross-Reference to specific pertinent Operation and Maintenance manuals.
- .11 Organization, names and phone numbers of persons to call for warranty service.
- .12 Typical response time and repair time expected for various warranted equipment.
- .4 Procedure and status of tagging of equipment covered by extended warranties.
- .5 Post copies of instructions near selected pieces of equipment where operation is critical for warranty and/or safety reasons.
- .9 Respond in timely manner to oral or written notification of required construction warranty repair work.
- .10 Written verification to follow oral instructions.
  - .1 Failure to respond will be cause for Departmental Representative to proceed with action against Contractor.

**1.12 WARRANTY TAGS**

- .1 Tag, at time of installation, each warranted item. Provide durable, oil and water resistant tag approved Departmental Representative.
- .2 Attach tags with copper wire and spray with waterproof silicone coating.
- .3 Leave date of acceptance until project is accepted for occupancy.
- .4 Indicate following information on tag:
  - .1 Type of product/material.
  - .2 Model number.
  - .3 Serial number.
  - .4 Contract number.
  - .5 Warranty period.
  - .6 Inspector's signature.
  - .7 Construction Contractor.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not Used.

**Part 3            Execution**

**3.1                NOT USED**

.1                Not Used.

**END OF SECTION**

**Part 1            General**

**1.1                ADMINISTRATIVE REQUIREMENTS**

- .1     Demonstrate scheduled operation and maintenance of equipment and systems to Owner's personnel one weeks prior to date of final inspection.
- .2     Owner: provide list of personnel to receive instructions, and co-ordinate their attendance at agreed-upon times.
- .3     Preparation:
  - .1     Verify conditions for demonstration and instructions comply with requirements.
  - .2     Verify designated personnel are present.
  - .3     Ensure equipment has been inspected and put into operation in accordance with manufacturers recommendations.
  - .4     Ensure testing, adjusting, and balancing has been performed in accordance with Section 01 91 13 - General Commissioning (Cx) Requirements and equipment and systems are fully operational.
- .4     Demonstration and Instructions:
  - .1     Demonstrate start-up, operation, control, adjustment, trouble-shooting, servicing, and maintenance of each item of equipment at agreed upon times, at the designated location.
  - .2     Instruct personnel in phases of operation and maintenance using operation and maintenance manuals as basis of instruction.
  - .3     Review contents of manual in detail to explain aspects of operation and maintenance.
  - .4     Prepare and insert additional data in operations and maintenance manuals when needed during instructions.
- .5     Time Allocated for Instructions: ensure amount of time required for instruction of each item of equipment or system as follows:
  - .1     Heating system: four hours of instruction.

**1.2                ACTION AND INFORMATIONAL SUBMITTALS**

- .1     Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2     Submit schedule of time and date for demonstration of each item of equipment and each system one weeks prior to designated dates, for Departmental Representative's approval.
- .3     Submit reports within one week after completion of demonstration, that demonstration and instructions have been satisfactorily completed.
- .4     Give time and date of each demonstration, with list of persons present.

- .5 Provide copies of completed operation and maintenance manuals for use in demonstrations and instructions.

**1.3 QUALITY ASSURANCE**

- .1 When specified in individual Sections requiring manufacturer to provide authorized representative to demonstrate operation of equipment and systems:
  - .1 Instruct Owner's personnel.
  - .2 Provide written report that demonstration and instructions have been completed.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not Used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not Used.

**END OF SECTION**

**Part 1 General**

**1.1 SUMMARY**

- .1 Section Includes:
  - .1 General requirements relating to commissioning of project's components and systems, specifying general requirements to PV of components, equipment, sub-systems, systems, and integrated systems.
- .2 Acronyms:
  - .1 AFD - Alternate Forms of Delivery, service provider.
  - .2 BMM - Building Management Manual.
  - .3 Cx - Commissioning.
  - .4 EMCS - Energy Monitoring and Control Systems.
  - .5 O M - Operation and Maintenance.
  - .6 PI - Product Information.
  - .7 PV - Performance Verification.
  - .8 TAB - Testing, Adjusting and Balancing.

**1.2 GENERAL**

- .1 Cx is a planned program of tests, procedures and checks carried out systematically on systems and integrated systems of the finished Project. Cx is performed after systems and integrated systems are completely installed, functional and Contractor's Performance Verification responsibilities have been completed and approved. Objectives:
  - .1 Verify installed equipment, systems and integrated systems operate in accordance with contract documents and design criteria and intent.
  - .2 Ensure appropriate documentation is compiled into the BMM.
  - .3 Effectively train O M staff.
- .2 Contractor assists in Cx process, operating equipment and systems, troubleshooting and making adjustments as required.
  - .1 Systems to be operated at full capacity under various modes to determine if they function correctly and consistently at peak efficiency. Systems to be interactively with each other as intended in accordance with Contract Documents and design criteria.
  - .2 During these checks, adjustments to be made to enhance performance to meet environmental or user requirements.
- .3 Design Criteria: as per client's requirements or determined by designer. To meet Project functional and operational requirements.
- .4 AFD managed projects the term Departmental Representative in Cx specifications to be interpreted as AFD Service Provider.

### **1.3 COMMISSIONING OVERVIEW**

- .1 Section 01 91 31 - Commissioning (Cx) Plan.
- .2 For Cx responsibilities refer to Section 01 91 31 - Commissioning (Cx) Plan.
- .3 Cx to be a line item of Contractor's cost breakdown.
- .4 Cx activities supplement field quality and testing procedures described in relevant technical sections.
- .5 Cx is conducted in concert with activities performed during stage of project delivery. Cx identifies issues in Planning and Design stages which are addressed during Construction and Cx stages to ensure the heating system is constructed and proven to operate satisfactorily under weather, environmental and occupancy conditions to meet functional and operational requirements. Cx activities includes transfer of critical knowledge to facility operational personnel.
- .6 Departmental Representative will issue Interim Acceptance Certificate when:
  - .1 Completed Cx documentation has been received, reviewed for suitability and approved by Departmental Representative.
  - .2 Equipment, components and systems have been commissioned.
  - .3 O M training has been completed.

### **1.4 NON-CONFORMANCE TO PERFORMANCE VERIFICATION REQUIREMENTS**

- .1 Should equipment, system components, and associated controls be incorrectly installed or malfunction during Cx, correct deficiencies, re-verify equipment and components within the unfunctional system, including related systems as deemed required by Departmental Representative, to ensure effective performance.
- .2 Costs for corrective work, additional tests, inspections, to determine acceptability and proper performance of such items to be borne by Contractor. Above costs to be in form of progress payment reductions or hold-back assessments.

### **1.5 PRE-CX REVIEW**

- .1 Before Construction:
  - .1 Review contract documents, confirm by writing to Departmental Representative.
    - .1 Adequacy of provisions for Cx.
    - .2 Aspects of design and installation pertinent to success of Cx.
- .2 During Construction:
  - .1 Co-ordinate provision, location and installation of provisions for Cx.
- .3 Before start of Cx:
  - .1 Have completed Cx Plan up-to-date.
  - .2 Ensure installation of related components, equipment, sub-systems, systems is complete.

- .3 Fully understand Cx requirements and procedures.
  - .4 Have Cx documentation shelf-ready.
  - .5 Understand completely design criteria and intent and special features.
  - .6 Submit complete start-up documentation to Departmental Representative.
  - .7 Have Cx schedules up-to-date.
  - .8 Ensure systems have been cleaned thoroughly.
  - .9 Complete TAB procedures on systems, submit TAB reports to Departmental Representative for review and approval.
  - .10 Ensure "As-Built" system schematics are available.
- .4 Inform Departmental Representative in writing of discrepancies and deficiencies on finished works.

#### **1.6 CONFLICTS**

- .1 Report conflicts between requirements of this section and other sections to Departmental Representative before start-up and obtain clarification.
- .2 Failure to report conflict and obtain clarification will result in application of most stringent requirement.

#### **1.7 ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
  - .1 Submit no later than 4 weeks after award of Contract:
    - .1 Name of Contractor's Cx agent.
    - .2 Draft Cx documentation.
    - .3 Preliminary Cx schedule.
  - .2 Request in writing Departmental Representative for changes to submittals and obtain written approval at least 2 weeks prior to start of Cx.
  - .3 Submit proposed Cx procedures to Departmental Representative where not specified and obtain written approval at least 2 weeks prior to start of Cx.
  - .4 Provide additional documentation relating to Cx process required by Departmental Representative.

#### **1.8 COMMISSIONING DOCUMENTATION**

- .1 Refer to Section 01 91 33 - Commissioning (Cx) Forms: Installation Check Lists and Product Information (PI) / Performance Verification (PV) Forms for requirements and instructions for use.
- .2 Departmental Representative to review and approve Cx documentation.
- .3 Provide completed and approved Cx documentation to Departmental Representative.

#### **1.9 COMMISSIONING SCHEDULE**

- .1 Provide detailed Cx schedule as part of construction schedule.



- .2 Provide adequate time for Cx activities prescribed in technical sections and commissioning sections including:
  - .1 Approval of Cx reports.
  - .2 Verification of reported results.
  - .3 Repairs, retesting, re-commissioning, re-verification.
  - .4 Training.

#### **1.10 COMMISSIONING MEETINGS**

- .1 Convene Cx meetings following project meetings.
- .2 Purpose: to resolve issues, monitor progress, identify deficiencies, relating to Cx.
- .3 Continue Cx meetings on regular basis until commissioning deliverables have been addressed.

#### **1.11 STARTING AND TESTING**

- .1 Contractor assumes liabilities and costs for inspections. Including disassembly and re-assembly after approval, starting, testing and adjusting, including supply of testing equipment.

#### **1.12 WITNESSING OF STARTING AND TESTING**

- .1 Provide 14 days notice prior to commencement.
- .2 Departmental Representative to witness of start-up and testing.
- .3 Contractor's Cx Agent to be present at tests performed and documented by sub-trades, suppliers and equipment manufacturers.

#### **1.13 MANUFACTURER'S INVOLVEMENT**

- .1 Factory testing: manufacturer to:
  - .1 Coordinate time and location of testing.
  - .2 Provide testing documentation for approval by Departmental Representative.
  - .3 Arrange Departmental Representative to witness tests.
  - .4 Obtain written approval of test results and documentation from Departmental Representative before delivery to site.
- .2 Obtain manufacturers installation, start-up and operations instructions prior to start-up of components, equipment and systems and review with Departmental Representative.
  - .1 Compare completed installation with manufacturer's published data, record discrepancies, and review with manufacturer.
  - .2 Modify procedures detrimental to equipment performance and review same with manufacturer before start-up.
- .3 Integrity of warranties:
  - .1 Use manufacturer's trained start-up personnel where specified elsewhere in other divisions or required to maintain integrity of warranty.

- .2 Verify with manufacturer that testing as specified will not void warranties.
- .4 Qualifications of manufacturer's personnel:
  - .1 Experienced in design, installation and operation of equipment and systems.
  - .2 Ability to interpret test results accurately.
  - .3 To report results in clear, concise, logical manner.

#### **1.14 PROCEDURES**

- .1 Verify that equipment and systems are complete, clean, and operating in normal and safe manner prior to conducting start-up, testing and Cx.
- .2 Conduct start-up and testing in following distinct phases:
  - .1 Included in delivery and installation:
    - .1 Verification of conformity to specification, approved shop drawings and completion of PI report forms.
    - .2 Visual inspection of quality of installation.
  - .2 Start-up: follow accepted start-up procedures.
  - .3 Operational testing: document equipment performance.
  - .4 System PV: include repetition of tests after correcting deficiencies.
  - .5 Post-substantial performance verification: to include fine-tuning.
- .3 Correct deficiencies and obtain approval from Departmental Representative after distinct phases have been completed and before commencing next phase.
- .4 Document require tests on approved PV forms.
- .5 Failure to follow accepted start-up procedures will result in re-evaluation of equipment by an independent testing agency selected by Departmental Representative. If results reveal that equipment start-up was not in accordance with requirements, and resulted in damage to equipment, implement following:
  - .1 Minor equipment/systems: implement corrective measures approved by Departmental Representative.
  - .2 Major equipment/systems: if evaluation report concludes that damage is minor, implement corrective measures approved by Departmental Representative.
  - .3 If evaluation report concludes that major damage has occurred, Departmental Representative shall reject equipment.
    - .1 Rejected equipment to be remove from site and replace with new.
    - .2 Subject new equipment/systems to specified start-up procedures.

#### **1.15 START-UP DOCUMENTATION**

- .1 Assemble start-up documentation and submit to Departmental Representative for approval before commencement of commissioning.
- .2 Start-up documentation to include:
  - .1 Factory and on-site test certificates for specified equipment.

- .2 Pre-start-up inspection reports.
- .3 Signed installation/start-up check lists.
- .4 Start-up reports,
- .5 Step-by-step description of complete start-up procedures, to permit Departmental Representative to repeat start-up at any time.

**1.16 OPERATION AND MAINTENANCE OF EQUIPMENT AND SYSTEMS**

- .1 After start-up, operate and maintain equipment and systems as directed by equipment/system manufacturer.
- .2 With assistance of manufacturer develop written maintenance program and submit Departmental Representative for approval before implementation.
- .3 Operate and maintain systems for length of time required for commissioning to be completed.
- .4 After completion of commissioning, operate and maintain systems until issuance of certificate of interim acceptance.

**1.17 TEST RESULTS**

- .1 If start-up, testing and/or PV produce unacceptable results, repair, replace or repeat specified starting and/or PV procedures until acceptable results are achieved.
- .2 Provide manpower and materials, assume costs for re-commissioning.

**1.18 START OF COMMISSIONING**

- .1 Notify Departmental Representative at least 14 days prior to start of Cx.
- .2 Start Cx after elements of building affecting start-up and performance verification of systems have been completed.

**1.19 INSTRUMENTS / EQUIPMENT**

- .1 Submit to Departmental Representative for review and approval:
  - .1 Complete list of instruments proposed to be used.
  - .2 Listed data including, serial number, current calibration certificate, calibration date, calibration expiry date and calibration accuracy.
- .2 Provide the following equipment as required:
  - .1 Equipment as required to complete work.

**1.20 COMMISSIONING PERFORMANCE VERIFICATION**

- .1 Carry out Cx:
  - .1 Under actual operating conditions, over entire operating range, in all modes.
  - .2 On independent systems and interacting systems.
- .2 Cx procedures to be repeatable and reported results are to be verifiable.

- .3 Follow equipment manufacturer's operating instructions.
- .4 EMCS trending to be available as supporting documentation for performance verification.

#### **1.21 WITNESSING COMMISSIONING**

- .1 Departmental Representative to witness activities and verify results.

#### **1.22 AUTHORITIES HAVING JURISDICTION**

- .1 Where specified start-up, testing or commissioning procedures duplicate verification requirements of authority having jurisdiction, arrange for authority to witness procedures so as to avoid duplication of tests and to facilitate expedient acceptance of facility.
- .2 Obtain certificates of approval, acceptance and compliance with rules and regulation of authority having jurisdiction.
- .3 Provide copies to Departmental Representative within 5 days of test and with Cx report.

#### **1.23 EXTRAPOLATION OF RESULTS**

- .1 Where Cx of weather, occupancy, or seasonal-sensitive equipment or systems cannot be conducted under near-rated or near-design conditions, extrapolate part-load results to design conditions when approved by Departmental Representative in accordance with equipment manufacturer's instructions, using manufacturer's data, with manufacturer's assistance and using approved formulae.

#### **1.24 DEFICIENCIES, FAULTS, DEFECTS**

- .1 Correct deficiencies found during start-up and Cx to satisfaction of Departmental Representative

#### **1.25 COMPLETION OF COMMISSIONING**

- .1 Upon completion of Cx leave systems in normal operating mode.
- .2 Except for warranty and seasonal verification activities specified in Cx specifications, complete Cx prior to issuance of Interim Certificate of Completion.
- .3 Cx to be considered complete when contract Cx deliverables have been submitted and accepted by Departmental Representative.

#### **1.26 TRAINING**

- .1 In accordance with Section 01 91 41 - Commissioning (Cx) - Training.

#### **1.27 MAINTENANCE MATERIALS, SPARE PARTS, SPECIAL TOOLS**

- .1 Supply, deliver, and document maintenance materials, spare parts, and special tools as specified in contract.

---

**1.28 OWNER'S PERFORMANCE TESTING**

- .1 Performance testing of equipment or system by Departmental Representative will not relieve Contractor from compliance with specified start-up and testing procedures.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not Used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not Used.

**END OF SECTION**

**Part 1            General**

**1.1                SUMMARY**

- .1    Section Includes:
  - .1    Description of overall structure of Cx Plan and roles and responsibilities of Cx team.

**1.2                REFERENCES**

- .1    Underwriters' Laboratories of Canada (ULC)

**1.3                GENERAL**

- .1    Provide a fully functional heating system:
  - .1    Systems, equipment and components meet user's functional requirements before date of acceptance, and operate consistently at peak efficiencies and within specified energy budgets under normal loads.
  - .2    O M personnel have been fully trained in aspects of installed systems.
  - .3    Optimized life cycle costs.
  - .4    Complete documentation relating to installed equipment and systems.
- .2    Term "Cx" in this section means "Commissioning".
- .3    Use this Cx Plan as master planning document for Cx:
  - .1    Outlines organization, scheduling, allocation of resources, documentation, pertaining to implementation of Cx.
  - .2    Communicates responsibilities of team members involved in Cx Scheduling, documentation requirements, and verification procedures.
  - .3    Sets out deliverables relating to O M, process and administration of Cx.
  - .4    Describes process of verification of how built works meet Departmental Representative's requirements.
  - .5    Produces a complete functional system prior to issuance of Certificate of Occupancy.
  - .6    Management tool that sets out scope, standards, roles and responsibilities, expectations, deliverables, and provides:
    - .1    Overview of Cx.
    - .2    General description of elements that make up Cx Plan.
    - .3    Process and methodology for successful Cx.
- .4    Acronyms:
  - .1    Cx - Commissioning.
  - .2    BMM - Building Management Manual.
  - .3    EMCS - Energy Monitoring and Control Systems.

- .4 MSDS - Material Safety Data Sheets.
- .5 PI - Product Information.
- .6 PV - Performance Verification.
- .7 TAB - Testing, Adjusting and Balancing.
- .8 WHMIS - Workplace Hazardous Materials Information System.
- .5 Commissioning terms used in this Section:
  - .1 Bumping: short term start-up to prove ability to start and prove correct rotation.
  - .2 Deferred Cx - Cx activities delayed for reasons beyond Contractor's control due to lack of occupancy, weather conditions, need for heating/cooling loads.

#### **1.4 DEVELOPMENT OF 100% CX PLAN**

- .1 Cx Plan to be 95% completed before added into Project Specifications.
- .2 Cx Plan to be 100% completed within 2 weeks of award of contract to take into account:
  - .1 Approved shop drawings and product data.
  - .2 Approved changes to contract.
  - .3 Contractor's project schedule.
  - .4 Cx schedule.
  - .5 Contractor's, sub-contractor's, suppliers' requirements.
  - .6 Project construction team's and Cx team's requirements.
- .3 Submit completed Cx Plan to Departmental Representative and obtain written approval.

#### **1.5 REFINEMENT OF CX PLAN**

- .1 During construction phase, revise, refine and update Cx Plan to include:
  - .1 Changes resulting from Client program modifications.
  - .2 Approved design and construction changes.
- .2 Revise, refine and update every 2 weeks during construction phase. At each revision, indicate revision number and date.
- .3 Submit each revised Cx Plan to Departmental Representative for review and obtain written approval.
- .4 Include testing parameters at full range of operating conditions and check responses of equipment and systems.

#### **1.6 COMPOSITION, ROLES AND RESPONSIBILITIES OF CX TEAM**

- .1 Departmental Representative to maintain overall responsibility for project and is sole point of contact between members of commissioning team.
- .2 Project Manager will select Cx Team consisting of following members:
  - .1 PWGSC Design Quality Review Team: during construction, will conduct periodic site reviews to observe general progress.

- .2 PWGSC Quality Assurance Commissioning Manager: ensures Cx activities are carried out to ensure delivery of a fully operational project including:
  - .1 Review of Cx documentation from operational perspective.
  - .2 Review for performance, reliability, durability of operation, accessibility, maintainability, operational efficiency under conditions of operation.
  - .3 Protection of health, safety and comfort of occupants and O M personnel.
  - .4 Monitoring of Cx activities, training, development of Cx documentation.
  - .5 Work closely with members of Cx Team.
- .3 Departmental Representative is responsible for:
  - .1 Organizing Cx.
  - .2 Monitoring operations Cx activities.
  - .3 Witnessing, reviewing accuracy of reported results.
  - .4 Witnessing and reviewing TAB and other tests.
  - .5 Ensuring implementation of final Cx Plan.
  - .6 Performing review of performance of installed systems and equipment.
  - .7 Implementation of Training Plan.
- .4 Construction Team: contractor, sub-contractors, suppliers and support disciplines, is responsible for construction/installation in accordance with contract documents, including:
  - .1 Testing.
  - .2 TAB.
  - .3 Performance of Cx activities.
  - .4 Delivery of training and Cx documentation.
  - .5 Assigning one person as point of contact with Consultant and PWGSC Cx Manager for administrative and coordination purposes.
- .5 Contractor's Cx agent implements specified Cx activities including:
  - .1 Demonstrations.
  - .2 Training.
  - .3 Testing.
  - .4 Preparation, submission of test reports.
- .6 Facility Manager: represents lead role in Operation Phase and onwards and is responsible for:
  - .1 Receiving facility.
  - .2 Day-To-Day operation and maintenance of facility.

## 1.7 CX PARTICIPANTS

- .1 Employ the following Cx participants to verify performance of equipment and systems:
  - .1 Installation contractor/subcontractor:
    - .1 Equipment and systems except as noted.



- .2 Equipment manufacturer: equipment specified to be installed and started by manufacturer.
  - .1 To include performance verification.
- .3 Specialist subcontractor: equipment and systems supplied and installed by specialist subcontractor.
- .4 Specialist Cx agency:
  - .1 Possessing specialist qualifications and installations providing environments essential to client's program but are outside scope or expertise of Cx specialists on this project.
- .5 Client: responsible for intrusion and access security systems.
- .6 Ensure that Cx participant:
  - .1 Could complete work within scheduled time frame.
  - .2 Available for emergency and troubleshooting service during first year of occupancy by user for adjustments and modifications outside responsibility of O M personnel, including:
    - .1 Changes to heating or cooling loads beyond scope of EMCS.
    - .2 Changes to EMCS control strategies beyond level of training provided to O M personnel.
- .7 Provide names of participants to Departmental Representative and details of instruments and procedures to be followed for Cx 3 weeks prior to starting date of Cx for review and approval.

## **1.8 EXTENT OF CX**

- .1 Commission mechanical systems and associated equipment:
  - .1 Heating systems:
    - .1 Boiler systems
    - .2 Pumps

## **1.9 DELIVERABLES RELATING TO O M PERSPECTIVES**

- .1 General requirements:
  - .1 Compile English documentation.
  - .2 Documentation to be computer-compatible format ready for inputting for data management.
- .2 Provide deliverables:
  - .1 Warranties.
  - .2 Project record documentation.
  - .3 Inventory of spare parts, special tools and maintenance materials.
  - .4 Maintenance Management System (MMS) identification system used.

- .5 WHMIS information.
- .6 MSDS data sheets.
- .7 Electrical Panel inventory containing detailed inventory of electrical circuitry for each panel board. Duplicate of inventory inside each panel.

#### **1.10 DELIVERABLES RELATING TO THE CX PROCESS**

- .1 General:
  - .1 Start-up, testing and Cx requirements, conditions for acceptance and specifications form part of relevant technical sections of these specifications.
- .2 Definitions:
  - .1 Cx as used in this section includes:
    - .1 Cx of components, equipment, systems, subsystems, and integrated systems.
    - .2 Factory inspections and performance verification tests.
- .3 Deliverables: provide:
  - .1 Cx Specifications.
  - .2 Startup, pre-Cx activities and documentation for systems, and equipment.
  - .3 Completed installation checklists (ICL).
  - .4 Completed product information (PI) report forms.
  - .5 Completed performance verification (PV) report forms.
  - .6 Results of Performance Verification Tests and Inspections.
  - .7 Description of Cx activities and documentation.
  - .8 Description of Cx of integrated systems and documentation.
  - .9 Tests of following witnessed by PWGSC Design Quality Review Team:
    - .1 Heating systems
  - .10 Training Plans.
  - .11 Cx Reports.
  - .12 Prescribed activities during warranty period.
- .4 Departmental Representative to witness and review tests and reports of results provided to Departmental Representative.

#### **1.11 PRE-CX ACTIVITIES AND RELATED DOCUMENTATION**

- .1 Items listed in this Cx Plan include the following:
  - .1 Pre-Start-Up inspections: by Departmental Representative prior to permission to start up and rectification of deficiencies to Departmental Representative's satisfaction.
  - .2 Departmental Representative to use approved check lists.
  - .3 Departmental Representative will monitor some of these pre-start-up inspections.

- .4 Include completed documentation with Cx report.
- .5 Include completed documentation in Cx report.
- .2 Pre-Cx activities - MECHANICAL:
  - .1 Heating systems:
    - .1 "Bump" each item of equipment in its "stand-alone" mode.
    - .2 Complete pre-start-up checks and complete relevant documentation.
    - .3 After equipment has been started, test related systems in conjunction with control systems on a system-by-system basis.

### **1.12 START-UP**

- .1 Start up components, equipment and systems.
- .2 Equipment manufacturer, supplier, installing specialist sub-contractor, as appropriate, to start-up, under Contractor's direction, following equipment, systems:
  - .1 Heating systems
- .3 Departmental Representative to monitor some of these start-up activities.
  - .1 Rectify start-up deficiencies to satisfaction of Departmental Representative.
- .4 Performance Verification (PV):
  - .1 Approved Cx Agent to perform.
    - .1 Repeat when necessary until results are acceptable to Departmental Representative.
  - .2 Use procedures modified generic procedures to suit project requirements.
  - .3 Departmental Representative to witness and review reported results using approved PI and PV forms.
  - .4 Departmental Representative to review completed PV reports and provide to Departmental Representative.
  - .5 Departmental Representative reserves right to verify up to 30% of reported results at random.
  - .6 Failure of randomly selected item shall result in rejection of PV report or report of system startup and testing.

### **1.13 CX ACTIVITIES AND RELATED DOCUMENTATION**

- .1 Perform Cx by specified Cx agency using procedures developed by Departmental Representative and approved by Departmental Representative.
- .2 Departmental Representative to monitor Cx activities.
- .3 Upon satisfactory completion, Cx agency performing tests to prepare Cx Report using approved PV forms.
- .4 Departmental Representative to witness, review reported results of, Cx activities and forward to Departmental Representative.

- .5 Departmental Representative reserves right to verify a percentage of reported results at no cost to contract.

#### **1.14 CX OF INTEGRATED SYSTEMS AND RELATED DOCUMENTATION**

- .1 Cx to be performed by specified Cx specialist, using procedures developed by Departmental Representative and approved by Departmental Representative
- .2 Tests to be witnessed by Departmental Representative and documented on approved report forms.
- .3 Upon satisfactory completion, Cx specialist to prepare Cx Report, to be reviewed by Departmental Representative and submitted to Departmental Representative for review.
- .4 Departmental Representative reserves right to verify percentage of reported results.
- .5 Identification:
  - .1 In later stages of Cx, before hand-over and acceptance Departmental Representative and Cx Manager to co-operate to complete inventory data sheets and provide assistance to PWGSC in full implementation of MMS identification system of components, equipment, sub-systems, systems.

#### **1.15 INSTALLATION CHECK LISTS (ICL)**

- .1 Refer to Section 01 91 33 - Commissioning (Cx) Forms: Installation Check Lists and Product Information (PI) / Performance Verification (PV) Forms.

#### **1.16 PRODUCT INFORMATION (PI) REPORT FORMS**

- .1 Refer to Section 01 91 33 - Commissioning (Cx) Forms: Installation Check Lists and Product Information (PI) / Performance Verification (PV) Forms.

#### **1.17 PERFORMANCE VERIFICATION (PV) REPORT**

- .1 Refer to Section 01 91 33 - Commissioning (Cx) Forms: Installation Check Lists and Product Information (PI) / Performance Verification (PV) Forms.

#### **1.18 CX SCHEDULES**

- .1 Prepare detailed critical path Cx Schedule and submit to Departmental Representative for review and approval same time as project Construction Schedule. Include:
  - .1 Milestones, testing, documentation, training and Cx activities of components, equipment, subsystems, systems and integrated systems, including:
    - .1 Design criteria, design intents.
    - .2 Pre-TAB review: 28 days after contract award, and before construction starts.
    - .3 Cx agents' credentials: 15 days before start of Cx.
    - .4 Cx procedures: 1 months after award of contract.
    - .5 Cx Report format: 1 months after contract award.

- .6 Notification of intention to start Cx: 14 days before start of Cx.
- .7 Notification of intention to start Cx of integrated systems: after Cx of related systems is completed 14 days before start of integrated system Cx.
- .8 Identification of deferred Cx.
- .9 Implementation of training plans.
- .10 Cx reports: immediately upon successful completion of Cx.
- .2 Detailed training schedule to demonstrate no conflicts with testing, completion of project and hand-over to Property Manager.
- .2 After approval, incorporate Cx Schedule into Construction Schedule.
- .3 Consultant, Contractor, Contractor's Cx agent, and Departmental Representative will monitor progress of Cx against this schedule.

#### **1.19 CX REPORTS**

- .1 Submit reports of tests, witnessed and certified by Departmental Representative to Departmental Representative who will verify reported results.
- .2 Include completed and certified PV reports in properly formatted Cx Reports.
- .3 Before reports are accepted, reported results to be subject to verification by Departmental Representative.

#### **1.20 TESTS TO BE PERFORMED BY OWNER/USER**

- .1 None is anticipated on this project.

#### **1.21 FINAL SETTINGS**

- .1 Upon completion of Cx to satisfaction of Departmental Representative lock control devices in their final positions, indelibly mark settings marked and include in Cx Reports.

#### **Part 2 Products**

##### **2.1 NOT USED**

- .1 Not Used.

#### **Part 3 Execution**

##### **3.1 NOT USED**

- .1 Not Used.

**END OF SECTION**

**Part 1            General**

**1.1                SUMMARY**

- .1    Section Includes:
  - .1    Commissioning forms to be completed for equipment, system and integrated system.

**1.2                INSTALLATION/START-UP CHECK LISTS**

- .1    Include the following data:
  - .1    Product manufacturer's installation instructions and recommended checks.
  - .2    Special procedures as specified in relevant technical sections.
  - .3    Items considered good installation and engineering industry practices deemed appropriate for proper and efficient operation.
- .2    Equipment manufacturer's installation/start-up check lists are acceptable for use. As deemed necessary by Departmental Representative supplemental additional data lists will be required for specific project conditions.
- .3    Use check lists for equipment installation. Document check list verifying checks have been made, indicate deficiencies and corrective action taken.
- .4    Installer to sign check lists upon completion, certifying stated checks and inspections have been performed. Return completed check lists to Departmental Representative. Check lists will be required during Commissioning and will be included in Building Maintenance Manual (BMM) at completion of project.
- .5    Use of check lists will not be considered part of commissioning process but will be stringently used for equipment pre-start and start-up procedures.

**1.3                PRODUCT INFORMATION (PI) REPORT FORMS**

- .1    Product Information (PI) forms compiles gathered data on items of equipment produced by equipment manufacturer, includes nameplate information, parts list, operating instructions, maintenance guidelines and pertinent technical data and recommended checks that is necessary to prepare for start-up and functional testing and used during operation and maintenance of equipment. This documentation is included in the BMM at completion of work.
- .2    Prior to Performance Verification (PV) of systems complete items on PI forms related to systems and obtain Departmental Representative's approval.

**1.4                PERFORMANCE VERIFICATION (PV) FORMS**

- .1    PV forms to be used for checks, running dynamic tests and adjustments carried out on equipment and systems to ensure correct operation, efficiently and function independently and interactively with other systems as intended with project requirements.

- .2 PV report forms include those developed by Contractor records measured data and readings taken during functional testing and Performance Verification procedures.
- .3 Prior to PV of integrated system, complete PV forms of related systems and obtain Departmental Representative's approval.

### **1.5 SAMPLES OF COMMISSIONING FORMS**

- .1 Revise items on Commissioning forms to suit project requirements.
- .2 Samples of Commissioning forms and a complete index of produced to date will be attached to this section.

### **1.6 CHANGES AND DEVELOPMENT OF NEW REPORT FORMS**

- .1 When additional forms are required, develop appropriate verification forms and submit to Departmental Representative for approval prior to use.

### **1.7 COMMISSIONING FORMS**

- .1 Use Commissioning forms to verify installation and record performance when starting equipment and systems.
- .2 Strategy for Use:
  - .1 Contractor will provide required shop drawings information and verify correct installation and operation of items indicated on these forms.
  - .2 Confirm operation as per design criteria and intent.
  - .3 Identify variances between design and operation and reasons for variances.
  - .4 Verify operation in specified normal and emergency modes and under specified load conditions.
  - .5 Record analytical and substantiating data.
  - .6 Verify reported results.
  - .7 Form to bear signatures of recording technician and reviewed and signed off by Departmental Representative.
  - .8 Submit immediately after tests are performed.
  - .9 Reported results in true measured SI unit values.
  - .10 Provide Departmental Representative with originals of completed forms.
  - .11 Maintain copy on site during start-up, testing and commissioning period.
  - .12 Forms to be both hard copy and electronic format with typed written results in Building Management Manual.

### **1.8 LANGUAGE**

- .1 To suit the language profile of the awarded contract.

---

**Part 2**            **Products**

**2.1**                **NOT USED**

.1                  Not Used.

**Part 3**            **Execution**

**3.1**                **NOT USED**

.1                  Not Used.

**END OF SECTION**



**Part 1            General**

**1.1                SECTION INCLUDES**

- .1            Work and conditions common to Division 23.

**1.2                RELATED SECTIONS**

- .1            Section 01 33 00 - Submittal Procedures
- .2            Section 01 35 29 - Health and Safety Requirements
- .3            Section 01 74 21 - Construction/Demolition Waste Management and Disposal
- .4            Section 01 78 00 – Closeout Submittals

**1.3                ACTION AND INFORMATIONAL SUBMITTALS**

- .1            Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2            Product Data:
  - .1            Submit manufacturer's instructions, printed product literature and data sheets for all HVAC, Plumbing Equipment and materials and include product characteristics, performance criteria, physical size, finish and limitations.
- .3            Shop Drawings:
  - .1            Submit drawings stamped and signed by professional engineer registered or licensed in Province of British Columbia, Canada.
  - .2            Indicate on drawings:
    - .1            Mounting arrangements.
    - .2            Operating and maintenance clearances.
  - .3            Shop drawings and product data accompanied by:
    - .1            Detailed drawings of bases, supports, and anchor bolts.
    - .2            Acoustical sound power data, where applicable.
    - .3            Points of operation on performance curves.
    - .4            Manufacturer to certify current model production.
    - .5            Certification of compliance to applicable codes.
  - .4            In addition to transmittal letter referred to in Section 01 33 00 - Submittal Procedures: use MCAC "Shop Drawing Submittal Title Sheet". Identify section and paragraph number.
- .4            Sustainable Design Submittals:
  - .1            Construction Waste Management:
    - .1            Submit project Waste Management Plan highlighting recycling and salvage requirements.

- .2 Submit calculations on end-of-project recycling rates, salvage rates, and landfill rates demonstrating that 50% of construction wastes were recycled or salvaged.

#### **1.4 CLOSEOUT SUBMITTALS**

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for all HVAC, Plumbing Equipment and materials for incorporation into manual.
  - .1 Operation and maintenance manual approved by, and final copies deposited with, Departmental Representative before final inspection.
  - .2 Operation data to include:
    - .1 Control schematics for systems including environmental controls.
    - .2 Description of systems and their controls.
    - .3 Description of operation of systems at various loads together with reset schedules and seasonal variances.
    - .4 Operation instruction for systems and component.
    - .5 Description of actions to be taken in event of equipment failure.
    - .6 Valves schedule and flow diagram.
    - .7 Colour coding chart.
  - .3 Maintenance data to include:
    - .1 Servicing, maintenance, operation and trouble-shooting instructions for each item of equipment.
    - .2 Data to include schedules of tasks, frequency, tools required and task time.
  - .4 Performance data to include:
    - .1 Equipment manufacturer's performance datasheets with point of operation as left after commissioning is complete.
    - .2 Equipment performance verification test results.
    - .3 Special performance data as specified.
    - .4 Testing, adjusting and balancing reports as specified in Section [23 05 93 - Testing, Adjusting and Balancing for HVAC].
  - .5 Approvals:
    - .1 Submit 3 copies of draft Operation and Maintenance Manual to Departmental Representative for approval. Submission of individual data will not be accepted unless directed by Departmental Representative.
    - .2 Make changes as required and re-submit as directed by Departmental Representative.
  - .6 Additional data:

- .1 Prepare and insert into operation and maintenance manual additional data when need for it becomes apparent during specified demonstrations and instructions.
- .7 Site records:
  - .1 Departmental Representative will provide 1 set of reproducible mechanical drawings. Provide sets of white prints as required for each phase of work. Mark changes as work progresses and as changes occur. Include changes to existing mechanical systems, control systems and low voltage control wiring.
  - .2 Transfer information weekly to reproducibles, revising reproducibles to show work as actually installed.
  - .3 Use different colour waterproof ink for each service.
  - .4 Make available for reference purposes and inspection.
- .8 As-built drawings:
  - .1 Prior to start of Testing, Adjusting and Balancing for HVAC, finalize production of as-built drawings.
  - .2 Identify each drawing in lower right hand corner in letters at least 12 mm high as follows: - "AS BUILT DRAWINGS: THIS DRAWING HAS BEEN REVISED TO SHOW MECHANICAL SYSTEMS AS INSTALLED" (Signature of Contractor) (Date).
  - .3 Submit Departmental Representative for approval and make corrections as directed.
  - .4 Perform testing, adjusting and balancing for HVAC using as-built drawings.
  - .5 Submit completed reproducible as-built drawings with Operating and Maintenance Manuals.
- .9 Submit copies of as-built drawings for inclusion in final TAB report.

## **1.5 MAINTENANCE MATERIAL SUBMITTALS**

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Furnish spare parts as follows:
  - .1 One set of packing for each pump.
  - .2 One casing joint gasket for each size pump.
  - .3 One glass for each gauge glass.
- .3 Provide one set of special tools required to service equipment as recommended by manufacturers.

## **1.6 DELIVERY, STORAGE AND HANDLING**

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.

- .3 Storage and Handling Requirements:
  - .1 Store material indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
  - .2 Store and protect all HVAC and Plumbing Equipment from nicks, scratches, and blemishes.
  - .3 Replace defective or damaged materials with new.
- .4 Develop Construction Waste Management Plan related to Work of this Section.

**Part 2 Products**

- .1 Not Used

**Part 3 Execution**

**3.1 DEMONSTRATION**

- .1 Departmental Representative may use equipment and systems for test purposes prior to acceptance. Supply labour, material, and instruments required for testing.
- .2 Supply tools, equipment and personnel to demonstrate and instruct operating and maintenance personnel in operating, controlling, adjusting, trouble-shooting and servicing of all systems and equipment during regular work hours, prior to acceptance.
- .3 Use operation and maintenance manual, as-built drawings, and audio visual aids as part of instruction materials.
- .4 Instruction duration time requirements as specified in appropriate sections.
- .5 Departmental Representative will record these demonstrations on video tape for future reference.

**3.2 CLEANING**

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
  - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment.

**3.3 PROTECTION**

- .1 Protect equipment and systems openings from dirt, dust, and other foreign materials with materials appropriate to system.

**END OF SECTION**

**Part 1            General**

**1.1                REFERENCES**

- .1 Canadian General Standards Board (CGSB)
  - .1 CAN/CGSB-1.181-99, Ready-Mixed Organic Zinc-Rich Coating.
- .2 Canadian Standards Association (CSA International)
  - .1 CSA B139-04, Installation Code for Oil Burning Equipment.

**1.2                ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Provide manufacturer's printed product literature, specifications and datasheets for piping and equipment and include product characteristics, performance criteria, physical size, finish and limitations.

**1.3                DELIVERY, STORAGE AND HANDLING**

- .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements:
  - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.

**Part 2            Products**

**2.1                MATERIAL**

- .1 Paint: zinc-rich to CAN/CGSB-1.181.
  - .1 Paints: in accordance with manufacturer's recommendations for surface conditions.

**Part 3            Execution**

**3.1                APPLICATION**

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

**3.2                CONNECTIONS TO EQUIPMENT**

- .1 In accordance with manufacturer's instructions unless otherwise indicated.

- .2 Use valves and either unions or flanges for isolation and ease of maintenance and assembly.
- .3 Use double swing joints when equipment mounted on vibration isolation and when piping subject to movement.

### **3.3 CLEARANCES**

- .1 Provide clearance around systems, equipment and components for observation of operation, inspection, servicing, maintenance and as recommended by manufacturer and CSA B139.
- .2 Provide space for disassembly, removal of equipment and components as recommended by manufacturer without interrupting operation of other system, equipment, components.

### **3.4 DRAINS**

- .1 Install piping with grade in direction of flow except as indicated.
- .2 Install drain valve at low points in piping systems, at equipment and at section isolating valves.
- .3 Pipe each drain valve discharge separately to above floor drain.
  - .1 Discharge to be visible.
- .4 Drain valves: NPS 3/4 gate or globe valves unless indicated otherwise, with hose end male thread, cap and chain.

### **3.5 AIR VENTS**

- .1 Install air vents to CSA B139 at high points in piping systems.
- .2 Install isolating valve at each automatic air valve.
- .3 Install drain piping to approved location and terminate where discharge is visible.

### **3.6 DIELECTRIC COUPLINGS**

- .1 General: compatible with system, to suit pressure rating of system.
- .2 Locations: where dissimilar metals are joined.
- .3 NPS 2 and under: isolating unions or bronze valves.
- .4 Over NPS 2: isolating flanges.

### **3.7 PIPEWORK INSTALLATION**

- .1 Install pipework to CSA B139.
- .2 Screwed fittings jointed with Teflon tape.
- .3 Protect openings against entry of foreign material.
- .4 Install to isolate equipment and allow removal without interrupting operation of other equipment or systems.

- .5 Assemble piping using fittings manufactured to ANSI standards.
- .6 Saddle type branch fittings may be used on mains if branch line is no larger than half size of main.
  - .1 Hole saw (or drill) and ream main to maintain full inside diameter of branch line prior to welding saddle.
- .7 Install exposed piping, equipment, rectangular cleanouts and similar items parallel or perpendicular to building lines.
- .8 Install concealed pipework to minimize furring space, maximize headroom, conserve space.
- .9 Slope piping, except where indicated, in direction of flow for positive drainage and venting.
- .10 Install, except where indicated, to permit separate thermal insulation of each pipe.
- .11 Group piping wherever possible and as indicated.
- .12 Ream pipes, remove scale and other foreign material before assembly.
- .13 Use eccentric reducers at pipe size changes to ensure positive drainage and venting.
- .14 Provide for thermal expansion as indicated.
- .15 Valves:
  - .1 Install in accessible locations.
  - .2 Remove interior parts before soldering.
  - .3 Install with stems above horizontal position unless indicated.
  - .4 Valves accessible for maintenance without removing adjacent piping.
  - .5 Install globe valves in bypass around control valves.
  - .6 Use ball valves or butterfly valves at branch take-offs for isolating purposes except where specified.
  - .7 Install butterfly valves between weld neck flanges to ensure full compression of liner.
  - .8 Use chain operators on valves NPS 2 1/2 and larger where installed more than 2400 mm above floor in Mechanical Rooms.
- .16 Check Valves:
  - .1 Install silent check valves on discharge of pumps in vertical pipes with downward flow and as indicated.
  - .2 Install swing check valves in horizontal lines on discharge of pumps and as indicated.

### **3.8 FLUSHING OUT OF PIPING SYSTEMS**

- .1 Flush system in accordance with Section 23 08 02 - Cleaning and Start-up of Mechanical Piping Systems.

- .2 Before start-up, clean interior of piping systems in accordance with requirements of Section 01 74 11 – Cleaning.
- .3 Preparatory to acceptance, clean and refurbish equipment and leave in operating condition, including replacement of filters in piping systems.

### **3.9 PRESSURE TESTING OF EQUIPMENT AND PIPEWORK**

- .1 Advise Departmental Representative 48 hours minimum prior to performance of pressure tests.
- .2 Pipework: test as specified in relevant sections of heating, ventilating and air conditioning work.
- .3 Maintain specified test pressure without loss for 4 hours minimum unless specified for longer period of time in relevant mechanical sections.
- .4 Prior to tests, isolate equipment and other parts which are not designed to withstand test pressure or media.
- .5 Conduct tests in presence of Departmental Representative.
- .6 Pay costs for repairs or replacement, retesting, and making good. Departmental Representative to determine whether repair or replacement is appropriate.
- .7 Insulate or conceal work only after review of tests by Departmental Representative.

### **3.10 EXISTING SYSTEMS**

- .1 Connect into existing piping systems at times approved by Departmental Representative.
- .2 Request written approval by Departmental Representative 10 days minimum, prior to commencement of work.
- .3 Be responsible for damage to existing plant by this work.

### **3.11 CLEANING**

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
  - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**END OF SECTION**



**Part 1            General**

**1.1                SUMMARY**

- .1    Section Includes:
  - .1    Materials and installation for thermometers and pressure gauges in piping systems.

**1.2                RELATED SECTIONS**

- .1    Section 01 33 00 - Submittal Procedures
- .2    Section 01 74 21 - Construction/Demolition Waste Management and Disposal
- .3    Section 23 05 24 – Mechanical Identification

**1.3                REFERENCES**

- .1    American Society of Mechanical Engineers (ASME)
  - .1    ASME B40.100-05, Pressure Gauges and Gauge Attachments.
  - .2    ASME B40.200-08, Thermometers, Direct Reading and Remote Reading.
- .2    Canadian General Standards Board (CGSB)
  - .1    CAN/CGSB-14.4-M88, Thermometers, Liquid-in-Glass, Self Indicating, Commercial/Industrial Type.
  - .2    CAN/CGSB-14.5-M88, Thermometers, Bimetallic, Self-Indicating, Commercial/Industrial Type.

**1.4                ACTION AND INFORMATIONAL SUBMITTALS**

- .1    Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2    Submit shop drawings for the following items:
  - .1    Thermometers.
  - .2    Pressure gauges.
  - .3    Stop cocks.
  - .4    Syphons.
  - .5    Wells.

**1.5                Waste Management and Disposal:**

- .1    Construction/Demolition Waste Management and Disposal: separate waste materials for recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**Part 2**

**Products**

**2.1 GENERAL**

- .1 Design point to be at mid-point of scale or range.

**2.2 DIRECT READING THERMOMETERS**

- .1 Industrial, variable angle type, mercury-free, liquid filled, 225mm scale length: to CAN/CGSB-14.4-M88.
  - .1 Resistance to shock and vibration.

**2.3 THERMOMETER WELLS**

- .1 Copper pipe: copper or bronze.
- .2 Steel pipe: brass or stainless steel.

**2.4 PRESSURE GAUGES**

- .1 112 mm, dial type: to ASME B40.100, Grade 2A, stainless steel bourdon tube having 0.5% accuracy full scale unless otherwise specified.
- .2 Provide:
  - .1 Snubber for pulsating operation.
  - .2 Diaphragm assembly for corrosive service.
  - .3 Gasketed pressure relief back with solid front.
  - .4 Bronze stop cock.
  - .5 Oil filled for high vibration applications.

**Part 3**

**Execution**

**3.1 EXAMINATION**

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for installation in accordance with manufacturer's written instructions.
  - .1 Visually inspect substrate in presence of Departmental Representative.
  - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
  - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

**3.2 GENERAL**

- .1 Install thermometers and gauges so they can be easily read from floor or platform.
  - .1 If this cannot be accomplished, install remote reading units.

- .2 Install between equipment and first fitting or valve.

### **3.3 THERMOMETERS**

- .1 Install in wells on piping. Include heat conductive material inside well.
- .2 Install in locations as indicated and on inlet and outlet of:
  - .1 Heat exchangers.
  - .2 Water boilers.
- .3 Install wells for balancing purposes.
- .4 Use extensions where thermometers are installed through insulation.

### **3.4 PRESSURE GAUGES**

- .1 Install in locations as follows:
  - .1 Suction and discharge of pumps.
  - .2 Upstream and downstream of PRV's.
  - .3 Upstream and downstream of control valves.
  - .4 Inlet and outlet of liquid side of heat exchangers.
  - .5 Outlet of boilers.
  - .6 In other locations as indicated.
- .2 Install gauge cocks for balancing purposes, elsewhere [as indicated].
- .3 Use extensions where pressure gauges are installed through insulation.

### **3.5 NAMEPLATES**

- .1 Install engraved lamicoïd nameplates in accordance with Section 23 05 53.01 - Mechanical Identification, identifying medium.

### **3.6 CLEANING**

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
  - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
  - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

### **3.7 PROTECTION**

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by thermometer and gauge installation.

**END OF SECTION**

**Part 1            General**

**1.1                SUMMARY**

- .1    Section Includes:
  - .1        Materials and installation of bronze valves.

**1.2                RELATED SECTIONS**

- .1    Section 01 33 00 - Submittal Procedures
- .2    Section 01 74 21 - Construction/Demolition Waste Management and Disposal
- .3    Section 01 78 00 – Closeout Submittals

**1.3                REFERENCES**

- .1    American National Standards Institute (ANSI)/American Society of Mechanical Engineers (ASME)
  - .1        ANSI/ASME B1.20.1-1983 (R2001), Pipe Threads, General Purpose (Inch).
  - .2        ANSI/ASME B16.18-2001(R2005), Cast Copper Alloy Solder Joint Pressure Fittings.
- .2    ASTM International
  - .1        ASTM B62-02, Standard Specification for Composition Bronze or Ounce Metal Castings.
  - .2        ASTM B283-08a, Standard Specification for Copper and Copper Alloy Die Forgings (Hot-Pressed).
  - .3        ASTM B505/B505M-08a, Standard Specification for Copper-Base Alloy Continuous Castings.
- .3    Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS)
  - .1        MSS-SP-25-1998, Standard Marking System for Valves, Fittings, Flanges and Unions.
  - .2        MSS-SP-80-2008, Bronze Gate Globe, Angle and Check Valves.

**1.4                ACTION AND INFORMATIONAL SUBMITTALS**

- .1    Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2    Product Data:
  - .1        Provide manufacturer's printed product literature and data sheets for equipment and systems and include product characteristics, performance criteria, physical size, finish and limitations.
- .3    Shop Drawings:
  - .1        Submit drawings stamped and signed by professional engineer registered or licensed in Province of British Columbia Canada.

**1.5 CLOSEOUT SUBMITTALS**

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

**1.6 DELIVERY, STORAGE AND HANDLING**

- .1 Packaging Waste Management: remove for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**Part 2 Products**

**2.1 MATERIALS**

- .1 Valves:
  - .1 Except for specialty valves, to be single manufacturer.
  - .2 Products to have CRN registration numbers.
- .2 End Connections:
  - .1 Connection into adjacent piping/tubing:
    - .1 Steel pipe systems: screwed ends to ANSI/ASME B1.20.1.
    - .2 Copper tube systems: solder ends to ANSI/ASME B16.18.
- .3 Lockshield Keys:
  - .1 Where lockshield valves are specified, provide 10 keys of each size: malleable iron cadmium plated.
- .4 Globe Valves:
  - .1 Requirements common to globe valves, unless specified otherwise:
    - .1 Standard specification: MSS SP-80.
    - .2 Bonnet: union with hexagonal shoulders.
    - .3 Connections: screwed with hexagonal shoulders.
    - .4 Pressure testing: to MSS SP-80. Tests to be hydrostatic.
    - .5 Stuffing box: threaded to bonnet with gland follower, packing nut, high grade non-asbestos packing.
    - .6 Handwheel: non-ferrous.
    - .7 Handwheel Nut: bronze to ASTM B62.
  - .2 NPS 2 and under, composition disc, Class 125:
    - .1 Body and bonnet: screwed bonnet.
    - .2 Disc and seat: renewable rotating disc composition to suit service conditions], regrindable bronze seat, loosely secured to bronze stem to ASTM B505.
    - .3 Operator: handwheel.
  - .3 NPS 2 and under, composition disc, Class 150:
    - .1 Body and bonnet: union bonnet.

- .2 Disc and seat: renewable rotating disc in easily removable disc holder, regrindable bronze seat, loosely secured to bronze stem to ASTM B505.
- .3 Operator: handwheel.
- .4 NPS 2 and under, plug disc, Class 150, screwed ends:
  - .1 Body and bonnet: union bonnet.
  - .2 Disc and seat ring: tapered plug type with disc stem ring of AISI S420 stainless steel to ASTM A276, loosely secured to stem.
  - .3 Operator: handwheel
- .5 Angle valve, NPS 2 and under, composition disc, Class 150:
  - .1 Body and bonnet: union bonnet.
  - .2 Disc and seat: renewable rotating PTFE disc in slip-on easily removable disc holder having integral guides, regrindable bronze seat, loosely secured to stem.
  - .3 Operator: handwheel.
- .5 Check Valves:
  - .1 Requirements common to check valves, unless specified otherwise:
    - .1 Standard specification: MSS SP-80.
    - .2 Connections: screwed with hexagonal shoulders.
  - .2 NPS 2 and under, swing type, bronze disc, Class 125:
    - .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
    - .2 Disc and seat: renewable rotating disc, two-piece hinge disc construction; seat: regrindable.
  - .3 NPS 2 and under, swing type, bronze disc:
    - .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
    - .2 Disc and seat: renewable rotating disc, two-piece hinge disc construction; seat: regrindable.
  - .4 NPS 2 and under, swing type, composition disc, Class 200:
    - .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
    - .2 Disc: renewable rotating disc of number 6 composition to suit service conditions, bronze two-piece hinge disc construction.
  - .5 NPS 2 and under, horizontal lift type, composition disc, Class 150:
    - .1 Body: with integral seat, union bonnet ring with hex shoulders, cap.
    - .2 Disc: renewable [PTFE] [no. 6 composition] rotating disc in disc holder having guides top and bottom, of bronze to ASTM B62.
  - .6 NPS 2 and under, vertical lift type, bronze disc, Class 125:
    - .1 Disc: rotating disc having guides top and bottom, disc guides, retaining rings.

- .6 Silent Check Valves:
  - .1 NPS 2 and under:
    - .1 Body: cast high tensile bronze to ASTM B62 with integral seat.
    - .2 Pressure rating: Class 125.
    - .3 Connections: screwed ends to ANSI B1.20.1 and with hex. shoulders.
    - .4 Disc and seat: renewable rotating disc.
    - .5 Stainless steel spring, heavy duty.
    - .6 Seat: regrindable.
- .7 Ball Valves:
  - .1 NPS 2 and under:
    - .1 Body and cap: cast high tensile bronze to ASTM B62.
    - .2 Pressure rating: Class125
    - .3 Connections: screwed ends to ANSI B1.20.1 and with hexagonal shoulders.
    - .4 Stem: tamperproof ball drive.
    - .5 Stem packing nut: external to body.
    - .6 Ball and seat: replaceable chrome plated solid ball and Teflon seats.
    - .7 Stem seal: TFE with external packing nut.
    - .8 Operator: removable lever handle.

### **Part 3 Execution**

#### **3.1 INSTALLATION**

- .1 Install rising stem valves in upright position with stem above horizontal.
- .2 Remove internal parts before soldering.
- .3 Install valves with unions at each piece of equipment arranged to allow servicing, maintenance, and equipment removal.

#### **3.2 CLEANING**

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
  - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**END OF SECTION**



**Part 1            General**

**1.1                SUMMARY**

- .1 Section Includes:
  - .1 Materials and installation of cast iron valves.

**1.2                RELATED SECTIONS**

- .1 Section 01 33 00 - Submittal Procedures
- .2 Section 01 74 21 - Construction/Demolition Waste Management and Disposal
- .3 Section 01 78 00 – Closeout Submittals

**1.3                REFERENCES**

- .1 American Society of Mechanical Engineers (ASME)
  - .1 ASME B16.1-05, Cast Iron Pipe Flanges and Flanged Fittings.
- .2 ASTM International Inc.
  - .1 ASTM A49-01(2006), Standard Specification for Heat-Treated Carbon Steel Joint Bars.
  - .2 ASTM A126-04, Standard Specification for Gray Iron Castings for Valves, Flanges, and Pipe Fittings.
  - .3 ASTM B61-08, Standard Specification for Steam or Valve Bronze Castings.
  - .4 ASTM B62-02, Standard Specification for Composition Bronze or Ounce Metal Castings.
- .3 Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS)
  - .1 MSS SP-70-06, Grey Iron Gate Valves, Flanged and Threaded Ends.
  - .2 MSS SP-71-05, Grey Iron Swing Check Valves, Flanged and Threaded Ends.
  - .3 MSS SP-82-1992, Valve Pressure Testing Methods.
  - .4 MSS SP-85-2002, Cast Iron Globe and Angle Valves, Flanged and Threaded Ends.

**1.4                ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Provide manufacturer's printed product literature, specifications and datasheets for valves and include product characteristics, performance criteria, physical size, finish and limitations.

**1.5                CLOSEOUT SUBMITTALS**

- .1 Submit maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

**1.6 DELIVERY, STORAGE AND HANDLING**

- .1 Packaging Waste Management: remove for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**Part 2 Products**

**2.1 MATERIAL**

- .1 Valves:
  - .1 Except for specialty valves, to be of single manufacturer.
  - .2 Standard specifications:
    - .1 Gate valves: MSS SP-70.
    - .2 Globe valves: MSS SP-85.
    - .3 Check valves: MSS SP-71.
  - .3 Requirements common to valves, unless specified otherwise:
    - .1 Body, bonnet: cast iron to ASTM B209 Class B.
    - .2 Connections: flanged ends plain face to ANSI B16.1.
    - .3 Inspection and pressure testing: to MSS SP-82.
    - .4 Bonnet gasket: non-asbestos.
    - .5 Stem: to have precision-machined Acme or 60 degrees V threads, top screwed for handwheel nut.
    - .6 Stuffing box: non-galling two-piece ball-jointed packing gland, gland bolts and nuts.
    - .7 Gland packing: non-asbestos.
    - .8 Handwheel: die-cast aluminum alloy to ASTM B85/B85M or malleable iron to ASTM A49. Nut of bronze to ASTM B62.
    - .9 Identification tag: with catalogue number, size, other pertinent data.
  - .4 All products to have CRN registration numbers.

**2.2 BUTTERFLY VALVES - RESILIENT SEAT - 200 PSIG**

- .1 Except to specialty valves, to be of single manufacturer.
- .2 To be suitable for dead-end service.
- .3 CRN registration number required for products.
- .4 Sizes:
  - .1 Lug type: NPS 2 to 30.
  - .2 Grooved end type: NPS 2 to 12.
- .5 Pressure rating for tight shut-off at temperatures up to maximum for seat material.
  - .1 NPS 2 - 12: 200 psig.

- .6 Minimum seat temperature ratings to 135 degrees C.
- .7 Application: on-off operation.
- .8 Full lug body (threaded).
- .9 Operators:
  - .1 NPS 2 - 6: handles capable of locking in any of ten (10) positions - 0 degrees to 90 degrees. Handle and release trigger - ductile iron. Return spring and hinge pin: carbon steel. Latch plate and mounting hardware: cadmium plated carbon steel. Standard coating: black laquer.
- .10 Designed to comply with MSS SP-67 and API 609.
- .11 Compatible with ANSI Class 125/Class 150 flanges.
- .12 Construction:
  - .1 Body: ductile iron
  - .2 Disc: 316 SS
  - .3 Seat: EPDM.
  - .4 Shaft: 316 stainless steel.
  - .5 Taper pin: 316 SS.
  - .6 Key: carbon steel.
  - .7 O-Ring: EPDM.
  - .8 Bushings: luberized bronze or Teflon.

### **2.3 GLOBE VALVES**

- .1 NPS 2 1/2 - 10, OSY:
  - .1 Body: with multiple-bolted bonnet.
  - .2 WP: 860 kPa steam, 1.4 MPa CWP.
  - .3 Bonnet-yoke gasket: non-asbestos.
  - .4 Disc: bronze to ASTM B62, fully guided from bottom, securely yet freely connected to stem for swivel action and accurate engagement with disc.
  - .5 Seat ring: renewable, regrindable, screwed into body.
  - .6 Stem: bronze to ASTM B62.
  - .7 Operator: handwheel
  - .8 Bypass: complete with union and NPS globe valve as Section 23 05 22 - Valves – Bronze.

### **2.4 VALVE OPERATORS**

- .1 Install valve operators as follows:
  - .1 Handwheel: on valves except as specified.
  - .2 Handwheel with chain operators: on valves installed more than 2400 mm above floor in boiler rooms and mechanical equipment rooms.

## **2.5 CHECK VALVES**

- .1 Swing check valves, Class 125:
  - .1 Body and bolted cover: with tapped and plugged opening on each side for hinge pin. Grooved or flanged ends: plain faced with smooth finish.
    - .1 Up to NPS 16: cast iron to ASTM A126 Class B
  - .2 Ratings:
    - .1 NPS 2 1/2 - 12: 860 kPa steam; 1.4 MPa CWP.
  - .3 Disc: rotating for extended life.
    - .1 Up to NPS 6: bronze to ASTM B62.
    - .2 NPS 8 and over: bronze-faced cast iron.
  - .4 Seat rings: renewable bronze to ASTM B62 screwed into body.
  - .5 Hinge pin, bushings: renewable bronze to ASTM B62.
  - .6 Disc: A126 Class B, secured to stem, rotating for extended life.
  - .7 Seat: cast iron, integral with body.
  - .8 Hinge pin: exelloy; bushings: malleable iron.
  - .9 Identification tag: fastened to cover.
  - .10 Hinge: galvanized malleable iron.
- .2 Swing check valves, NPS 2 1/2 - 8 Class 250:
  - .1 Body and bolted cover: cast iron to ASTM A126 Class B with tapped and plugged opening on each side for hinge pin.
  - .2 Flanged ends: 2 mm raised face with serrated finish.
  - .3 Rating: 250 psi steam; 500 psi CWP.
  - .4 Disc: rotating for extended life.
    - .1 Up to NPS 3: bronze to ASTM B61.
    - .2 NPS 4 - 8: iron faced with ASTM B61 bronze.
  - .5 Seat rings: renewable bronze to ASTM B61, screwed into body.
  - .6 Hinge pin, bushings: renewable, bronze to ASTM B61.
  - .7 Hinge: galvanized malleable iron.
  - .8 Identification tag: fastened to cover.

## **Part 3 Execution**

### **3.1 INSTALLATION**

- .1 Install rising stem valves in upright position with stem above horizontal.

### **3.2 CLEANING**

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**END OF SECTION**

**Part 1            General**

**1.1                SUMMARY**

- .1 Section Includes:
  - .1 Materials and requirements for the identification of piping systems, duct work, valves and controllers, including the installation and location of identification systems.

**1.2                RELATED SECTIONS**

- .1 Section 01 33 00 - Submittal Procedures
- .2 Section 01 74 21 - Construction/Demolition Waste Management and Disposal

**1.3                REFERENCES**

- .1 Canadian Gas Association (CGA)
  - .1 CSA/CGA B149.1-05, Natural Gas and Propane Installation Code.
- .2 Canadian General Standards Board (CGSB)
  - .1 CAN/CGSB-24.3-[92], Identification of Piping Systems.

**1.4                ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Include the following:
  - .1 Legend of proposed identification details for each system.
  - .2 Details of proposed nameplates, labels and tags.

**1.5                DELIVERY, STORAGE, AND HANDLING**

- .1 Packing, shipping, handling and unloading:
  - .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
  - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Waste Management and Disposal:
  - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**Part 2 Products**

**2.1 MANUFACTURER'S EQUIPMENT NAMEPLATES**

- .1 Metal or plastic laminate nameplate mechanically fastened to each piece of equipment by manufacturer.
- .2 Lettering and numbers raised or recessed.
- .3 Information to include, as appropriate:
  - .1 Equipment: manufacturer's name, model, size, serial number, capacity.
  - .2 Motor: voltage, Hz, phase, power factor, duty, frame size.

**2.2 SYSTEM NAMEPLATES**

- .1 Colours:
  - .1 Hazardous: red letters, white background.
  - .2 Elsewhere: black letters, white background (except where required otherwise by applicable codes).
- .2 Construction:
  - .1 3 mm thick laminated plastic, matte finish, with square corners, letters accurately aligned and machine engraved into core.
- .3 Sizes:
  - .1 Conform to following table:

Size # mm	Sizes (mm)	No. of Lines	Height of Letters (mm)
1	10 x 50	1	3
2	13 x 75	1	5
3	13 x 75	2	3
4	20 x 100	1	8
5	20 x 100	2	5
6	20 x 200	1	8
7	25 x 125	1	12
8	25 x 125	2	8
9	35 x 200	1	20

- .2 Use maximum of 25 letters/numbers per line.
- .4 Locations:
  - .1 Terminal cabinets, control panels: use size # 5.
  - .2 Equipment in Mechanical Rooms: use size # 9.

**2.3 EXISTING IDENTIFICATION SYSTEMS**

- .1 Apply existing identification system to new work.
- .2 Where existing identification system does not cover for new work, use identification system specified this section.

- .3 Before starting work, obtain written approval of identification system from Departmental Representative.

## 2.4 PIPING SYSTEMS GOVERNED BY CODES

- .1 Identification:
  - .1 Natural gas: to CSA/CGA B149.1.

## 2.5 IDENTIFICATION OF PIPING SYSTEMS

- .1 Identify contents by background colour marking, pictogram (as necessary), legend; direction of flow by arrows. To CAN/CGSB 24.3 except where specified otherwise.
- .2 Pictograms:
  - .1 Where required: Workplace Hazardous Materials Information System (WHMIS) regulations.
- .3 Legend:
  - .1 Block capitals to sizes and colours listed in CAN/CGSB 24.3.
- .4 Arrows showing direction of flow:
  - .1 Outside diameter of pipe or insulation less than 75 mm: 100 mm long x 50 mm high.
  - .2 Outside diameter of pipe or insulation 75 mm and greater: 150 mm long x 50 mm high.
  - .3 Use double-headed arrows where flow is reversible.
- .5 Extent of background colour marking:
  - .1 To full circumference of pipe or insulation.
  - .2 Length to accommodate pictogram, full length of legend and arrows.
- .6 Materials for background colour marking, legend, arrows:
  - .1 Pipes and tubing 20 mm and smaller: waterproof and heat-resistant pressure sensitive plastic marker tags.
  - .2 Other pipes: pressure sensitive plastic-coated cloth or vinyl with protective overcoating, waterproof contact adhesive undercoating, suitable for ambient of 100% RH and continuous operating temperature of 150 degrees C and intermittent temperature of 200 degrees C.
- .7 Colours and Legends:
  - .1 Where not listed, obtain direction from Departmental Representative.
  - .2 Colours for legends, arrows: to following table:

Background colour:	Legend, arrows:
Yellow	BLACK
Green	WHITE
Red	WHITE

- .3 Background colour marking and legends for piping systems:



Contents	Background colour marking	Legend
** Add design temperature		
++ Add design temperature and pressure		
Hot water heating supply	Yellow	HEATING SUPPLY
Hot water heating return	Yellow	HEATING RETURN
Make-up water	Yellow	MAKE-UP WTR
Safety valve vent	Yellow	STEAM VENT
Gasoline	Yellow	GASOLINE
Natural gas	to Codes	
Gas regulator vents	to Codes	

## 2.6 VALVES, CONTROLLERS

- .1 Lamicoid tags with 12 mm stamped identification data filled with black paint.
- .2 Include flow diagrams for each system, of approved size, showing charts and schedules with identification of each tagged item, valve type, service, function, normal position, location of tagged item.

## 2.7 CONTROLS COMPONENTS IDENTIFICATION

- .1 Identify all systems, equipment, components, controls, sensors with system nameplates specified in this section.
- .2 Inscriptions to include function and (where appropriate) fail-safe position.

## 2.8 LANGUAGE

- .1 Identification in English and French.
- .2 Use one nameplate and label for both languages.

## Part 3 Execution

### 3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

### 3.2 INSTALLATION

- .1 Perform work in accordance with CAN/CGSB-24.3 except as specified otherwise.
- .2 Provide ULC and/or CSA registration plates as required by respective agency.
- .3 Identify systems, equipment to conform to PWGSC PMSS.

### 3.3 NAMEPLATES

- .1 Locations:

- .1 In conspicuous location to facilitate easy reading and identification from operating floor.
- .2 Standoffs:
  - .1 Provide for nameplates on hot and/or insulated surfaces.
- .3 Protection:
  - .1 Do not paint, insulate or cover.

### **3.4 LOCATION OF IDENTIFICATION ON PIPING AND DUCTWORK SYSTEMS**

- .1 On long straight runs in open areas in boiler rooms, equipment rooms, galleries, tunnels: at not more than 17 m intervals and more frequently if required to ensure that at least one is visible from any one viewpoint in operating areas and walking aisles.
- .2 Adjacent to each change in direction.
- .3 At least once in each small room through which piping or ductwork passes.
- .4 On both sides of visual obstruction or where run is difficult to follow.
- .5 On both sides of separations such as walls, floors, partitions.
- .6 Where system is installed in pipe chases, ceiling spaces, galleries, confined spaces, at entry and exit points, and at access openings.
- .7 At beginning and end points of each run and at each piece of equipment in run.
- .8 At point immediately upstream of major manually operated or automatically controlled valves, and dampers. Where this is not possible, place identification as close as possible, preferably on upstream side.
- .9 Identification easily and accurately readable from usual operating areas and from access points.
  - .1 Position of identification approximately at right angles to most convenient line of sight, considering operating positions, lighting conditions, risk of physical damage or injury and reduced visibility over time due to dust and dirt.

### **3.5 VALVES, CONTROLLERS**

- .1 Valves and operating controllers, except where in plain sight of equipment they serve: Secure tags with non-ferrous chains or closed "S" hooks.
- .2 Install one copy of flow diagrams, valve schedules mounted in frame behind non-glare glass where directed Departmental Representative. Provide one copy (reduced in size if required) in each operating and maintenance manual.
- .3 Number valves in each system consecutively.

### **3.6 CLEANING**

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

**END OF SECTION**

**Part 1 General****1.1 SUMMARY**

- .1 Section Includes:
  - .1 Concrete housekeeping pads, hangers and supports for HVAC piping and equipment.

**1.2 RELATED SECTIONS**

- .1 Section 01 33 00 - Submittal Procedures
- .2 Section 01 78 00 – Closeout Submittals

**1.3 REFERENCES**

- .1 American Society of Mechanical Engineers (ASME)
  - .1 ASME B31.1-07, Power Piping.
- .2 ASTM International
  - .1 ASTM A125-1996 (R2007), Standard Specification for Steel Springs, Helical, Heat-Treated.
  - .2 ASTM A307-07b, Standard Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
  - .3 ASTM A563-07a, Standard Specification for Carbon and Alloy Steel Nuts.
- .3 Manufacturer's Standardization Society of the Valves and Fittings Industry (MSS)
  - .1 MSS SP58-2002, Pipe Hangers and Supports - Materials, Design and Manufacture.
  - .2 MSS SP69-2003, Pipe Hangers and Supports - Selection and Application.
  - .3 MSS SP89-2003, Pipe Hangers and Supports - Fabrication and Installation Practices.
- .4 Canadian Gas Association (CGA)
  - .1 CAN/CGA-B149.1-05, Natural Gas and Propane Installation.
- .5 National Research Council (NRC)/Institute for Research in Construction
  - .1 NRCC 38728, National Plumbing Code of Canada (NPC) - 2005
- .6 Underwriter's Laboratories of Canada (ULC)

**1.4 ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:

- .1 Provide manufacturer's printed product literature and data sheets for hangers and supports and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
  - .1 Submit drawings stamped and signed by professional engineer registered or licensed in British Columbia of Canada.
  - .2 Submit shop drawings for:
    - .1 Bases, hangers and supports.
    - .2 Connections to equipment and structure.
    - .3 Structural assemblies.
- .4 Certificates:
  - .1 Submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .5 Manufacturers' Instructions:
  - .1 Provide manufacturer's installation instructions.

## **1.5 CLOSEOUT SUBMITTALS**

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

## **1.6 DELIVERY, STORAGE AND HANDLING**

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Delivery and Acceptance Requirements:
  - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

## **Part 2 Products**

### **2.1 SYSTEM DESCRIPTION**

- .1 Design Requirements:
  - .1 Construct pipe hanger and support to manufacturer's recommendations utilizing manufacturer's regular production components, parts and assemblies.
  - .2 Base maximum load ratings on allowable stresses prescribed by ASME B31.1 or MSS SP58.
  - .3 Ensure that supports, guides, anchors do not transmit excessive quantities of heat to building structure.

- .4 Design hangers and supports to support systems under conditions of operation, allow free expansion and contraction, prevent excessive stresses from being introduced into pipework or connected equipment.
- .5 Provide for vertical adjustments after erection and during commissioning. Amount of adjustment in accordance with MSS SP58.

## 2.2 GENERAL

- .1 Fabricate hangers, supports and sway braces in accordance with MSS SP58.

## 2.3 PIPE HANGERS

- .1 Finishes:
  - .1 Pipe hangers and supports: galvanized after manufacture.
  - .2 Use electro-plating galvanizing process or hot dipped galvanizing process.
  - .3 Ensure steel hangers in contact with copper piping are copper plated or epoxy coated.
- .2 Upper attachment structural: suspension from lower flange of I-Beam:
  - .1 Cold piping NPS 2 maximum: malleable iron C-clamp with hardened steel cup point setscrew, locknut [carbon steel retaining clip].
    - .1 Rod: 9 mm UL listed.
  - .2 Cold piping NPS 2 1/2 or greater, hot piping: malleable iron beam clamp, eye rod, jaws and extension with carbon steel retaining clip, tie rod, nuts and washers, UL listed to MSS-SP58 and MSS-SP69.
- .3 Upper attachment to concrete:
  - .1 Ceiling: carbon steel welded eye rod, clevis plate, clevis pin and cotters with weldless forged steel eye nut. Ensure eye 6 mm minimum greater than rod diameter.
  - .2 Concrete inserts: wedge shaped body with knockout protector plate UL listed to MSS SP69.
- .4 Hanger rods: threaded rod material to MSS SP58:
  - .1 Ensure that hanger rods are subject to tensile loading only.
  - .2 Provide linkages where lateral or axial movement of pipework is anticipated.
  - .3 Do not use 22 mm or 28 mm rod.
- .5 Pipe attachments: material to MSS SP58:
  - .1 Attachments for steel piping: carbon steel black.
  - .2 Attachments for copper piping: copper plated black steel.
  - .3 Use insulation shields for hot pipework.
  - .4 Oversize pipe hangers and supports.
- .6 Adjustable clevis: material to MSS SP69 UL listed, clevis bolt with nipple spacer and vertical adjustment nuts above and below clevis.

- .1 Ensure "U" has hole in bottom for rivetting to insulation shields.
- .7 Yoke style pipe roll: carbon steel yoke, rod and nuts with cast iron roll, to MSS SP69.
- .8 U-bolts: carbon steel to MSS SP69 with 2 nuts at each end to ASTM A563.
  - .1 Finishes for steel pipework: black.
  - .2 Finishes for copper, glass, brass or aluminum pipework: black, with formed portion plastic coated.
- .9 Pipe rollers: cast iron roll and roll stand with carbon steel rod to MSS SP69.

## **2.4 RISER CLAMPS**

- .1 Steel or cast iron pipe: black carbon steel to MSS SP58, type 42, UL listed.
- .2 Copper pipe: carbon steel copper plated to MSS SP58, type 42.
- .3 Bolts: to ASTM A307.
- .4 Nuts: to ASTM A563.

## **2.5 INSULATION PROTECTION SHIELDS**

- .1 Insulated cold piping:
  - .1 64 kg/m<sup>3</sup> density insulation plus insulation protection shield to: MSS SP69, galvanized sheet carbon steel. Length designed for maximum 3 m span.
- .2 Insulated hot piping:
  - .1 Curved plate 300 mm long, with edges turned up, welded-in centre plate for pipe sizes NPS 12 and over, carbon steel to comply with MSS SP69.

## **2.6 CONSTANT SUPPORT SPRING HANGERS**

- .1 Springs: alloy steel to ASTM A125, shot peened, magnetic particle inspected, with +/-5% spring rate tolerance, tested for free height, spring rate, loaded height and provided with Certified Mill Test Report (CMTR).
- .2 Load adjustability: 10% minimum adjustability each side of calibrated load. Adjustment without special tools. Adjustments not to affect travel capabilities.
- .3 Provide upper and lower factory set travel stops.
- .4 Provide load adjustment scale for field adjustments.
- .5 Total travel to be actual travel + 20%. Difference between total travel and actual travel 25 mm minimum.
- .6 Individually calibrated scales on each side of support calibrated prior to shipment, complete with calibration record.

## **2.7 VARIABLE SUPPORT SPRING HANGERS**

- .1 Vertical movement: 13 mm minimum, 50 mm maximum, use single spring pre-compressed variable spring hangers.

- .2 Vertical movement greater than 50 mm: use double spring pre-compressed variable spring hanger with 2 springs in series in single casing.
- .3 Variable spring hanger complete with factory calibrated travel stops. Provide certificate of calibration for each hanger.
- .4 Steel alloy springs: to ASTM A125, shot peened, magnetic particle inspected, with +/-5 % spring rate tolerance, tested for free height, spring rate, loaded height and provided with CMTR.

## **2.8 EQUIPMENT ANCHOR BOLTS AND TEMPLATES**

- .1 Provide templates to ensure accurate location of anchor bolts.

## **2.9 HOUSE-KEEPING PADS**

- .1 Provide 100 mm high concrete housekeeping pads for base-mounted equipment; size pads 50 mm larger than equipment; chamfer pad edges.
- .2 Concrete: to Section 03 30 00 - Cast-in-Place Concrete.

## **Part 3 Execution**

### **3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

### **3.2 INSTALLATION**

- .1 Install in accordance with:
  - .1 Manufacturer's instructions and recommendations.
- .2 Vibration Control Devices:
  - .1 Install on piping systems at pumps, boilers and as indicated.
- .3 Clamps on riser piping:
  - .1 Support independent of connected horizontal pipework using riser clamps and riser clamp lugs welded to riser.
  - .2 Bolt-tightening torques to industry standards.
  - .3 Steel pipes: install below coupling or shear lugs welded to pipe.
  - .4 Cast iron pipes: install below joint.
- .4 Clevis plates:
  - .1 Attach to concrete with 4 minimum concrete inserts, one at each corner.
- .5 Provide supplementary structural steelwork where structural bearings do not exist or where concrete inserts are not in correct locations.
- .6 Use approved constant support type hangers where:



- .1 Vertical movement of pipework is 13 mm or more,
- .2 Transfer of load to adjacent hangers or connected equipment is not permitted.
- .7 Use variable support spring hangers where:
  - .1 Transfer of load to adjacent piping or to connected equipment is not critical.
  - .2 Variation in supporting effect does not exceed 25 % of total load.

### 3.3 HANGER SPACING

- .1 Plumbing piping: to Canadian Plumbing Code or authority having jurisdiction.
- .2 Gas and fuel oil piping: up to NPS 1/2: every 1.8 m.
- .3 Copper piping: up to NPS 1/2: every 1.5 m.
- .4 Flexible joint roll groove pipe: in accordance with table below for steel, but not less than one hanger at joints. Table listings for straight runs without concentrated loads and where full linear movement is not required.
- .5 Within 300 mm of each elbow.

Maximum Pipe Size : NPS	Maximum Spacing Steel	Maximum Spacing Copper
up to 1-1/4	2.4 m	1.8 m
1-1/2	3.0 m	2.4 m
2	3.0 m	2.4 m
2-1/2	3.7 m	3.0 m
3	3.7 m	3.0 m
3-1/2	3.7 m	3.3 m
4	3.7 m	3.6 m
5	4.3 m	
6	4.3 m	
8	4.3 m	
10	4.9 m	
12	4.9 m	

- .6 Pipework greater than NPS 12: to MSS SP69.

### 3.4 HANGER INSTALLATION

- .1 Install hanger so that rod is vertical under operating conditions.
- .2 Adjust hangers to equalize load.
- .3 Support from structural members. Where structural bearing does not exist or inserts are not in suitable locations, provide supplementary structural steel members.

### 3.5 HORIZONTAL MOVEMENT

- .1 Angularity of rod hanger resulting from horizontal movement of pipework from cold to hot position not to exceed 4 degrees from vertical.
- .2 Where horizontal pipe movement is less than 13 mm, offset pipe hanger and support so that rod hanger is vertical in the hot position.

**3.6 FINAL ADJUSTMENT**

- .1 Adjust hangers and supports:
  - .1 Ensure that rod is vertical under operating conditions.
  - .2 Equalize loads.
- .2 Adjustable clevis:
  - .1 Tighten hanger load nut securely to ensure proper hanger performance.
  - .2 Tighten upper nut after adjustment.
- .3 C-clamps:
  - .1 Follow manufacturer's recommended written instructions and torque values when tightening C-clamps to bottom flange of beam.
- .4 Beam clamps:
  - .1 Hammer jaw firmly against underside of beam.

**3.7 CLEANING**

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**END OF SECTION**

---

**Part 1            General**

**1.1                SUMMARY**

- .1 Section Includes:
  - .1 Vibration isolation materials and components, seismic control measures and their installation.

**1.2                REFERENCES**

- .1 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
  - .1 Material Safety Data Sheets (MSDS).
- .2 National Building Code of Canada (NBC) - 1995

**1.3                ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
  - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
    - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
    - .1 Shop drawings: submit drawings stamped and signed by professional engineer registered or licensed in Province of British Columbia, Canada.
    - .2 Provide separate shop drawings for each isolated system complete with performance and product data.
    - .3 Provide detailed drawings of seismic control measures for equipment and piping.
  - .3 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
    - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
    - .2 Instructions: submit manufacturer's installation instructions.
    - .3 Manufacturer's Field Reports: manufacturer's field reports specified.

**1.4                QUALITY ASSURANCE**

- .1 Health and Safety:
  - .1 Do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.

---

**1.5 DELIVERY, STORAGE, AND HANDLING**

- .1 Packing, shipping, handling and unloading:
  - .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
  - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Waste Management and Disposal:
  - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**Part 2 Products**

**2.1 GENERAL**

- .1 Size and shape of bases type and performance of vibration isolation as indicated.

**2.2 ELASTOMERIC PADS**

- .1 Type EP1 - neoprene waffle or ribbed; 9 mm minimum thick; 50 durometer; maximum loading 350 kPa.
- .2 Type EP2 - rubber waffle or ribbed; 9 mm minimum thick; 30 durometer natural rubber; maximum loading 415 kPa.
- .3 Type EP3 - neoprene-steel-neoprene; 9 mm minimum thick neoprene bonded to 1.71 mm steel plate; 50 durometer neoprene, waffle or ribbed; holes sleeved with isolation washers; maximum loading 350 kPa.
- .4 Type EP4 - rubber-steel-rubber; 9 mm minimum thick rubber bonded to 1.71 mm steel plate; 30 durometer natural rubber, waffle or ribbed; holes sleeved with isolation washers; maximum loading 415 kPa.

**2.3 ELASTOMERIC MOUNTS**

- .1 Type M1 - colour coded; neoprene in shear; maximum durometer of 60; threaded insert and two bolt-down holes; ribbed top and bottom surfaces.

**2.4 SPRINGS**

- .1 Design stable springs: ratio of lateral to axial stiffness is equal to or greater than 1.2 times ratio of static deflection to working height. Select for 50% travel beyond rated load. Units complete with levelling devices.
- .2 Ratio of height when loaded to diameter of spring between 0.8 to 1.0.
- .3 Colour code springs.

---

## **2.5 SPRING MOUNT**

- .1 Zinc or cadmium plated hardware; housings coated with rust resistant paint.
- .2 Type M2 - stable open spring: support on bonded 6 mm minimum thick ribbed neoprene or rubber friction and acoustic pad.
- .3 Type M3 - stable open spring: 6 mm minimum thick ribbed neoprene or rubber friction and acoustic pad, bonded under isolator and on isolator top plate; levelling bolt for rigidly mounting to equipment.
- .4 Type M4 - restrained stable open spring: supported on bonded 6 mm minimum thick ribbed neoprene or rubber friction and acoustic pad; built-in resilient limit stops, removable spacer plates.
- .5 Type M5 - enclosed spring mounts with snubbers for isolation up to 950 kg maximum.
- .6 Performance: as indicated.

## **2.6 HANGERS**

- .1 Colour coded springs, rust resistant, painted box type hangers. Arrange to permit hanger box or rod to move through a 30 degrees arc without metal to metal contact.
- .2 Type H1 - neoprene - in-shear, moulded with rod isolation bushing which passes through hanger box.
- .3 Type H2 - stable spring, elastomeric washer, cup with moulded isolation bushing which passes through hanger box.
- .4 Type H3 - stable spring, elastomeric element, cup with moulded isolation bushing which passes through hanger box.
- .5 Type H4 - stable spring, elastomeric element with precompression washer and nut with deflection indicator.
- .6 Performance: as indicated.

## **2.7 ACOUSTIC BARRIERS FOR ANCHORS AND GUIDES**

- .1 Acoustic barriers: between pipe and support, consisting of 25 mm minimum thick heavy duty duck and neoprene isolation material.

## **2.8 HORIZONTAL THRUST RESTRAINT**

- .1 Spring and elastomeric element housed in box frame; assembly complete with rods and angle brackets for equipment and ductwork attachment; provision for adjustment to limit maximum start and stop movement to 9 mm.
- .2 Arrange restraints symmetrically on either side of unit and attach at centerline of thrust.

## **2.9 STRUCTURAL BASES**

- .1 Type B1 - Prefabricated steel base: integrally welded on sizes up to 2400 mm on smallest dimension, split for field welding on sizes over 2400 mm on smallest dimension

and reinforced for alignment of drive and driven equipment; without supplementary hold down devices; complete with isolation element attached to base brackets arranged to minimize height; pre-drilled holes to receive equipment anchor bolts; and complete with adjustable built-in motor slide rail where indicated.

- .2 Type B2 - Steel rail base: structural steel, positioned for alignment of drive and driven equipment; without supplementary hold down devices; complete with isolation element attached to base brackets arranged to minimize height; and pre-drilled holes to receive equipment anchor bolts.
- .3 Bases to clear housekeeping pads by 25 mm minimum.

## 2.10 SEISMIC CONTROL MEASURES

- .1 General:
  - .1 Seismic control systems to work in every direction.
  - .2 Fasteners and attachment points to resist same maximum load as seismic restraint.
  - .3 Drilled or power driven anchors and fasteners not permitted.
  - .4 No equipment, equipment supports or mounts to fail before failure of structure.
  - .5 Supports of cast iron or threaded pipe not permitted.
  - .6 Seismic control measures not to interfere with integrity of firestopping.
- .2 Static equipment:
  - .1 Anchor equipment to equipment supports. Anchor equipment supports to structure.
  - .2 Suspended equipment:
    - .1 Use one or more of following methods depending upon site conditions:
      - .1 Install tight to structure.
      - .2 Cross brace in every direction.
      - .3 Brace back to structure.
      - .4 Cable restraint system.
    - .3 Seismic restraints:
      - .1 Cushioning action gentle and steady.
      - .2 Never reach metal-like stiffness.
- .3 Vibration isolated equipment:
  - .1 Seismic control measures not to jeopardize noise and vibration isolation systems. Provide 6 to 9 mm clearance during normal operation of equipment and systems between seismic restraint and equipment.
  - .2 Incorporate seismic restraints into vibration isolation system to resist complete isolator unloading.
  - .3 As indicated.
- .4 Piping systems:

- .1 Piping systems: hangers longer than 300 mm; brace at each hanger.
- .2 Compatible with requirements for anchoring and guiding of piping systems.
- .5 Bracing methods:
  - .1 Reviewed by Departmental Representative.
  - .2 Structural angles or channels.
  - .3 Cable restraint system incorporating grommets, shackles and other hardware to ensure alignment of restraints and to avoid bending of cables at connection points. Incorporate neoprene into cable connections to reduce shock loads.

### **Part 3 Execution**

#### **3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

#### **3.2 INSTALLATION**

- .1 Seismic control measures to meet requirements of NBC.
- .2 Install vibration isolation equipment in accordance with manufacturers instructions and adjust mountings to level equipment.
- .3 Ensure piping, ducting and electrical connections to isolated equipment do not reduce system flexibility and that piping, conduit and ducting passage through walls and floors do not transmit vibrations.
- .4 Unless indicated otherwise, support piping connected to isolated equipment with spring mounts or spring hangers with 25 mm minimum static deflection as follows:
  - .1 Up to NPS4: first 3 points of support. NPS5 to NPS8: first 4 points of support. NPS10 and Over: first 6 points of support.
  - .2 First point of support: static deflection of twice deflection of isolated equipment, but not more than 50 mm.
- .5 Where isolation is bolted to floor use vibration isolation rubber washers.
- .6 Block and shim level bases so that ductwork and piping connections can be made to rigid system at operating level, before isolator adjustment is made. Ensure that there is no physical contact between isolated equipment and building structure.

#### **3.3 FIELD QUALITY CONTROL**

- .1 Manufacturer's Field Services:
  - .1 Arrange with manufacturer's representative to review work of this Section and submit written reports to verify compliance with Contract Documents.

- .2 Manufacturer's Field Services: consisting of product use recommendations and periodic site visits to review installation, scheduled as follows:
  - .1 After delivery and storage of Products.
  - .2 After preparatory work is complete but before installation commences.
  - .3 Twice during the installation, at 25% and 60% completion stages.
  - .4 Upon completion of installation.
- .3 Submit manufacturer's reports to Departmental Representative within 3 days of manufacturer representative's review.
- .4 Make adjustments and corrections in accordance with written report.
- .2 Inspection and Certification:
  - .1 Experienced and competent sound and vibration testing professional engineer to take vibration measurement for HVAC system after start up and TAB of systems.
  - .2 Take vibration measurements for equipment listed below.
    - .1 Heating system equipment:
      - .1 Boilers
      - .2 Pumps
  - .3 Provide Departmental Representative with notice 24 h in advance of commencement of tests.
  - .4 Establish adequacy of equipment isolation and acceptability of noise levels in occupied areas and where appropriate, remedial recommendations (including sound curves).
  - .5 Submit complete report of test results including sound curves.

### **3.4 CLEANING**

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

**END OF SECTION**



**Part 1            General**

**1.1                SUMMARY**

- .1      TAB is used throughout this Section to describe the process, methods and requirements of testing, adjusting and balancing for HVAC.
- .2      TAB means to test, adjust and balance to perform in accordance with requirements of Contract Documents and to do other work as specified in this section.

**1.2                QUALIFICATIONS OF TAB PERSONNEL**

- .1      Employ an established independent TAB agency to test and balance the listed systems. Prior to finalizing contractual arrangements with the TAB agency.
- .2      Submit names of personnel to perform TAB to Departmental Representative within 30 days of award of contract.
- .3      Provide documentation confirming qualifications, successful experience.
- .4      TAB: performed in accordance with the requirements of standard under which TAB Firm's qualifications are approved:
  - .1      Associated Air Balance Council, (AABC) National Standards for Total System Balance, MN-1-2002.
  - .2      National Environmental Balancing Bureau NEBB TABES, Procedural Standards for Testing, Adjusting, Balancing of Environmental Systems-1998.
  - .3      Sheet Metal and Air Conditioning Contractors' National Association (SMACNA), HVAC TAB HVAC Systems - Testing, Adjusting and Balancing-2002.
- .5      Recommendations and suggested practices contained in the TAB Standard: mandatory.
- .6      Use TAB Standard provisions, including checklists, and report forms to satisfy Contract requirements.
- .7      Use TAB Standard for TAB, including qualifications for TAB Firm and Specialist and calibration of TAB instruments.
- .8      Where instrument manufacturer calibration recommendations are more stringent than those listed in TAB Standard, use manufacturer's recommendations.
- .9      TAB Standard quality assurance provisions such as performance guarantees form part of this contract.
  - .1      For systems or system components not covered in TAB Standard, use TAB procedures developed by TAB Specialist.
  - .2      Where new procedures, and requirements, are applicable to Contract requirements have been published or adopted by body responsible for TAB Standard used (AABC, NEBB, or TABB), requirements and recommendations contained in these procedures and requirements are mandatory.

### **1.3 PURPOSE OF TAB**

- .1 Test to verify proper and safe operation, determine actual point of performance, evaluate qualitative and quantitative performance of equipment, systems and controls at design, average and low loads using actual or simulated loads
- .2 Adjust and regulate equipment and systems to meet specified performance requirements and to achieve specified interaction with other related systems under normal and emergency loads and operating conditions.
- .3 Balance systems and equipment to regulate flow rates to match load requirements over full operating ranges.

### **1.4 EXCEPTIONS**

- .1 TAB of systems and equipment regulated by codes, standards to satisfaction of authority having jurisdiction.

### **1.5 CO-ORDINATION**

- .1 Schedule time required for TAB (including repairs, re-testing) into project construction and completion schedule to ensure completion before acceptance of project.
- .2 Do TAB of each system independently and subsequently, where interlocked with other systems, in unison with those systems.

### **1.6 PRE-TAB REVIEW**

- .1 Review contract documents before project construction is started and confirm in writing to Departmental Representative adequacy of provisions for TAB and other aspects of design and installation pertinent to success of TAB.
- .2 Review specified standards and report to Departmental Representative in writing proposed procedures which vary from standard.
- .3 During construction, co-ordinate location and installation of TAB devices, equipment, accessories, measurement ports and fittings.

### **1.7 START-UP**

- .1 Follow start-up procedures as recommended by equipment manufacturer unless specified otherwise.
- .2 Follow special start-up procedures specified elsewhere in Division 23.

### **1.8 OPERATION OF SYSTEMS DURING TAB**

- .1 Operate systems for length of time required for TAB and as required by Departmental Representative for verification of TAB reports.

### **1.9 START OF TAB**

- .1 Notify Departmental Representative 7 days prior to start of TAB.
- .2 Start TAB when building is essentially completed, including:

- .3 Pressure, leakage, other tests specified elsewhere Division 23.
- .4 Provisions for TAB installed and operational.
- .5 Start-up, verification for proper, normal and safe operation of mechanical and associated electrical and control systems affecting TAB including but not limited to:
  - .1 Proper thermal overload protection in place for electrical equipment.
  - .2 Liquid systems:
    - .1 Flushed, filled, vented.
    - .2 Correct pump rotation.
    - .3 Strainers in place, baskets clean.
    - .4 Isolating and balancing valves installed, open.
    - .5 Calibrated balancing valves installed, at factory settings.
    - .6 Chemical treatment systems complete, operational.

**1.10 APPLICATION TOLERANCES**

- .1 Do TAB to following tolerances of design values:
  - .1 Hydronic systems: plus or minus 10 %.

**1.11 ACCURACY TOLERANCES**

- .1 Measured values accurate to within plus or minus 2 % of actual values.

**1.12 INSTRUMENTS**

- .1 Prior to TAB, submit to Departmental Representative list of instruments used together with serial numbers.
- .2 Calibrate in accordance with requirements of most stringent of referenced standard for either applicable system or HVAC system.
- .3 Calibrate within 3 months of TAB. Provide certificate of calibration to Departmental Representative.

**1.13 ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Submit, prior to commencement of TAB:
- .2 Proposed methodology and procedures for performing TAB if different from referenced standard.

**1.14 PRELIMINARY TAB REPORT**

- .1 Submit for checking and approval of Departmental Representative, prior to submission of formal TAB report, sample of rough TAB sheets. Include:
  - .1 Details of instruments used.
  - .2 Details of TAB procedures employed.
  - .3 Calculations procedures.

.4 Summaries.

**1.15 TAB REPORT**

- .1 Format in accordance with SMACNA Guidelines.
- .2 TAB report to show results in SI units and to include:
  - .1 Project record drawings.
  - .2 System schematics.
- .3 Submit 6 copies of TAB Report Departmental Representative for verification and approval, in English in D-ring binders, complete with index tabs.

**1.16 VERIFICATION**

- .1 Reported results subject to verification Departmental Representative.
- .2 Provide personnel and instrumentation to verify up to 30% of reported results.
- .3 Number and location of verified results as directed Departmental Representative.
- .4 Pay costs to repeat TAB as required to satisfaction Departmental Representative.

**1.17 SETTINGS**

- .1 After TAB is completed to satisfaction Departmental Representative, replace drive guards, close access doors, lock devices in set positions, and ensure sensors are at required settings.
- .2 Permanently mark settings to allow restoration at any time during life of facility. Do not eradicate or cover markings.

**1.18 COMPLETION OF TAB**

- .1 TAB considered complete when final TAB Report received and approved by Departmental Representative.

**1.19 TAB GENERAL**

- .1 Standard: TAB to most stringent of this section.
- .2 Do TAB of following systems, equipment, components, controls:
  - .1 Heating hot water system(s).
- .3 Qualifications: personnel performing TAB current member in good standing of AABC.
- .4 The TAB agency shall be responsible to the Contractor but report jointly to the Departmental Representative and the Contractor. Report in writing to the Departmental Representative any lack of cooperation and any discrepancies or items not installed in accordance with the contract documents.
- .5 Procedures shall be in general accordance with AABC'S National Standards for Field Measurement and Instrumentation and ASHRAE Standards.

- .6 The TAB agency shall agree to perform spot checks, where requested, in the presence of the Departmental Representative.
- .7 .Work with the TAB agency to:
  - .1 Ensure that all mechanical systems are complete and ready to be balanced and provide sufficient time for testing and balancing prior to substantial performance.
  - .2 Make corrections to achieve system balance without delay, include all corrections made during the balancing procedure on "As Built" Drawings. Mechanical Contractor to provide "As Built" information to the balancing agency before balancing commences.
  - .3 Maintain all systems in full operation during the complete testing and balancing period.
  - .4 Employ control technicians to make adjustments to the control systems to facilitate the balancing process.
- .8 Consult with the Departmental Representative to clarify the design intent where necessary or in case there are any problems foreseen as the balancing processes.
- .9 Complete air balance before commencing water balance where heating coils are installed in the air system. Balancing shall not commence until systems have been cleaned and treated and the air removed from within the piping systems.
- .10 This TAB agency shall remove and re-install ceiling tile to provide access to piping. The TAB agency will make good any damage or soiling caused by his forces.
- .11 Permanently mark final settings on valves, dampers and other adjustment devices. Set and lock all memory stop balancing devices.
- .12 The controls contractor and TAB agency are to allow for checking and making adjustments during the 12 month warranty period, when weather conditions provide natural loads and in cases where complaints arise.
- .13 Submit a draft balance report to the Departmental Representative for approval and submit approved copies to the agency preparing the O & M manuals for inclusion in each operating and maintenance manual. Provide field notes in the balancing report to clearly identify unusual conditions, problem areas and report on any cases where the specified flow rates or conditions could not be achieved by adjustment. Identify outstanding problems that cannot be corrected by the balancing team or that will not be corrected by the installing trades (e.g. in cases where additional balancing dampers are required).
- .14 Submit a statutory declaration to the Departmental Representative, certifying that the testing and balancing procedures have been completed, that complete factual reports have been distributed and that directions have been given to the Contractor to correct faults and omissions and, finally, that follow-up testing, after correction of faults and omissions, has been completed and recorded. Reports to be signed by the senior member of the TAB agency.

- .15 The Balancing Agency shall include for 3 days of return visits for readjustment of systems after the building is occupied and used.

**1.20 LIQUID SYSTEMS TAB**

- .1 Set balance valves and balance fittings to provide required or design flow rates for each system component.
- .2 Use installed flow measuring devices to determine flow rates for system balance. Where flow measuring devices are not installed, base flow balance on the air and liquid temperature difference across terminal heating/cooling elements and coils, acknowledging the different design temperature drops/rises used in the design of the systems.
- .3 Effect system balance with automatic control valves fully open to heat transfer elements.
- .4 Trim pump impellers to match pump performance to system characteristics rather than artificially increasing system pressure drops to match pump characteristics as directed by the Departmental Representative.
- .5 Check air vents to ensure that they are correctly installed and are operating properly. The mechanical contractor shall ensure that all air is removed from within the piping system and that there is flow throughout all piping systems before the balancing is started.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not used.

**END OF SECTION**

**Part 1            General**

**1.1                SUMMARY**

- .1    Section Includes:
  - .1    Thermal insulation for HVAC piping and Plumbing piping.

**1.2                RELATED SECTIONS**

- .1    Section 01 33 00 - Submittal Procedures
- .2    Section 01 74 21 - Construction/Demolition Waste Management and Disposal
- .3    Section 23 05 29 – Hangers and Supports for HVAC Piping and Equipment

**1.3                REFERENCES**

- .1    American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE)
  - .1    ASHRAE Standard 90.1-01, Energy Standard for Buildings Except Low-Rise Residential Buildings (IESNA co-sponsored; ANSI approved; Continuous Maintenance Standard).
- .2    American Society for Testing and Materials International (ASTM)
  - .1    ASTM C449/C449M-00, Standard Specification for Mineral Fiber-Hydraulic-Setting Thermal Insulating and Finishing Cement.
  - .2    ASTM C547-2003, Mineral Fiber Pipe Insulation.
  - .3    ASTM C921, Standard Practice for Determining the Properties of Jacketing Materials for Thermal Insulation.
- .3    Canadian General Standards Board (CGSB)
  - .1    CGSB 51-GP-52Ma-89, Vapour Barrier, Jacket and Facing Material for Pipe, Duct and Equipment Thermal Insulation.
  - .2    CAN/CGSB-51.53-95, Poly (Vinyl Chloride) Jacketing Sheet, for Insulated Pipes, Vessels and Round Ducts
- .4    Health Canada/Workplace Hazardous Materials Information System (WHMIS)
  - .1    Material Safety Data Sheets (MSDS).
- .5    Manufacturer's Trade Associations
  - .1    Thermal Insulation Association of Canada (TIAC): National Insulation Standards (Revised 2004).
- .6    Underwriters' Laboratories of Canada (ULC)

**1.4                DEFINITIONS**

- .1    For purposes of this section:

- .1 "CONCEALED" - insulated mechanical services in suspended ceilings and non-accessible chases and furred-in spaces.
- .2 "EXPOSED" - will mean "not concealed" as specified.
- .2 TIAC ss:
  - .1 CRF: Code Rectangular Finish.
  - .2 CPF: Code Piping Finish.

### **1.5 ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit the following shop drawing information:
  - .1 Pipe Insulation" manufacturers literature
  - .2 Installation requirements
  - .3 Schedule of all piping systems and proposed insulation types, thicknesses and finishes.

### **1.6 DELIVERY, STORAGE AND HANDLING**

- .1 Packing, shipping, handling and unloading:
  - .1 Deliver, store and handle in accordance with manufacturer's written instructions.
  - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
  - .3 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .2 Storage and Protection:
  - .1 Protect from weather, construction traffic.
  - .2 Protect against damage.
  - .3 Store at temperatures and conditions required by manufacturer.
- .3 Waste Management and Disposal:
  - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
  - .2 Place excess or unused insulation and insulation accessory materials in designated containers.
  - .3 Divert unused metal materials from landfill to metal recycling facility approved by Departmental Representative.
  - .4 Dispose of unused adhesive material at official hazardous material collections site approved by Departmental Representative.



---

**Part 2 Products**

**2.1 FIRE AND SMOKE RATING**

- .1 In accordance with CAN/ULC-S102.
  - .1 Maximum flame spread rating: 25.
  - .2 Maximum smoke developed rating: 50.

**2.2 INSULATION**

- .1 Mineral fibre specified includes glass fibre, rock wool, slag wool.
- .2 Thermal conductivity ("k" factor) not to exceed specified values at 24 degrees C mean temperature when tested in accordance with ASTM C335.

**2.3 PREFORMED PIPE COVERING**

- .1 Mineral Fibre - Low and Medium Temperature:
  - .1 With integral vapour barrier jacket and longitudinal lap.
  - .2 Thermal conductivity at 24oC - 0.033 W/m/deg.C.
  - .3 Acceptable Products:
    - .1 Manson Alley K, Owens Corning SSL-11, Knauf 850 ASJ/SSL, Johns Manville Micro-Lok AP-T Plus, Owens Corning 1200 ASJ/SSL.
- .2 Mineral Fibre - High Temperature:
  - .1 With integral vapour barrier jacket and longitudinal lap.
  - .2 Thermal Conductivity at 93oC - 0.040 W/m/deg.C.
  - .3 Acceptable Products:
    - .1 Manson Alley Kapt, Johns Manville Micro-Lok AP-T Plus, Owens Corning 1200 ASJ/SSL, Roxul ASJ/SL.
- .3 Flexible Foamed Elastomeric:
  - .1 Thermal Conductivity at 24oC - 0.040 W/m/deg.C.
  - .2 Acceptable Products:
    - .1 AP Armaflex, Rubatex R-180-FS.
- .4 Flexible Closed Cell:
  - .1 Thermal Conductivity at 24oC - 0.036 W/m/deg.C.
  - .2 Acceptable Products:
    - .1 Bondtex Polyethylene, Therma-Cel.

**2.4 JACKETS**

- .1 Canvas:

- .1 220 gm/m<sup>2</sup> cotton, plain weave, treated with dilute fire retardant lagging adhesive to ASTM C921.
- .2 Lagging adhesive: compatible with insulation.

### **Part 3 Execution**

#### **3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

#### **3.2 PRE-INSTALLATION REQUIREMENT**

- .1 Pressure testing of piping systems and adjacent equipment to be complete, witnessed and certified.
- .2 Surfaces clean, dry, free from foreign material.

#### **3.3 INSTALLATION**

- .1 Install in accordance with TIAC National Standards.
- .2 Apply materials in accordance with manufacturers instructions and this specification.
- .3 Use two layers with staggered joints when required nominal wall thickness exceeds 75 mm.
- .4 Maintain uninterrupted continuity and integrity of vapour retarder jacket and finishes.
  - .1 Install hangers, supports outside vapour retarder jacket.
- .5 Supports, Hangers:
  - .1 Apply high compressive strength insulation, suitable for service, at oversized saddles and shoes where insulation saddles have not been provided.

#### **3.4 REMOVABLE, PRE-FABRICATED, INSULATION AND ENCLOSURES**

- .1 Application: at expansion joints, valves, primary flow measuring elements, flanges and unions at equipment.
- .2 Design: to permit movement of expansion joint and to permit periodic removal and replacement without damage to adjacent insulation.
- .3 Insulation:
  - .1 Insulation, fastenings and finishes: same as system.

#### **3.5 INSTALLATION OF ELASTOMERIC INSULATION**

- .1 Insulation to remain dry. Overlaps to manufacturers instructions. Ensure tight joints.
- .2 Provide vapour retarder as recommended by manufacturer.

**3.6 SCOPE OF INSULATION**

- .1 Includes heating, valves, valve bonnets, strainers, flanges and fittings unless otherwise specified.
  - .1 Insulate the following systems, unless otherwise noted:
    - .1 Hot water heating and preheating supply and return piping.
    - .2 Glycol heat recovery piping.
  - .2 Do not insulate the following, unless otherwise noted:
    - .1 Drain lines.
    - .2 Relief piping
  - .3 Insulate the following valves and fittings if the pipe is insulated:
    - .1 Elbows, tees, reducers.
    - .2 Valve bodies on valves and check valves, over NPS 65 mm.
    - .3 Flanges.
    - .4 Strainers.

**3.7 PIPING INSULATION SCHEDULE**

- .1 Thickness of insulation as listed in following table.
  - .1 Run-outs to individual units and equipment not exceeding 4000 mm long.
  - .2 Do not insulate exposed runouts to plumbing fixtures, chrome plated piping, valves, fittings.

		Pipe sizes (NPS) and insulation thickness (mm)				
Application	Temp degrees C	to 1	1 1/4 to 2	2 1/2 to 4	5 to 6	8 and over
Hot Water Heating	50 - 94	25	25	38	38	38
Hot Water Heating	up to 49	25	25	25	25	25
Glycol Heating	50 - 94	25	25	38	38	38
Glycol Heating	up to 49	25	25	25	25	25
Domestic CWS	5	25	25	25	25	25

- .2 Finishes:
  - .1 Exposed indoors: canvas
  - .2 Exposed in mechanical rooms: canvas.
  - .3 Concealed, indoors: canvas on valves, fittings. No further finish.
  - .4 Use vapour retarder jacket on TIAC code A-3 insulation compatible with insulation.
  - .5 Finish attachments: SS bands, at 150 mm on centre. Seals: closed.
  - .6 Installation: to appropriate TIAC code CRF/1 through CPF/5.

**3.8 CLEANING**

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

**END OF SECTION**

**Part 1            General**

**1.1                SECTION INCLUDES**

- .1      Commissioning of mechanical systems.

**1.2                RELATED WORK**

- .1      Section 01 79 00 – Demonstration and Training

**1.3                QUALITY ASSURANCE**

- .1      The commissioning shall be executed in accordance with the intent of ASHRAE Standard 1-1996 "Guideline for Commissioning of HVAC Systems".

**1.4                GENERAL**

- .1      Be responsible for the performance and commissioning of all equipment supplied under the Sections of Division 23 and 25.
- .2      Commissioning is the process of advancing the installation from the stage of static completion to full working order in accordance with the contract documents and design intent. It is the activation of the completed installation.
- .3      In consultation with the General Contractor, ensure that sufficient time is allowed and fully identified on the construction schedule for the proper commissioning of all mechanical and process systems.

**1.5                COMMISSIONING AND DEMOSTRATION**

- .1      Provide the services of an approved independent specialist firm to coordinate the commissioning process specified under this division and those items of other Divisions which interact with work of this Division as outlined herein, including the complete life safety and fire protection system.
- .2      The cooperation of all trades is essential for an efficient and planned process. A team comprising the following is recommended:
  - .1      Commissioning Coordinator.
  - .2      General Contractor.
  - .3      Mechanical Contractor's Supervisor.
  - .4      Departmental Representative
  - .5      Division 23 and 25 Trades.
- .3      Prepare a commissioning statement for the entire project.
- .4      Regular meetings shall be held during the commissioning process. Minutes of the meetings shall be issued to all contractors involved, the Departmental Representative and the Owners representative.
- .5      Plan the work to be specific in respect of personnel, schedule, review and laboratory tests.

---

**Part 2**            **Products**

**2.1**                **NOT USED**

.1                  Not Used.

**Part 3**            **Execution**

**3.1**                **NOT USED**

.1                  Not Used.

**END OF SECTION**

**Part 1            General**

**1.1            RELATED REQUIREMENTS**

- .1    Section 01 91 13 - General Commissioning Requirements
- .2    Section 23 05 93 - Testing, Adjusting and Balancing for HVAC
- .3    Section 23 08 02 - Cleaning and Start-up

**1.2            CLEANING AND START-UP OF MECHANICAL PIPING SYSTEMS**

- .1    In accordance with Section 23 08 02 - Cleaning and Start-up of Mechanical Piping Systems.

**1.3            HYDRONIC SYSTEMS - PERFORMANCE VERIFICATION (PV)**

- .1    Perform hydronic systems performance verification after cleaning is completed and system is in full operation.
- .2    When systems are operational, perform following tests:
  - .1    Conduct full scale tests at maximum design flow rates, temperatures and pressures for continuous consecutive period of 48 hours to demonstrate compliance with design criteria.
  - .2    Verify performance of hydronic system circulating pumps as specified, recording system pressures, temperatures, fluctuations by simulating maximum design conditions and varying.
    - .1    Pump operation.
    - .2    Boiler operation.
    - .3    Pressure bypass open/closed.
    - .4    Control pressure failure.
    - .5    Maximum heating demand.
    - .6    Boiler failure.
    - .7    Outdoor reset. Re-check heat exchanger output supply temperature at 100% and 50% reset, maximum water temperature.

**1.4            HYDRONIC SYSTEM CAPACITY TEST**

- .1    Perform hydronic system capacity tests after:
  - .1    TAB has been completed
  - .2    Verification of operating, limit, safety controls.
  - .3    Verification of primary and secondary pump flow rates.
  - .4    Verification of accuracy of temperature and pressure sensors and gauges.
- .2    Calculate system capacity at test conditions.

- .3 Using manufacturer's published data and calculated capacity at test conditions, extrapolate system capacity at design conditions.
- .4 When capacity test is completed, return controls and equipment status to normal operating conditions.
- .5 Submit sample of system water to approved testing agency to determine if chemical treatment is correct. Include cost.
- .6 Heating system capacity test:
  - .1 Perform capacity test when ambient temperature is within 10% of design conditions. Simulate design conditions by:
    - .1 Increasing OA flow rates through heating coils (in this case, monitor heating coil discharge temperatures to ensure that coils are not subjected to freezing conditions) or
    - .2 Reducing space temperature by turning off heating system for sufficient period of time before starting testing.
  - .2 Test procedures:
    - .1 Open fully heat exchanger, heating coil and radiation control valves.
    - .2 With boilers on full firing and hot water heating supply temperature stabilized, record flow rates and supply and return temperatures simultaneously.
    - .3 Conduct flue gas analysis test on boilers at full load and at low fire conditions.

## **1.5 GASEOUS FUEL SYSTEMS (NATURAL GAS)**

- .1 Operation tests:
  - .1 Measure gas pressure at gas meter outlet and at burner manifold.
  - .2 Verify details of temperature and pressure compensation at meter.
  - .3 Verify settings, operation, venting of high and low pressure cut-outs, alarms.
  - .4 Check terminals of vents for gas pressure regulators.

## **1.6 REPORTS**

- .1 In accordance with Section 01 91 13 - General Commissioning (Cx) Requirements: Reports, supplemented as specified herein.

## **1.7 TRAINING**

- .1 In accordance with Section 01 91 13 - General Commissioning (Cx) Requirements: Training of O M Personnel.



---

**Part 2**            **Products**

**2.1**                **NOT USED**

.1                  Not Used.

**Part 3**            **Execution**

**3.1**                **NOT USED**

.1                  Not Used.

**END OF SECTION**

**Part 1            General**

**1.1                SUMMARY**

- .1 Section Includes:
  - .1 Procedures and cleaning solutions for cleaning mechanical piping systems.
- .2 Related Requirements
  - .1 Section 01 79 00 – Demonstration and Training
  - .2 Section 23 08 00 – Commissioning of Mechanical Systems
  - .3 Section 23 08 01 – Performance Verification Mechanical Piping Systems

**1.2                REFERENCES**

- .1 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
  - .1 Material Safety Data Sheets (MSDS).

**1.3                ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Product Data:
  - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.

**1.4                DELIVERY, STORAGE, AND HANDLING**

- .1 Packing, shipping, handling and unloading:
  - .1 Deliver, store and handle in accordance with manufacturer's written instructions.
- .2 Waste Management and Disposal:
  - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**Part 2            Products**

**2.1                CLEANING SOLUTIONS**

- .1 Tri-sodium phosphate: 0.40 kg per 100 L water in system.
- .2 Sodium carbonate: 0.40 kg per 100 L water in system.
- .3 Low-foaming detergent: 0.01 kg per 100 L water in system.

---

**Part 3 Execution**

**3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

**3.2 CLEANING HYDRONIC SYSTEMS**

- .1 Timing: systems operational, hydrostatically tested and with safety devices functional, before cleaning is carried out.
- .2 Cleaning Agency:
  - .1 Retain qualified water treatment specialist to perform system cleaning.
- .3 Install instrumentation such as flow meters, orifice plates, pitot tubes, flow metering valves only after cleaning is certified as complete by water treatment specialist.
- .4 Cleaning procedures:
  - .1 Provide detailed report outlining proposed cleaning procedures at least 4 weeks prior to proposed starting date. Report to include:
    - .1 Cleaning procedures, flow rates, elapsed time.
    - .2 Chemicals and concentrations used.
    - .3 Inhibitors and concentrations.
    - .4 Specific requirements for completion of work.
    - .5 Special precautions for protecting piping system materials and components.
    - .6 Complete analysis of water used to ensure water will not damage systems or equipment.
- .5 Conditions at time of cleaning of systems:
  - .1 Systems: free from construction debris, dirt and other foreign material.
  - .2 Control valves: operational, fully open to ensure that terminal units can be cleaned properly.
  - .3 Strainers: clean prior to initial fill.
  - .4 Install temporary filters on pumps not equipped with permanent filters.
  - .5 Install pressure gauges on strainers to detect plugging.
- .6 Report on Completion of Cleaning:
  - .1 When cleaning is completed, submit report, complete with certificate of compliance with specifications of cleaning component supplier.
- .7 Hydronic Systems:
  - .1 Fill system with water, ensure air is vented from system.

- .2 Fill expansion tanks 1/3 to 1/2 full, charge system with compressed air to at least 35 kPa (does not apply to diaphragm type expansion tanks).
- .3 Use water metre to record volume of water in system to +/- 0.5%.
- .4 Add chemicals under direct supervision of chemical treatment supplier.
- .5 Closed loop systems: circulate system cleaner at 60 degrees C for at least 36 h. Drain as quickly as possible. Refill with water and inhibitors. Test concentrations and adjust to recommended levels.
- .6 Flush velocity in system mains and branches to ensure removal of debris. System pumps may be used for circulating cleaning solution provided that velocities are adequate.
- .7 Add chemical solution to system.
- .8 Establish circulation, raise temperature slowly to [maximum design] [82 degrees C minimum]. Circulate for 12 h, ensuring flow in all circuits. Remove heat, continue to circulate until temperature is below 38 degrees C. Drain as quickly as possible. Refill with clean water. Circulate for 6 h at design temperature. Drain and repeat procedures specified above. Flush through low point drains in system. Refill with clean water adding to sodium sulphite (test for residual sulphite).

### 3.3 START-UP OF HYDRONIC SYSTEMS

- .1 After cleaning is completed and system is filled:
  - .1 Establish circulation and expansion tank level, set pressure controls.
  - .2 Ensure air is removed.
  - .3 Check pumps to be free from air, debris, possibility of cavitation when system is at design temperature.
  - .4 Dismantle system pumps used for cleaning, inspect, replace worn parts, install new gaskets and new set of seals.
  - .5 Clean out strainers repeatedly until system is clean.
  - .6 Commission water treatment systems as specified in Section 23 25 00 - HVAC Water Treatment Systems.
  - .7 Check water level in expansion tank with cold water with circulating pumps OFF and again with pumps ON.
  - .8 Repeat with water at design temperature.
  - .9 Check pressurization to ensure proper operation and to prevent water hammer, flashing, cavitation. Eliminate water hammer and other noises.
  - .10 Bring system up to design temperature and pressure slowly.
  - .11 Perform TAB as specified in Section 23 05 93 - Testing, Adjusting and Balancing for HVAC.
  - .12 Adjust pipe supports, hangers, and springs as necessary.
  - .13 Monitor pipe movement, performance of expansion joints, loops, guides, anchors.

- .14 If sliding type expansion joints bind or if bellows type expansion joints flex incorrectly, shut down system, re-align, and repeat start-up procedures.
- .15 Re-tighten bolts using torque wrench, to compensate for heat-caused relaxation. Repeat several times during commissioning.
- .16 Check operation of drain valves.
- .17 Adjust valve stem packings as systems settle down.
- .18 Fully open balancing valves (except those that are factory-set).
- .19 Check operation of over-temperature protection devices on circulating pumps.
- .20 Adjust alignment of piping at pumps to ensure flexibility, adequacy of pipe movement, absence of noise or vibration transmission.

### **3.4 CLEANING**

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

**END OF SECTION**

**Part 1            General**

**1.1                SUMMARY**

- .1 Section Includes:
  - .1 Materials and installation for piping, valves and fittings for gas fired equipment.
- .2 Related Requirements
  - .1 Section 01 33 00 - Submittal Procedures
  - .2 Section 01 74 11 - Cleaning
  - .3 Section 01 74 21 - Construction/Demolition Waste Management and Disposal
  - .4 Section 01 78 00 - Closeout Submittals
  - .5 Section 23 05 05 - Installation of Pipework
  - .6 Section 23 08 01 - Performance Verification
  - .7 Section 23 08 02 - Cleaning and Start-Up

**1.2                REFERENCES**

- .1 American Society of Mechanical Engineers (ASME)
  - .1 ASME B16.5-03, Pipe Flanges and Flanged Fittings.
  - .2 ASME B16.18-01 (R2005), Cast Copper Alloy Solder Joint Pressure Fittings.
  - .3 ASME B16.22-01 (R2005), Wrought Copper and Copper Alloy Solder-Joint Pressure Fittings.
  - .4 ASME B18.2.1-96 (R2005), Square and Hex Bolts and Screws Inch Series.
- .2 American Society for Testing and Materials International (ASTM)
  - .1 ASTM A47/A47M-99(2004), Standard Specification for Ferritic Malleable Iron Castings.
  - .2 ASTM A53/A53M-04, Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc Coated, Welded and Seamless.
  - .3 ASTM B837-01, Standard Specification for Seamless Copper Tube for Natural Gas and Liquefied Petroleum (LP) Gas Fuel Distribution Systems.
- .3 Canadian Standards Association (CSA International)
  - .1 CSA W47.1-03, Certification of Companies for Fusion Welding of Steel.
- .4 Canadian Standards Association (CSA)/Canadian Gas Association (CGA)
  - .1 CAN/CSA B149.1HB-00, Natural Gas and Propane Installation Code Handbook.

**1.3                ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Shop drawings:

- .1 Submit manufacturer's printed product literature, specifications and datasheet for piping, fittings and equipment.
- .2 Indicate the following shop drawings:
  - .1 Valves.
  - .2 Pressure reducing valves
- .3 Test Reports: submit certified test reports from approved independent testing laboratories indicating compliance with specifications for specified performance characteristics and physical properties.
- .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .5 Instructions: submit manufacturer's installation instructions.
- .6 Closeout Submittals: submit maintenance and engineering data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

#### **1.4 DELIVERY, STORAGE AND HANDLING**

- .1 Waste Management and Disposal:
  - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

### **Part 2 Products**

#### **2.1 PIPE**

- .1 Steel pipe: to ASTM A53/A53M, Schedule 40, seamless as follows:
  - .1 NPS 1/2 to 2, screwed.
  - .2 NPS2 1/2 and over, plain end.
- .2 Copper tube: to ASTM B837.

#### **2.2 JOINTING MATERIAL**

- .1 Screwed fittings: pulverized lead paste.
- .2 Welded fittings: to CSA W47.1.
- .3 Flange gaskets: nonmetallic flat.
- .4 Brazing: to ASTM B837.

#### **2.3 FITTINGS**

- .1 Steel pipe fittings, screwed, flanged or welded:
  - .1 Malleable iron: screwed, banded, Class 150.
  - .2 Steel pipe flanges and flanged fittings: to ASME B16.5.
  - .3 Welding: butt-welding fittings.
  - .4 Unions: malleable iron, brass to iron, ground seat, to ASTM A47/A47M.

- .5 Bolts and nuts: to ASME B18.2.1.
- .6 Nipples: schedule 40, to ASTM A53/A53M.
- .2 Copper pipe fittings, screwed, flanged or soldered:
  - .1 Cast copper fittings: to ASME B16.18.
  - .2 Wrought copper fittings: to ASME B16.22.

## **2.4 VALVES**

- .1 Provincial Code approved, lubricated plug type.
- .2 NPS 2 and under, screwed.
- .3 NPS 2-1/2 and over, flanged.
- .4 Suitable for the temperature to which exposed.
- .5 Certified by Canadian Gas Association (CGA).

## **Part 3 Execution**

### **3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

### **3.2 PIPING**

- .1 Install in accordance with Section 23 05 05 - Installation of Pipework, and CAN/CSA B149.1.

### **3.3 VALVES**

- .1 Install valves with stems upright or horizontal unless otherwise approved by Departmental Representative.
- .2 Install valves at branch take-offs to isolate pieces of equipment, and as indicated.

### **3.4 FIELD QUALITY CONTROL**

- .1 Site Tests/Inspection:
  - .1 Test system in accordance with CAN/CSA B149.1 and requirements of authorities having jurisdiction.
- .2 Notify the Departmental Representative and the Inspection Authority having jurisdiction, 48 hours in advance of intended test date.
- .3 Examine piping for leaks. Remake all leaking connections and joints.
- .4 Obtain reports within 3 days of review and submit immediately Departmental Representative.
- .5 Performance Verification:



- .1 Refer to Section 23 08 01 - Performance Verification of Mechanical Piping Systems.

### **3.5 ADJUSTING**

- .1 Purging: purge after pressure test in accordance with CAN/CSA B149.1.
- .2 Pre-Start-Up Inspections:
  - .1 Check vents from regulators, control valves, terminate outside building in approved location, protected against blockage, damage.
  - .2 Check gas trains, entire installation is approved by authority having jurisdiction.

### **3.6 CLEANING**

- .1 Cleaning: in accordance with Section 23 08 02 - Cleaning and Start-Up of Mechanical Piping Systems and CAN/CSA B149.1, supplemented as specified.
- .2 Perform cleaning operations as specified in Section 01 74 11 and in accordance with manufacturer's recommendations.
- .3 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

**END OF SECTION**

**Part 1            General**

**1.1                RELATED REQUIREMENTS**

- .1    Section 01 33 00 - Submittal Procedures
- .2    Section 01 74 11 - Cleaning
- .3    Section 01 74 21 - Construction/Demolition Waste Management and Disposal
- .4    Section 01 78 00 - Closeout Submittals
- .5    Section 23 05 00 - Common Work Results - for Mechanical
- .6    Section 23 08 02 – Cleaning and Start-Up

**1.2                REFERENCES**

- .1    American National Standards Institute/American Water Works Association (ANSI/AWWA)
  - .1    ANSI/AWWA C111/A21.11-06, Standard for Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings.
- .2    American Society of Mechanical Engineers (ASME)
  - .1    ASME B16.1-10, Grey Iron Pipe Flanges and Flanged Fittings: Classes 25, 125, and 250.
  - .2    ASME B16.3-06, Malleable Iron Threaded Fittings: Classes 150 and 300.
  - .3    ASME B16.5-09, Pipe Flanges and Flanged Fittings: NPS through NPS 24 Metric/Inch Standard.
  - .4    ASME B16.9-07, Factory-Made Wrought Butt welding Fittings.
  - .5    ASME B18.2.1-10, Square Hex, Heavy Hex and Askew Head Bolts and Hex, Heavy Hex, Hex Flange. Loded Head and Lag Screws (Inch Series).
  - .6    ASME B18.2.2-10, Nuts for General Applications: Machine Screw Nuts, Hex, Square, Hex Flange, and Coupling Nuts (Inch Series).
- .3    ASTM International
  - .1    ASTM A47/A47M-99(2009), Standard Specification for Ferritic Malleable Iron Castings.
  - .2    ASTM A53/A53M-10, Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc Coated Welded and Seamless.
  - .3    ASTM A536-84(2009), Standard Specification for Ductile Iron Castings.
  - .4    ASTM B61-08, Standard Specification for Steam or Valve Bronze Castings.
  - .5    ASTM B62-09, Standard Specification for Composition Bronze or Ounce Metal Castings.
  - .6    ASTM E202-10, Standard Test Method for Analysis of Ethylene Glycols and Propylene Glycols.

- .4 CSA International
  - .1 CSA B242-05(R2011), Groove and Shoulder Type Mechanical Pipe Couplings.
  - .2 CSA W48-06, Filler Metals and Allied Materials for Metal Arc Welding.
- .5 Manufacturer's Standardization of the Valve and Fittings Industry (MSS)
  - .1 MSS-SP-67-2002a, Butterfly Valves.
  - .2 MSS-SP-70-06, Gray Iron Gate Valves, Flanged and Threaded Ends.
  - .3 MSS-SP-71-05, Gray Iron Swing Check Valves Flanged and Threaded Ends.
  - .4 MSS-SP-80-08, Bronze Gate, Globe, Angle and Check Valves.
  - .5 MSS-SP-85-02, Gray Iron Globe and Angle Valves, Flanged and Threaded Ends.

### **1.3 ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Shop Drawings:
  - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of British Columbia, Canada.
  - .2 Indicate on drawings:
    - .1 Manufacturers literature for piping and fittings.

### **1.4 DELIVERY, STORAGE AND HANDLING**

- .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.

## **Part 2 Products**

### **2.1 PIPE**

- .1 Steel pipe: to ASTM A53/A53M, Grade B, as follows:
- .2 Steel Pipe:
  - .1 Schedule 40 to ASTM A53 Grade B for the following systems:
  - .2 Hot water heating
  - .3 Relief valve vents

### **2.2 PIPE JOINTS**

- .1 NPS 2 and under: screwed fittings with PTFE tape.
- .2 NPS 2-1/2 and over: welding fittings and flanges to CSA W48.
- .3 Flanges: raised face, weld neck to ANSI/AWWA C111/ A21.11.
- .4 Orifice flanges: slip-on raised face, 2100 kPa.

- .5 Flange gaskets: to ANSI/AWWA C111/ A21.11.
- .6 Pipe thread: taper.
- .7 Bolts and nuts: to ASME B18.2.1 and ASME B18.2.2.

### 2.3 FITTINGS

- .1 Screwed fittings: malleable iron, to ASME B16.3, Class 150.
- .2 Pipe flanges and flanged fittings:
  - .1 Cast iron: to ASME B16.1, Class 125.
  - .2 Steel: to ASME B16.5.
- .3 Butt-welding fittings: steel, to ASME B16.9.
- .4 Unions: malleable iron, to ASTM A47/A47M and ASME B16.3.

### 2.4 VALVES

- .1 Connections:
  - .1 NPS 2 and smaller: screwed ends.
  - .2 NPS 2-1/2 and larger: flanged ends.
- .2 Butterfly valves: to MSS-SP-67
  - .1 NPS 2-1/2 and over: lug type:
- .3 Globe valves: to application: throttling, flow control, emergency bypass MSS-SP- 80:
  - .1 NPS 2 and under:
    - .1 Mechanical Rooms: with PTFE disc, as specified Section 23 05 23.01 - Valves - Bronze.
    - .2 NPS 2-1/2 and over:
      - .1 With lead free bronze disc, bronze trim, as specified Section 23 05 23.02 - Valves - Cast Iron.
- .4 Balancing, for TAB:
  - .1 Sizes: calibrated balancing valves, as specified this section.
  - .2 NPS 2 and under:
    - .1 Mechanical Rooms: globe, with plug disc as specified Section 23 05 23.01 - Valves - Bronze.
- .5 Swing check valves: to MSS-SP-71.
  - .1 NPS 2 and under:
    - .1 Class 125, swing, with disc, as specified Section 23 05 23.01 - Valves - Bronze.
  - .2 NPS 2-1/2 and over:
    - .1 Flanged ends: as specified Section 23 05 23.02 - Valves - Cast Iron.
- .6 Ball valves:

- .1 NPS 2 and under: as specified Section 23 05 23.01 - Valves - Bronze.

### **Part 3 Execution**

#### **3.1 EXAMINATION**

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for hydronic systems installation in accordance with manufacturer's written instructions.
  - .1 Visually inspect substrate in presence of DFO Representative.
  - .2 Inform DFO Representative of unacceptable conditions immediately upon discovery.
  - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed DFO Representative.

#### **3.2 PIPING INSTALLATION**

- .1 Install pipework in accordance with Section 23 05 05 - Installation of Pipe Work.

#### **3.3 CIRCUIT BALANCING VALVES**

- .1 Install flow measuring stations and flow balancing valves as indicated.
- .2 Remove handwheel after installation and when TAB is complete.
- .3 Tape joints in prefabricated insulation on valves installed in chilled water mains.

#### **3.4 CLEANING, FLUSHING AND START-UP**

- .1 In accordance with Section 23 08 02 - Cleaning and Start-Up of Mechanical Piping Systems.

#### **3.5 TESTING**

- .1 Test system in accordance with Section 21 05 01 - Common Work Results for Mechanical.

#### **3.6 BALANCING**

- .1 Balance water systems to within plus or minus 5 % of design output.
- .2 In accordance with Section 23 05 93 - Testing, Adjusting and Balancing for HVAC for applicable procedures.

#### **3.7 GLYCOL CHARGING**

- .1 Include mixing tank and positive displacement pump for glycol charging.
- .2 Retest for concentration to ASTM E202 after cleaning.

---

**3.8 PERFORMANCE VERIFICATION**

- .1 In accordance with Section 23 08 01 - Performance Verification Mechanical Piping Systems.

**3.9 CLEANING**

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
  - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal
  - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

**3.10 PROTECTION**

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by hydronic systems installation.

**END OF SECTION**

**Part 1            General**

**1.1                SUMMARY**

- .1    Section Includes:
  - .1        Materials and installation of Hydronic Specialties Equipment.

**1.2                RELATED REQUIREMENTS**

- .1    Section 01 33 00 - Submittal Procedures
- .2    Section 01 74 21 - Construction/Demolition Waste Management and Disposal
- .3    Section 01 78 00 - Closeout Submittals
- .4    Section 23 08 01 - Performance Verification

**1.3                REFERENCES**

- .1    ASME
  - .1        ASME Boiler and Pressure Vessel.
- .2    ASTM International
  - .1        ASTM A47/A47M-99(2009), Standard Specification for Ferritic Malleable Iron Castings.
  - .2        ASTM A278/A278M-01(2011), Standard Specification for Gray Iron Castings for Pressure-Containing Parts for Temperatures up to 650 degrees F (350 degrees C).
  - .3        ASTM A516/A516M-10, Standard Specification for Pressure Vessel Plates, Carbon Steel, for Moderate - and Lower - Temperature Service.
  - .4        ASTM A536-84(2009), Standard Specification for Ductile Iron Castings.
  - .5        ASTM B62-09], Standard Specification for Composition Bronze or Ounce Metal Castings.
- .3    CSA Group
  - .1        CSA B51-09, Boiler, Pressure Vessel, and Pressure Piping Code.

**1.4                ACTION AND INFORMATIONAL SUBMITTALS**

- .1    Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2    Product Data:
  - .1        Submit manufacturer's instructions, printed product literature and data sheets for:
    - .1            Expansion tanks
    - .2            Air vents
    - .3            Air separators,

- .4 Valves
- .5 Strainers
- .6 Suction diffusers
- .7 Pressure reducing valves and relief valves
- .3 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .4 Operation and Maintenance Data: submit operation and maintenance data for hydronic specialties for incorporation into manual.

## **1.5 DELIVERY, STORAGE AND HANDLING**

- .1 Deliver, store and handle materials in accordance manufacturer's written instructions.
- .2 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

## **Part 2 Products**

### **2.1 DIAPHRAGM TYPE EXPANSION TANK**

- .1 Vertical steel pressurized diaphragm type expansion tank.
- .2 Diaphragm sealed in EPDM suitable for 115 degrees C operating temperature.
- .3 Working pressure: 860 kPa with ASME stamp and certification.
- .4 Supports: provide supports with hold down bolts and installation templates incorporating seismic restraint systems.

### **2.2 AUTOMATIC AIR VENT**

- .1 Standard float vent: brass body and NPS 1/8 connection and rated at 690 kPa working pressure.
- .2 Float: solid material suitable for 115 degrees C working temperature.

### **2.3 AIR SEPARATOR - EXPANSION TANK FITTING**

- .1 Complete with adjustable vent tube and built-in manual vent valve.
- .2 Working pressure: 860 kPa.

### **2.4 AIR SEPARATOR - IN-LINE**

- .1 Working pressure: 860 kPa.
- .2 Size: as indicated.

### **2.5 COMBINATION SEPARATORS/STRAINERS**

- .1 Steel, tested and stamped in accordance with ASME BPVC, for 860 kPa operating pressure, with galvanized steel integral strainer with 5 mm perforations, tangential inlet and outlet connections, and internal stainless steel air collector tube.



## **2.6 PIPE LINE STRAINER**

- .1 NPS 1/2 to 2: bronze body to ASTM B62, screwed connections, Y pattern.
- .2 NPS 2 1/2 to 12: cast steel body to ASTM, class 30, flanged connections.
- .3 NPS 2 to 12: Y or T type with ductile iron body to ASTM A536 or malleable iron body to ASTM A47M, grooved ends.
- .4 Blowdown connection: NPS 1.
- .5 Screen: stainless steel or brass with 1.19 mm perforations.
- .6 Working pressure: 860 kPa.

## **2.7 SUCTION DIFFUSER**

- .1 Body: cast iron with flanged connections.
- .2 Strainer: with built-in, disposable 1.19mm mesh, low pressure drop screen and NPS 1 blowdown connection.
- .3 Permanent magnet particle trap.
- .4 Full length straightening vanes.
- .5 Pressure gauge tappings.
- .6 Adjustable support leg.

## **Part 3 Execution**

### **3.1 APPLICATION**

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and data sheets.

### **3.2 GENERAL**

- .1 Run drain lines and blow off connections to terminate above nearest drain.
- .2 Maintain adequate clearance to permit service and maintenance.
- .3 Should deviations beyond allowable clearances arise, request and Departmental Representative's directive.
- .4 Check shop drawings for conformance of tappings for ancillaries and for equipment operating weights.

### **3.3 STRAINERS**

- .1 Install in horizontal or down flow lines.
- .2 Ensure clearance for removal of basket.
- .3 Install ahead of each pump.

- .4 Install ahead of each automatic control valve larger than NPS and as indicated.

### **3.4 AIR VENTS**

- .1 Install at high points of systems.
- .2 Install gate valve on automatic air vent inlet. Run discharge to nearest drain.

### **3.5 EXPANSION TANKS**

- .1 Adjust expansion tank pressure to suit design criteria.
- .2 Install lockshield type valve at inlet to tank.

### **3.6 PRESSURE SAFETY RELIEF VALVES**

- .1 Run discharge pipe to terminate above nearest drain.

### **3.7 SUCTION DIFFUSERS**

- .1 Install on inlet to pumps having suction size greater than 50.

### **3.8 CLEANING**

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
  - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse or recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**END OF SECTION**

**Part 1            General**

**1.1                RELATED REQUIREMENTS**

- .1    Section 01 33 00 - Submittal Procedures
- .2    Section 01 74 21 - Construction/Demolition Waste Management and Disposal
- .3    Section 01 78 00 - Closeout Submittals
- .4    Section 23 08 01 - Performance Verification

**1.2                REFERENCES**

- .1    American Society of Heating Refrigeration and Air-Conditioning Engineers (ASHRAE)
  - .1    ANSI/ASHRAE/IES Standard 90.1-2010, Energy Standard for Buildings Except Low-Rise Residential Buildings.
- .2    CSA Group
  - .1    CAN/CSA-B214-12, Installation Code for Hydronic Heating Systems.
- .3    Electrical Equipment Manufacturers Association of Canada (EEMAC)
- .4    National Electrical Manufacturers' Association (NEMA)
  - .1    NEMA MG 1-2011, Motors and Generators.

**1.3                ACTION AND INFORMATIONAL SUBMITTALS**

- .1    Submit in accordance with Section 01 33 00 - Submittal Procedures.
  - .1    Submit drawings stamped and signed by professional engineer registered or licensed in Province of British Columbia, Canada.
  - .2    Indicate the following:
    - .1    Manufacturers detailed composite wiring diagrams for control systems.
    - .2    Equipment electrical drawings.
    - .3    Factory installed wiring and equipment on packaged equipment or required for controlling devices or ancillaries, accessories and controllers.
    - .4    Piping hook-ups.
    - .5    Performance Curves.
    - .6    Equipment weight and anchor bolt arrangement.
    - .7

**1.4                CLOSEOUT SUBMITTALS**

- .1    Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2    Operation and Maintenance Data: submit operation and maintenance data for hydronic pumps for incorporation into manual.

**1.5 DELIVERY, STORAGE AND HANDLING**

- .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
  - .1 Store materials off ground, indoors and in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
  - .2 Store and protect hydronic pumps from nicks, scratches, and blemishes.
  - .3 Replace defective or damaged materials with new.
- .4 Waste Management and Disposal:
  - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**Part 2 Products**

**2.1 EQUIPMENT**

- .1 Size and select components to: CAN/CSA-B214.

**2.2 IN-LINE CIRCULATORS**

- .1 Volute: cast iron radially split, with screwed or flanged design suction and discharge connections.
- .2 Impeller: stainless steel.
- .3 Shaft: stainless steel with bronze sleeve bearing, integral thrust collar.
- .4 Seal assembly: mechanical for service to 135 degrees C.
- .5 Coupling: flexible self-aligning.
- .6 Motor: to NEMA MG 1
- .7 Capacity: as indicated.
- .8 Design pressure: 860 kPa.

**Part 3 Execution**

**3.1 EXAMINATION**

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for hydronic pump installation in accordance with manufacturer's written instructions.
  - .1 Visually inspect substrate in presence of Departmental Representative.

- .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
- .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

### **3.2 APPLICATION**

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and data sheets.

### **3.3 INSTALLATION**

- .1 Install hydronic pumps to: CAN/CSA-B214.
- .2 In line circulators: install as indicated by flow arrows.
  - .1 Support at inlet and outlet flanges or unions.
  - .2 Install with bearing lubrication points accessible.
- .3 Base mounted type: supply templates for anchor bolt placement.
  - .1 Include anchor bolts with sleeves. Place level, shim unit and grout.
  - .2 Align coupling in accordance with manufacturer's recommended tolerance.
  - .3 Check oil level and lubricate. After run-in, tighten glands.
- .4 Ensure that pump body does not support piping or equipment.
  - .1 Provide stanchions or hangers for this purpose.
  - .2 Refer to manufacturer's installation instructions for details.
- .5 Pipe drain tapping to floor drain.
- .6 Install volute venting pet cock in accessible location.
- .7 Check rotation prior to start-up.
- .8 Install pressure gauge test cocks.

### **3.4 START-UP**

- .1 General:
  - .1 In accordance with Section 01 91 13 - General Commissioning (Cx) Requirements: General Requirements; supplemented as specified herein.
  - .2 In accordance with manufacturer's recommendations.
- .2 Procedures:
  - .1 Before starting pump, check that cooling water system over-temperature and other protective devices are installed and operative.
  - .2 After starting pump, check for proper, safe operation.
  - .3 Check installation, operation of mechanical seals, packing gland type seals. Adjust as necessary.

- .4 Check base for free-floating, no obstructions under base.
- .5 Run-in pumps for 12 continuous hours minimum.
- .6 Verify operation of over-temperature and other protective devices under low- and no-flow condition.
- .7 Eliminate air from scroll casing.
- .8 Adjust water flow rate through water-cooled bearings.
- .9 Adjust flow rate from pump shaft stuffing boxes to manufacturer's recommendation.
- .10 Adjust alignment of piping and conduit to ensure true flexibility.
- .11 Eliminate cavitation, flashing and air entrainment.
- .12 Adjust pump shaft seals, stuffing boxes, glands.
- .13 Measure pressure drop across strainer when clean and with flow rates as finally set.
- .14 Replace seals if pump used to degrease system or if pump used for temporary heat.
- .15 Verify lubricating oil levels.

### **3.5 PERFORMANCE VERIFICATION (PV)**

- .1 General:
  - .1 Verify performance in accordance with Section 01 91 13 - General Commissioning (Cx) Requirements: General Requirements, supplemented as specified herein.
- .2 Verify that manufacturer's performance curves are accurate.
- .3 Ensure valves on pump suction and discharge provide tight shut-off.
- .4 Net Positive Suction Head (NPSH):
  - .1 Application: measure NPSH for pumps which operate on open systems and with water at elevated temperatures.
  - .2 Measure using procedures prescribed in Section 01 91 13 - General Commissioning (Cx) Requirements.
  - .3 Where procedures do not exist, discontinue PV, report to Departmental Representative and await instructions.
- .5 Multiple Pump Installations - Series and Parallel:
  - .1 Repeat PV procedures specified above for pump performance and pump BHP for combinations of pump operations.
- .6 Mark points of design and actual performance at design conditions as finally set upon completion of TAB.
- .7 Commissioning Reports: in accordance with Section 01 91 13 - General Commissioning (Cx) Requirements reports supplemented as specified herein. Reports to include:

- .1 Record of points of actual performance at maximum and minimum conditions and for single and parallel operation as finally set at completion of commissioning on pump curves.
- .2 Use Report Forms specified in Section 01 91 13 - General Commissioning (Cx) Requirements: Report Forms and Schematics.
- .3 Pump performance curves (family of curves).

### **3.6 CLEANING**

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
  - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
  - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

**END OF SECTION**

**Part 1            General**

**1.1                RELATED REQUIREMENTS**

- .1        Section 01 33 00 - Submittal Procedures
- .2        Section 01 74 21 - Construction/Demolition Waste Management and Disposal

**1.2                REFERENCES**

- .1        Sheet Metal and Air Conditioning Contractors National Association (SMACNA)
- .2        Underwriters' Laboratories of Canada (ULC)
- .3        Canadian Gas Association (CGA)
  - .1        CAN1-3.1-77 (R2006), Industrial and Commercial Gas-Fired Packaged Boilers.
  - .2        CAN/CSA-B149.1-05, Natural Gas and Propane Installation Code.

**1.3                ACTION AND INFORMATIONAL SUBMITTALS**

- .1        Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2        Product Data:
  - .1        Submit manufacturer's instructions, printed product literature and data sheets for chimneys and stacks and include product characteristics, performance criteria, physical size, finish and limitations.
- .3        Shop Drawings:
  - .1        Submit drawings stamped and signed by professional engineer registered or licensed in Province of British Columbia, Canada.
  - .2        Indicate following:
    - .1        Methods of sealing sections.
    - .2        Methods of expansion.
    - .3        Details of thimbles.
    - .4        Bases/Foundations.
    - .5        Supports.
    - .6        Guy details.
    - .7        Rain caps.
- .4        Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

**1.4                QUALITY ASSURANCE**

- .1        Regulatory Requirements: work to be performed in compliance with applicable Provincial/Territorial regulations.
- .2        Certifications:



- .1 Catalogued or published ratings: obtained from tests carried out by independent testing agency or manufacturer signifying adherence to codes and standards.

## **1.5 DELIVERY, STORAGE AND HANDLING**

- .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.

## **Part 2 Products**

### **2.1 FUELS: PRESSURE CHIMNEY AND BREECHING**

- .1 ULC labelled, 760 degrees C rated.
- .2 Sectional, prefabricated, double wall with air space with mated fittings and couplings.
  - .1 Outer seals between sections: to suit application.
  - .2 Inner seals between sections: to suit application.

### **2.2 ACCESSORIES**

- .1 Cleanouts: bolted, gasketed type, full size of breeching, as indicated.
- .2 Barometric dampers: single acting, 70% of full size of breeching area.
- .3 Hangers and supports: in accordance with recommendations SMACNA.
- .4 Rain cap.
- .5 Expansion sleeves with heat resistant caulking, held in place as indicated.

## **Part 3 Execution**

### **3.1 EXAMINATION**

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for chimney and stack installation in accordance with manufacturer's written instructions.
  - .1 Visually inspect substrate in presence of the Departmental Representative.
  - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
  - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed Departmental Representative.

---

**3.2           INSTALLATION - GENERAL**

- .1       Follow manufacturer's and SMACNA installation recommendations for shop fabricated components.
- .2       Suspend breeching at 1.5 m centres and at each joint.
- .3       Support chimneys at bottom, roof and intermediate levels as indicated.
- .4       Install thimbles where penetrating roof, floor, ceiling and where breeching enters masonry chimney. Pack annular space with heat resistant caulking.
- .5       Install flashings on chimneys penetrating roofs, as indicated.
- .6       Install rain caps and cleanouts, as indicated.

**3.3           CLEANING**

- .1       Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
  - .1       Leave Work area clean at end of each day.
- .2       Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3       Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
  - .1       Remove recycling containers and bins from site and dispose of materials at appropriate facility.

**END OF SECTION**

**Part 1            General**

**1.1                RELATED REQUIREMENTS**

- .1      Section 01 33 00 - Submittal Procedures
- .2      Section 01 74 21 - Construction/Demolition Waste Management and Disposal
- .3      Section 23 05 48 - Vibration and Seismic Controls
- .4      Section 23 51 00 – Breeching, Chimneys and Stacks

**1.2                REFERENCES**

- .1      American Boiler Manufacturers Association (ABMA)
- .2      American National Standards Institute (ANSI)
  - .1      ANSI Z21.13-2005/CSA 4.9a-2005, Gas-Fired Low-Pressure Steam and Hot Water Boilers.
- .3      ASME
  - .1      ASME Boiler and Pressure Vessel Code (BPVC), Section VII-2013.
- .4      CSA Group
  - .1      CAN1-3.1-77(R2011), Industrial and Commercial Gas-Fired Package Boilers.
  - .2      CSA B51-09, Boiler, Pressure Vessel, and Pressure Piping Code.
  - .3      CSA B149.1-10, Natural Gas and Propane Installation Code.
  - .4      ANSI Z21.13-10/CSA 4.9-10, Gas-Fired Low-Pressure Steam and Hot Water Boilers.
- .5      Electrical and Electronic Manufacturers Association of Canada (EEMAC)

**1.3                ACTION AND INFORMATIONAL SUBMITTALS**

- .1      Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2      Shop Drawings:
  - .1      Submit drawings stamped and signed by professional engineer registered or licensed in Province of British Columbia, Canada.
  - .2      Indicate the following:
    - .1      General arrangement showing terminal points, instrumentation test connections.
    - .2      Clearances for operation, maintenance, servicing, tube cleaning, tube replacement.
    - .3      Foundations with loadings, anchor bolt arrangements.
    - .4      Piping hook-ups.
    - .5      Equipment electrical drawings.
    - .6      Burners and controls.

- .7 All miscellaneous equipment.
- .8 Flame safety control system.
- .9 Breeching and stack configuration.
- .10 Stack emission continuous monitoring system to measure CO, O, NOx, SO, stack temperature and smoke density of flue gases.
- .3 Engineering data to include:
  - .1 Boiler efficiency at 25%, 50%, 75%, 100%, of design capacity.
- .3 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

#### **1.4 CLOSEOUT SUBMITTALS**

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for heating boilers for incorporation into manual.

#### **1.5 QUALITY ASSURANCE**

- .1 Regulatory Requirements: work to be performed in compliance with CEPA, CEAA, TDGA, and applicable Provincial regulations.

#### **1.6 MAINTENANCE MATERIAL SUBMITTALS**

- .1 Extra materials:
  - .1 Submit maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.
    - .1 Special tools for burners, access opening, handholes and Operation and Maintenance.
    - .2 Spare parts for 1 year of operation.
    - .3 Spare gaskets.
    - .4 Spare gauge glass inserts.
    - .5 Probes and sealants for electronic indication.
    - .6 Spare burner tips.
    - .7 Spare burner gun.
    - .8 Safety valve test gauge.

#### **1.7 DELIVERY, STORAGE AND HANDLING**

- .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.

---

**Part 2            Products**

**2.1                GENERAL**

- .1    Packaged boiler:
  - .1    Complete with burner and necessary accessories and Controls, and ready for attachment of water supply, return and drain Piping, fuel piping, electrical connections, and chimney connection. UL/ULC labelled.
  - .2    Designed and constructed in accordance with ASME Code requirements.
  - .3    CRN (Canadian Registration Number), to CSA B51.
  - .4    Boiler/burner package to bear ULC or CGA label.
  - .5    ANSI Z21.13 Certified.
  - .6    Electrical components CSA approved.
  - .7    Approved by Gas Safety Authority
  - .8    Boilers to be test fired before shipment and to be registered with the Provincial Authorities.
  - .9    Include erection and wiring diagrams and an operating and maintenance manual with boiler package.
  - .10   Check all available drawings and ensure that the boiler proposed will fit in the space allotted and can be maintained and operated in a normal manner without difficulty.
  - .11   Zero clearance to combustibles
  
- .2    Performance:
  - .1    In accordance with American Boiler Manufacturers Association (ABMA).
  - .2    Capacity: Refer to equipment schedules.
  - .3    Boiler efficiency: 99 % minimum, at 4% to 97 % efficiency at 100% firing rates.
  - .4    Flue gas temperature leaving boiler:
    - .1    Not to exceed 260 degrees C.
    - .2    Above dew point conditions at minimum firing rate.
  - .5    Maximum working pressure: 160 PSI
  
- .3    Electrical:
  - .1    Power: 120 V, 1 phase, 60 Hz.
  - .2    Controls: 120 V, 1 phase, 60 Hz.
  - .3    Electrical components: CSA approved.
  
- .4    Controls: factory wired. Enclosed in EEMAC 1 steel cabinet.
  
- .5    Thermal insulation:
  - .1    50 mm thick mineral fibre. Seal insulation at handholes, access opening, mudholes, piping connections with insulating cement or asphaltic paint. Finish with heat resisting paint.

- .6 Jackets: heavy gauge metal, finished with heat resisting paint.
- .7 Mounting:
  - .1 Structural steel base, lifting lugs.
- .8 Anchor bolts and templates:
  - .1 Supply for installation by other Divisions. Anchor bolts to be sized to Section 23 05 48 - Vibration and Seismic Controls for HVAC Piping and Equipment.
- .9 Start-up, instruction, on-site performance tests: 3 days per boiler.
- .10 Trial usage:
  - .1 Departmental Representative may use boilers for test purposes prior to acceptance and commencement of warranty period.
  - .2 Supply labour, materials and instruments required for tests.
- .11 Temporary use by contractor:
  - .1 Contractor may use boilers only after written approval from Departmental Representative.
  - .2 Monitor and record performance continuously. Keep log of maintenance activities carried out.
  - .3 Refurbish to as-new condition before final inspection and acceptance.

## **2.2 FIRE TUBE BOILER**

- .1 Construction:
  - .1 Packaged flexible steel fire tube boiler designed to resist thermal shock.
  - .2 Wave style 316L stainless steel fire tubes.
  - .3 Boiler shall be furnished with an adequate number of tappings and inspection openings to facilitate internal boiler inspection and cleaning.
  - .4 Boiler shall be complete with a heavy gauge insulated metal jacket, finished with heat resistant enamel paint.
  - .5 All exposed boiler components such as down comers and drum ends to be insulated. If not factory insulated, boiler supplier shall include and arrange for field application.
  - .6 Provide secure attachment points for seismic anchoring.
- .2 Boiler Accessories:
  - .1 Provide all standard trim items and controls as described in the manufacturer's published product specification including the following:
    - .1 Flue gas thermometer.
    - .2 Thermometer and pressure gauge.
    - .3 Water temperature control operator.
    - .4 High limit safety control with manual reset.
    - .5 Low water cutoff with manual reset (manual reset should not be necessary after electrical power interruption).

- .6 50 PSI ASME safety relief valve.
- .7 Electronic combustion safety control
- .8 Direct spark Ignition.
- .9 Modulating burner unit.
- .3 Gas Burner and Control Equipment
  - .1 Boiler shall be furnished with a forced draft, flame retention gas burner.
  - .2 Burner shall be complete with integral motor and blower for supplying sufficient combustion air.
  - .3 Provide all standard trim items and controls as described in manufacturers published product specification including the following:
    - .1 Flue gas thermometer.
    - .2 Thermometer and pressure gauge.
    - .3 Water temperature control operator.
    - .4 High limit safety control with manual reset.
    - .5 Low water cutoff with manual reset. Manual reset should not be necessary after electrical power interruption. One normally open set of dry contacts for alarm signal to the EMCS.
    - .6 ASME safety relief valve(s) to release entire boiler capacity.
    - .7 Automatic gas valve operator.
    - .8 Auxiliary safety shut-off valve.
    - .9 Pilot solenoid valve.
    - .10 Pilot ignition assembly.
    - .11 Ignition transformer.
    - .12 Main manual gas shut-off valve.
    - .13 Pilot cock.
    - .14 Pilot and main gas pressure regulators.
    - .15 Air safety switch.
    - .16 Electronic combustion safety control with UV sensor.
- .4 Accessories:
  - .1 Modulating gas burner.
  - .2 Auxiliary low water cutoff with manual reset and test
  - .3 Adjustable high limit with manual reset.
  - .4 Low air pressure switches
  - .5 Condensate trap with blocked drain switch
  - .6 High voltage terminal strip
  - .7 Low voltage terminal strip
  - .8 Manufacturers Bacnet gateway
  - .9 Condensate neutralization kit
  - .10 Manufacturers plant level controller

- .11 Manufacturers line size two-way motorized control valve with 120 VAC actuator and 416L stainless steel stem and EPDM seal.
- .12 Manufacturers line size variable speed boiler circulation pump with 208V, 3PH connection and digital display and 316L stainless steel shaft and alarm contacts.

### **2.3 AUXILIARIES**

- .1 Provide auxiliaries for each boiler and to meet ASME requirements.
- .2 Hot water boilers:
  - .1 Relief valves: ASME rated, set to release entire boiler capacity.
  - .2 Pressure gauge: 90 mm diameter complete with shut-off cock.
  - .3 Thermometer: 115 mm diameter range 10 to 150 degrees C.
  - .4 Low water cut-off: with visual and audible alarms.
  - .5 Auxiliary low water cut-off: with separate cold water connection to boiler.
  - .6 Isolating gate valves: on supply and return connections.
  - .7 Drain valve: NPS 2.
  - .8 Stack thermometer: range 65 to 400 degrees C.
  - .9 Outdoor controller: to reset operating temperature controller.
  - .10 1 set of cleaning tools.
- .3 Pot type chemical feeder.
- .4 Turndown ratio: at least 20:1.

### **2.4 EMISSION CONTROL**

- .1 Rate of discharge of air contaminants from boiler not to exceed:
  - .1 For nitrogen oxides expressed as nitrogen dioxide:
    - .1 22 ng/J of heat input when fired with gaseous fuel.
  - .2 For carbon monoxide, 125 ng/J of heat input.

## **Part 3 Execution**

### **3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

### **3.2 INSTALLATION**

- .1 Install in accordance with ASME Boiler and Pressure Vessels Code, regulations of Province having jurisdiction, except where specified otherwise, and manufacturers recommendations.
- .2 Make required piping connections to inlets and outlets recommended by boiler manufacturer.



- .3 Maintain clearances as indicated or if not indicated, as recommended by manufacturer for operation, servicing and maintenance without disruption of operation of any other equipment/system.
- .4 Mount unit level using specified vibration isolation in Section 23 05 48 - Vibration and Seismic Controls for HVAC Piping and Equipment.
- .5 Pipe hot water relief valves full size to nearest drain.
- .6 Pipe blowdown/drain to blowdown tank/floor drain.
- .7 Pipe condensate drain to floor drain via condensate acid neutralization unit.
- .8 Natural gas fired installations: in accordance with CSA B149.1.

### **3.3 MOUNTINGS AND ACCESSORIES**

- .1 Safety valves and relief valves:
  - .1 Run separate discharge from each valve.
  - .2 Terminate discharge pipe as indicated.
  - .3 Run drain pipe from each valve outlet and drip pan elbow to above nearest drain.
- .2 Blowdown valves:
  - .1 Run discharge to terminate as indicated.

### **3.4 FIELD QUALITY CONTROL**

- .1 Commissioning:
  - .1 Manufacturer to:
    - .1 Certify installation.
    - .2 Start up and commission installation.
    - .3 Carry out on-site performance verification tests.
    - .4 Demonstrate operation and maintenance.
  - .2 Provide Departmental Representative at least 24 hour's notice prior to inspections, tests, and demonstrations. Submit written report of inspections and test results.

**END OF SECTION**

**Part 1            General**

**1.1                GENERAL**

- .1        This Section covers items common to Sections of Divisions 26 and 28. This section supplements requirements of Division 1.

**1.2                RELATED REQUIREMENTS**

- .1        Section 26 05 00 - Common Work Results – Electrical
- .2        Section 26 05 20 - Wire and Box Connectors 0-1000V
- .3        Section 26 05 21 - Wires and Cables 0-1000V
- .4        Section 26 05 22 - Connectors and Terminations
- .5        Section 26 05 29 - Hangers and Supports for Electrical Systems
- .6        Section 26 05 31 - Splitters, Junction, Pull Boxes and Cabinets
- .7        Section 26 05 34 - Conduits, Conduit Fastenings and Conduit Fittings
- .8        Section 26 05 44 – Installation of Cables in Ducts
- .9        Section 26 28 21 - Moulded Case Circuit Breakers

**1.3                REFERENCES**

- .1        Definitions:
  - .1        Electrical and electronic terms: unless otherwise specified or indicated, terms used in these specifications, and on drawings, are those defined by IEEE SP1122.
- .2        Reference Standards:
  - .1        CSA Group
    - .1        CSA C22.1-15, Canadian Electrical Code, Part 1 (23rd Edition), Safety Standard for Electrical Installations.
    - .2        CSA C22.2 No. 1-10, General Requirements - Canadian Electrical Code, Part 2.
    - .3        CAN3-C235-83(R2015), Preferred Voltage Levels for AC Systems, 0 to 50,000 V.
  - .2        Institute of Electrical and Electronics (IEEE)/National Electrical Safety Code Product Line (NESC)
    - .1        IEEE SP1122-2000, The Authoritative Dictionary of IEEE Standards Terms, 7th Edition.

#### **1.4 DRAWING NOTATION**

- .1 The electrical work for this project involves the installation of new electrical and the re-use or relocation of some existing equipment. In all cases the Contractor shall assume that it has to supply and install all electrical equipment. Standard notations are used on the Plans to assist the Contractor in identifying what work needs to be done. These standard notations are defined as follows:
  - .1 “All equipment is proposed unless noted otherwise” – This notation is used on Plans where the majority of the equipment on the drawing is to be supplied and installed by the Contractor. The notation means that the Contractor shall perform all work shown on the drawing except for equipment shown as existing (i.e. to remain).
  - .2 “All equipment is existing unless noted otherwise”: - This notation is used on Plans where the majority of the equipment is existing. The notation means that the Contractor shall perform only the work identified.

#### **1.5 CODES AND STANDARDS**

- .1 Complete installation in accordance with CSA C22.1-2015 except where specified otherwise.

#### **1.6 CARE, OPERATION AND START-UP**

- .1 Instruct Consultant and operating personnel in the operation, care and maintenance of systems, system equipment and components.
- .2 Provide these services for such period, and for as many visits as necessary to put equipment in operation, and ensure that operating personnel are conversant with all aspects of its care and operation.

#### **1.7 PERMITS, FEES AND INSPECTION**

- .1 Submit to Electrical Inspection Department and Supply Authority necessary number of drawings and specifications for examination and approval prior to commencement of Work.
- .2 Pay associated fees.
- .3 Notify Consultant of changes required by Electrical Inspection Department prior to making changes.
- .4 Furnish Certificates of Acceptance from authorities having jurisdiction on completion of work to Consultant.

#### **1.8 DELIVERY, STORAGE AND HANDLING**

- .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:

- .1 Store materials indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
- .2 Store and protect equipment from nicks, scratches, and blemishes.
- .3 Replace defective or damaged materials with new.
- .4 Develop Construction Waste Management Plan related to Work of this Section.

## **1.9 CLOSEOUT SUBMITTALS**

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for Pumps and Electrical Equipment for incorporation into manual.
  - .1 Provide for each system and principal item of equipment as specified in technical sections for use by operation and maintenance personnel.
  - .2 Operating instructions to include following:
    - .1 Wiring diagrams, control diagrams, and control sequence for each principal system and item of equipment.
    - .2 Start up, proper adjustment, operating, lubrication, and shutdown procedures.
    - .3 Safety precautions.
    - .4 Procedures to be followed in event of equipment failure.
    - .5 Other items of instruction as recommended by manufacturer of each system or item of equipment.
  - .3 Print or engrave operating instructions and frame under glass or in approved laminated plastic.
  - .4 Post instructions where directed.
  - .5 For operating instructions exposed to weather, provide weather-resistant materials or weatherproof enclosures.
- .3 Ensure operating instructions will not fade when exposed to sunlight and are secured to prevent easy removal or peeling.

## **Part 2 Products**

### **2.1 DESIGN REQUIREMENTS**

- .1 Operating voltages: to CAN3-C235.
- .2 Motors, electric heating, control and distribution devices and equipment to operate satisfactorily at 60 Hz within normal operating limits established by above standard.
  - .1 Equipment to operate in extreme operating conditions established in above standard without damage to equipment.
- .3 Language operating requirements: provide identification nameplates for control items in English.

- .4 Use one nameplate for each language.

## **2.2 MATERIALS AND EQUIPMENT**

- .1 Provide materials and equipment in accordance with Section 01 61 00 – Common Product Requirements.
- .2 Equipment and material to be CSA certified. Where there is no alternative to supplying equipment which is not CSA certified, obtain special approval from Electrical Inspection Department.
- .3 Factory assemble control panels and component assemblies.

## **2.3 ELECTRIC MOTORS, EQUIPMENT AND CONTROLS**

- .1 Verify installation and co-ordination responsibilities related to motors, equipment and controls, as indicated.

## **2.4 WARNING SIGNS**

- .1 Warning Signs: in accordance with requirements of authority having jurisdiction and Consultant.
- .2 Decal signs, minimum size 175 x 250 mm.

## **2.5 WIRING TERMINATIONS**

- .1 Ensure lugs, terminals, screws used for termination of wiring are suitable for either copper or aluminum conductors.

## **2.6 EQUIPMENT IDENTIFICATION**

- .1 Identify equipment cabinets with nameplates as follows:
  - .1 Nameplates:  
Lamicoid 3 mm thick plastic engraving sheet, white face, black core, mechanically attached with self-tapping screws or permanent self-adhesive, 20 x 90 mm, 1 line, 8 mm high letters.
  - .2 Identify electrical equipment with labels as follows:
    - .1 Labels:  
Embossed plastic labels with 6mm high letters unless specified otherwise.
  - .3 Allow for average of twenty-five (25) letters per nameplate and label.
  - .4 Nameplates for terminal cabinets and junction boxes to indicate system.
  - .5 Terminal cabinets and pull boxes: indicate system.

**2.7 WIRING IDENTIFICATION**

- .1 Identify wiring with permanent indelible identifying markings, either numbered or coloured plastic tapes, on both ends of cable.
- .2 Colour code: to CSA C22.1.
- .3 Use colour coded wires in communication cables, matched throughout system.

**2.8 CONDUIT AND CABLE IDENTIFICATION**

- .1 Colour code conduits, boxes and metallic sheathed cables.
- .2 Code with plastic tape or paint at points where conduit or cable enters wall, ceiling, or floor, and at 15 m intervals.
- .3 Colours: 25 mm wide prime colour and 20 mm wide auxiliary colour.

	Prime	Auxiliary
Communication Systems	Green	Blue
Security Systems	Red	Yellow

**2.9 MANUFACTURERS AND CSA LABELS**

- .1 Visible and legible, after equipment is installed.

**2.10 FINISHES**

- .1 Shop finish metal enclosure surfaces by application of rust resistant primer inside and outside, and at least two coats of finish enamel.
- .2 Clean and touch up surfaces of shop-painted equipment scratched or marred during shipment or installation, to match original paint.
- .3 Clean and prime exposed non-galvanized hangers, racks and fastenings to prevent rusting.

**Part 3 Execution**

**3.1 EXAMINATION**

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for installation in accordance with manufacturer's written instructions.
  - .1 Visually inspect substrate in presence of Consultant.
  - .2 Inform Consultant of unacceptable conditions immediately upon discovery.
  - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Consultant.

### **3.2 INSTALLATION**

- .1 Do complete installation in accordance with CSA C22.1 except where specified otherwise.
- .2 Do overhead and underground systems in accordance with CAN/CSA-C22.3 No.1 except where specified otherwise.

### **3.3 NAMEPLATES AND LABELS**

- .1 Ensure manufacturer's nameplates, CSA labels and identification nameplates are visible and legible after equipment is installed.

### **3.4 CONDUIT AND CABLE INSTALLATION**

- .1 Install conduit and sleeves prior to pouring of concrete.
  - .1 Sleeves through concrete: schedule 40 plastic, sized for free passage of conduit, and protruding 50 mm.
- .2 If plastic sleeves are used in fire rated walls or floors, remove before conduit installation.
- .3 Install cables, conduits and fittings embedded or plastered over, close to building structure so furring can be kept to minimum.

### **3.5 MOUNTING HEIGHTS**

- .1 Mounting height of equipment is from finished floor to centreline of equipment unless specified or indicated otherwise.
- .2 If mounting height of equipment is not specified or indicated, verify before proceeding with installation.

### **3.6 CO-ORDINATION OF PROTECTIVE DEVICES**

- .1 Ensure circuit protective devices such as overcurrent trips, relays and fuses are installed to required values and settings.

### **3.7 CLEANING**

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
  - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
  - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

**3.8 FIELD QUALITY CONTROL**

- .1 All electrical work to be carried out by qualified, licensed electricians or apprentices as per the conditions of the Provincial Act respecting manpower vocational training and qualification. Employees registered in a provincial apprentices program shall be permitted, under the direct supervision of a qualified licensed electrician, to perform specific tasks - the activities permitted shall be determined based on the level of training attained and the demonstration of ability to perform specific duties.
  
- .2 The work of this division to be carried out by a contractor who holds a valid Master Electrical contractor license as issued by the Province that the work is being constructed in.

**END OF SECTION**



**Part 1            General**

**1.1            SECTION INCLUDES**

- .1            Materials and installation for wire and box connectors.

**1.2            RELATED SECTIONS**

- .1            Section 01 74 19 - Construction/Demolition Waste Management And Disposal.

**1.3            REFERENCES**

- .1            Canadian Standards Association (CSA International)
  - .1            CAN/CSA-C22.2No.18.1-06, Metallic Outlet Boxes
  - .2            CAN/CSA-C22.2No.18.2-06, Nonmetallic Outlet Boxes
  - .3            CAN/CSA-C22.2No.18.3-04 (R2011), Conduit, Tubing, and Cable Fittings
  - .4            CAN/CSA-C22.2No.18.4-04 (R2011), Hardware for the Support of Conduit, Tubing
  - .5            CAN/CSA-C22.2No.18.5-02 (R2011), Positioning Devices
  - .6            CSA C22.2No.65-03(R2008)], Wire Connectors.
- .2            Electrical and Electronic Manufacturers' Association of Canada (EEMAC)
  - .1            EEMAC 1Y-2, 1961 Bushing Stud Connectors and Aluminum Adapters (1200 Ampere Maximum Rating).
- .3            National Electrical Manufacturers Association (NEMA)

**1.4            WASTE MANAGEMENT AND DISPOSAL**

- .1            Separate and recycle waste materials in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.
- .2            Remove from site and dispose of all packaging materials at appropriate recycling facilities.
- .3            Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard and other recyclable packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4            Divert unused wiring materials from landfill to metal recycling facility as approved by Engineer.

---

**Part 2**            **Products**

**2.1**            **MATERIALS**

- .1      Pressure type wire connectors to: CSA C22.2No.65, with current carrying parts of copper sized to fit copper conductors as required.
  
- .2      Fixture type splicing connectors to: CSA C22.2No.65, with current carrying parts of copper sized to fit copper conductors 10 AWG or less.
  
- .3      Bushing stud connectors: to EEMAC 1Y-2 to consist of:
  - .1      Connector body and stud clamp for copper conductors.
  - .2      Clamp for stranded copper conductors.
  - .3      Stud clamp bolts.
  - .4      Bolts for copper conductors.
  - .5      Sized for conductors as indicated.
  
- .4      Clamps or connectors for armoured cable and flexible conduit as required to: CAN/CSA-C22.2No.18 (all subsections).

**Part 3**            **Execution**

**3.1**            **EXAMINATION**

- .1      Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for wire and box connectors installation in accordance with manufacturer's written instructions.
  - .1      Visually inspect substrate in presence of Consultant or provide photographic evidence of areas of concern.
  - .2      Inform Consultant of unacceptable conditions immediately upon discovery.
  
- .2      Proceed with installation only after unacceptable conditions have been remedied.

**3.2**            **INSTALLATION**

- .1      Remove insulation carefully from ends of conductors and:
  - .1      Install mechanical pressure type connectors and tighten screws with appropriate compression tool recommended by manufacturer. Installation shall meet secureness tests in accordance with CSA C22.2No.65.
  - .2      Install fixture type connectors and tighten. Replace insulating cap.
  - .3      Install bushing stud connectors in accordance with EEMAC 1Y-2.

**3.3**            **CLEANING**

- .1      Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
  - .1      Leave Work area clean at end of each day.

- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
  - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

**END OF SECTION**

**Part 1            General**

**1.1            RELATED SECTIONS**

- .1        Section 26 05 20 - Wire and Box Connectors - 0 - 1000 V.

**1.2            REFERENCES**

- .1        CSA C22.2 No .0.3-09, Test Methods for Electrical Wires and Cables.

**1.3            PRODUCT DATA**

- .1        Submit product data in accordance with Section 01 33 00 - Submittal Procedures.

**Part 2           Products**

**2.1            BUILDING WIRES**

- .1        Conductors: stranded for 10 AWG and larger. Minimum size: 12 AWG.
- .2        Copper conductors: size as indicated, with 600 V insulation of cross-linked thermosetting polyethylene material rated RW90 XLPE, Jacketted.
- .3        Copper conductors: size as indicated, with thermoplastic insulation type TWU rated at 600 V.

**2.2            TECK 90 CABLE**

- .1        Cable: in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2        Conductors:
  - .1        Grounding conductor: copper as indicated.
  - .2        Circuit conductors: copper as indicated, size as indicated.
- .3        Insulation:
  - .1        Cross-linked polyethylene XLPE.
  - .2        Rating: , 600 V.
- .4        Inner jacket: polyvinyl chloride material.
- .5        Armour: interlocking galvanized steel.
- .6        Overall covering: thermoplastic polyvinyl chloride, compliant to applicable Building Code classification for this project.
- .7        Fastenings:

- .1 One hole aluminum straps to secure surface cables 50 mm and smaller. Two hole steel straps for cables larger than 50 mm.
- .2 Channel type supports for two or more cables at 300 mm centers.
- .3 Threaded rods: 6 mm diameter to support suspended channels.
- .8 Connectors:
- .9 Watertight approved for TECK cable.

### **2.3 CONTROL CABLES**

- .1 Type: LVT: [2] soft annealed copper conductors, sized as indicated:
  - .1 Insulation: thermoplastic.
  - .2 Sheath: thermoplastic jacket.
- .2 Type: low energy 300 V control cable: stranded annealed copper conductors sized as indicated LVT: [2] soft annealed copper conductors, sized as indicated:
  - .1 Insulation: polyethylene.
  - .2 Shielding: braid over each pair.
  - .3 Overall covering: PVC jackets.
- .3 Type: 600 V stranded annealed copper conductors, sizes as indicated:
  - .1 Insulation: polyethylene.
  - .2 Shielding: braid over each pair of conductors.
  - .3 Overall covering: PVC.

### **2.4 STANDARDS (UTP AND DATA CABLING)**

- .1 Except where specifically modified within this specification, the installation shall, as minimum, comply with the latest issues of the following standards:
  - .1 CAN/CSA-T527, "Commercial Building Grounding and Bonding Requirements for Telecommunications"
  - .2 CAN/CSA-T528-93(R2001), "Design Guideline for Administration Telecommunications Infrastructure in Commercial Buildings"
  - .3 CAN/CSA-C22.2 No. 182.4, "Plugs, Receptacles, and Connectors for Communication Systems".
  - .4 EIA/TIA Bulletin TSB-36, Technical Systems Bulletin Additional Cable Specifications for Unshielded Twisted Pair Cables, Electronic Industries Association (USA), November 1991.
  - .5 The installation shall, as minimum, comply with the latest issues of the following Building Codes: All municipal By-laws, Provincial Codes, The BC Building Code, The Canadian Electrical Code, Canadian Labour Code, and the BC Fire Code. In the case of conflict or discrepancy the more stringent code shall apply.
  - .6 TIA/EIA-606-A

**Part 3 Execution**

**3.1 FIELD QUALITY CONTROL**

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Perform tests using method appropriate to site conditions and to approval of Consultant and local authority having jurisdiction over installation.
- .3 Perform tests before energizing electrical system.

**3.2 GENERAL CABLE INSTALLATION**

- .1 Terminate cables in accordance with Section 26 05 20 - Wire and Box Connectors - (0-1000 V).
- .2 Cable Colour Coding: to Section 26 05 00 Common Work Results for Electrical.
- .3 All cabling shall be installed in conduit except in electrical/mechanical rooms where cabling is terminated.

**3.3 INSTALLATION OF BUILDING WIRES**

- .1 Install wiring as follows:
  - .1 In conduit systems in accordance with Section 26 05 34 - Conduits, Conduit Fastenings and Conduit Fittings.

**3.4 INSTALLATION OF TECK90 CABLE (0 -1000 V)**

- .1 Group cables wherever possible on channels.
- .2 Install cable exposed, securely supported by straps or hangers.

**3.5 INSTALLATION OF ARMOURED CABLES**

- .1 Group cables wherever possible on channels.

**3.6 TESTING GENERAL**

- .1 Cabling and connectors to be tested by an experienced company employing trained technicians with minimum 5 years experience in data cabling industry. Provide at the time of tender the name of the company to be performing the connection and testing of cables, a listing of the qualifications of the technicians to be performing the work and a listing major jobs completed by the company.
- .2 The Departmental Representative reserves the right to approve or reject any company being proposed to perform this work based on that company's previous experience or training.

- .3 Testing to include verification of cable configurations between connected equipment.

**END OF SECTION**

**Part 1            General**

**1.1            SECTION INCLUDES**

- .1        Materials and installation for connectors and terminations.

**1.2            RELATED SECTIONS**

- .1        Section 01 33 00 - Submittal Procedures.

**1.3            REFERENCES**

- .1        Canadian Standards Association (CSA International)
  - .1        CSA C22.2No.65-03 (R2008) Wire Connectors
  - .2        CSA C22.2 No.41-07, Grounding and Bonding Equipment.

**1.4            PRODUCT DATA**

- .1        Submit product data in accordance with Section 01 33 00 - Submittal Procedures.

**1.5            DELIVERY, STORAGE AND HANDLING**

- .1        Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2        Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3        Storage and Handling Requirements:
  - .1        Store materials indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
  - .2        Store and protect hangers and supports from nicks, scratches, and blemishes.
  - .3        Replace defective or damaged materials with new.

**Part 2            Products**

**2.1            CONNECTORS AND TERMINATIONS**

- .1        Copper compression connectors to CSA C22.2No.65 as required sized for conductors.

**Part 3            Execution**

**3.1            INSTALLATION**

- .1        Install terminations, and splices in accordance with manufacturer's instructions.



- .2 Bond and ground as required to CSA C22.2No.41.

**END OF SECTION**

**Part 1            General**

**1.1            RELATED SECTIONS**

- .1            Section 01 33 00 - Submittal Procedures.

**1.2            DELIVERY, STORAGE AND HANDLING**

- .1            Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.
- .2            Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3            Storage and Handling Requirements:
  - .1            Store the materials indoors off of the ground and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
  - .2            Store and protect hangers and supports from nicks, scratches, and blemishes.
- .4            Replace defective or damaged materials with new.

**Part 2            Products**

**2.1            SUPPORT CHANNELS**

- .1            Select channel as indicated in the drawings:
  - .1            U shape, galvanized steel, size 41 x 41 mm, 2.5 mm thick, surface mounted and suspended.

**Part 3            Execution**

**3.1            EXAMINATION**

- .1            Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for hangers and supports installation in accordance with manufacturer's written instructions.
  - .1            Visually inspect substrate in presence of Consultant or provide photographic evidence of areas of concern.
  - .2            Inform Consultant of unacceptable conditions immediately upon discovery.
  - .3            Proceed with installation only after unacceptable conditions have been remedied.

**3.2            INSTALLATION**

- .1            Secure equipment to poured concrete with expandable inserts.

- .2 Secure equipment to hollow masonry walls or suspended ceilings with toggle bolts.
- .3 Support equipment, conduit or cables using clips, spring loaded bolts, cable clamps designed as accessories to basic channel members.
- .4 Fasten exposed conduit or cables to building construction or support system using straps.
  - .1 One-hole stainless steel straps to secure surface conduits and cables 50 mm and smaller.
  - .2 Two-hole stainless steel straps for conduits and cables larger than 50 mm.
  - .3 Beam clamps to secure conduit to exposed steel work.
- .5 Suspended support systems.
  - .1 Support individual cable or conduit runs with 6 mm dia threaded rods and spring clips.
  - .2 Support 2 or more cables or conduits on channels supported by 6 mm dia threaded rod hangers where direct fastening to building construction is impractical.
- .6 For surface mounting of two or more conduits use channels at 1000 mm on centre spacing.
- .7 Provide metal brackets, frames, hangers, clamps and related types of support structures where indicated or as required to support conduit and cable runs.
- .8 Ensure adequate support for raceways and cables dropped vertically to equipment where there is no wall support.
- .9 Do not use wire lashing or perforated strap to support or secure raceways or cables.
- .10 Do not use supports or equipment installed for other trades for conduit or cable support except with permission of other trade and approval of Engineer.
- .11 Install fastenings and supports as required for each type of equipment cables and conduits, and in accordance with manufacturer's installation recommendations.

### **3.3 CLEANING**

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
  - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.

**END OF SECTION**

**PART 1 GENERAL**

**1.1 REFERENCES**

- .1 Canadian Standards Association (CSA International)
  - .1 CSA C22.1-15, Canadian Electrical Code, Part 1, 23th Edition.

**1.2 ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Provide shop drawings: in accordance with Section 01 33 00 - Submittal Procedures.

**1.3 DELIVERY, STORAGE AND HANDLING**

- .1 Waste Management and Disposal:
  - .1 Separate waste materials for recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**PART 2 PRODUCTS**

**2.1 SPLITTERS**

- .1 Construction: sheet metal enclosure, welded corners and formed hinged cover suitable for locking in closed position.
- .2 Terminations: main and branch lugs or connection blocks to match required size and number of incoming and outgoing conductors as indicated.
- .3 Spare Terminals: minimum three spare terminals or lugs on each connection or lug block sized less than 400 A.

**2.2 JUNCTION AND PULL BOXES**

- .1 NEMA 4X stainless steel construction with screw-on flat covers for surface mounting. All mounting hardware to be stainless steel.
- .2 Provide hinged lockable covers where noted on the drawings.
- .3 Covers with 25 mm minimum extension all around, for flush-mounted pull and junction boxes.

- .4 Provide Type 10 underground pull boxes that meet the requirements of the Ministry Electrical and Signing Material Standards Section 201 and the Plans.

### **2.3 CABINETS**

- .1 Provide enclosures that meet the requirements of the Ministry of Transportation and Infrastructure Electrical and Signing Material Standards Section 402 and the Plans (with heating as noted in the plans).
- .2 Equipment layouts shown on the drawings represent approximate locations only. Contractor shall provide shop drawings for the kiosks and cabinets including detailed equipment layout drawings and cabinet/kiosk dimensions. Provide detailed parts lists of the kiosk components and equipment to be installed in the kiosk.
- .3 Supply enclosures manufactured by Ministry of Transportation approved suppliers.
- .4 Provide a fold down shelf permanently fastened to each door for holding testing equipment or documentation.
- .5 All end of wire segments and all access points between source and destination shall be labeled. Wire labeling shall adhere to the nomenclature as noted on the Drawings. The Contractor shall provide a sample of the proposed labeling to the Department's Representative for approval prior to installation.
- .6 Notify the Departmental Representative five working days prior to the anticipated completion of the cabinet. The Owner's Representative will inspect the completed cabinet at the Supplier's facilities.
- .7 Supply all cabinets with a complete set of their respective as-built design drawings in the plan pouches.

## **PART 3 EXECUTION**

### **3.1 SPLITTER INSTALLATION**

- .1 Mount plumb, true and square to building lines.
- .2 Extend splitters full length of equipment arrangement except where indicated otherwise.

### **3.2 JUNCTION, PULL BOXES AND CABINETS INSTALLATION**

- .1 Install pull boxes in inconspicuous but accessible locations.
- .2 Mount cabinets with top not higher than 2 m above finished floor.
- .3 Install equipment and terminal blocks as indicated in cabinets.
- .4 Only main junction and pull boxes are indicated. Install pull boxes so as not to exceed 30 m of conduit run between pull boxes.

**3.3 IDENTIFICATION**

- .1 Provide equipment identification in accordance with Section 26 05 01 - Common Work Results - Electrical.
- .2 Install size 2 identification labels indicating system name, voltage, and phase.

**END OF SECTION**

**PART 1 GENERAL**

**1.1 RELATED SECTIONS**

- .1 Section 01 33 00 - Submittal Procedures.

**1.2 REFERENCES**

- .1 Canadian Standards Association (CSA)
  - .1 CAN/CSA C22.2 No. 18-98(R2003), Outlet Boxes, Conduit Boxes, Fittings and Associated Hardware, A National Standard of Canada.
  - .2 CSA C22.2 No. 45-M1981(R2003), Rigid Metal Conduit.
  - .3 CSA C22.2 No. 56-04, Flexible Metal Conduit and Liquid-Tight Flexible Metal Conduit.
  - .4 CSA C22.2 No. 83-M1985(R2003), Electrical Metallic Tubing.
  - .5 CSA C22.2 No. 211.2-M1984(R2003), Rigid PVC (Unplasticized) Conduit.

**1.3 ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product data: submit manufacturer's printed product literature, specifications and datasheets.
  - .1 Submit cable manufacturing data.
- .3 Quality assurance submittals:
  - .1 Test reports: submit certified test reports.
  - .2 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .4 Instructions: submit manufacturer's installation instructions.

**1.4 WASTE MANAGEMENT AND DISPOSAL**

- .1 Separate waste materials for recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Place materials defined as hazardous or toxic waste in designated containers.
- .3 Ensure emptied containers are sealed and stored safely for disposal away from children.

**PART 2 PRODUCTS**

**2.1 CABLES AND REELS**

- .1 Provide cables on reels or coils.

- .1 Mark or tag each cable and outside of each reel or coil, to indicate cable length, voltage rating, conductor size, and manufacturer's lot number and reel number.
- .2 Each coil or reel of cable to contain only one continuous cable without splices.
- .3 Identify cables for exclusively dc applications.
- .4 Reel and mark shielded cables rated [2,001] volts and above.

## **2.2 CONDUITS**

- .1 Rigid metal conduit: to CSA C22.2 No. 45, hot dipped galvanized steel threaded.
- .2 Electrical metallic tubing (EMT): to CSA C22.2 No. 83, with couplings.
- .3 Rigid PVC conduit: to CSA C22.2 No. 211.2.
- .4 Flexible metal conduit: to CSA C22.2 No. 56, liquid-tight flexible metal.

## **2.3 CONDUIT FASTENINGS**

- .1 One hole steel straps to secure surface conduits 50 mm and smaller. Two hole steel straps for conduits larger than 50 mm.
- .2 Beam clamps to secure conduits to exposed steel work.
- .3 Channel type supports for two or more conduits at 1500 mm oc.
- .4 Threaded rods, 6 mm diameter, to support suspended channels.

## **2.4 CONDUIT FITTINGS**

- .1 Fittings: manufactured for use with conduit specified. Coating: same as conduit.
- .2 Factory "ells" where 90 degree bends are required for 25 mm and larger conduits.
- .3 Watertight connectors and couplings for EMT. Set-screws are not acceptable.

## **2.5 EXPANSION FITTINGS FOR RIGID CONDUIT**

- .1 Weatherproof expansion fittings with internal bonding assembly suitable for 100 mm linear expansion.
- .2 Watertight expansion fittings with integral bonding jumper suitable for linear expansion and 19 mm deflection.
- .3 Weatherproof expansion fittings for linear expansion at entry to panel.

## **2.6 FISH CORD**

- .1 Polypropylene.



---

**PART 3 EXECUTION**

**3.1 INSTALLATION**

- .1 Install conduits to conserve headroom in exposed locations and cause minimum interference in spaces through which they pass.
- .2 Conceal conduits except in mechanical and electrical service rooms.
- .3 Surface mount conduits except where they are in a secure area designated as a wire chase already. Concealed conduit may be required in aesthetic locations. If in doubt, consult Owner and Consultant for direction.
- .4 Use rigid hot dipped galvanized steel threaded conduit except where specified otherwise.
- .5 Use electrical metallic tubing (EMT) indoors as specified.
- .6 Use rigid pvc conduit underground.
- .7 Use liquid tight flexible metal conduit for connection to devices.
- .8 Bend conduit cold:
  - .1 Replace conduit if kinked or flattened more than 1/10th of its original diameter.
- .9 Mechanically bend steel conduit over 19 mm diameter.
- .10 Field threads on rigid conduit must be of sufficient length to draw conduits up tight.
- .11 Install fish cord in empty conduits.
- .12 Remove and replace blocked conduit sections.
  - .1 Do not use liquids to clean out conduits.
- .13 Dry conduits out before installing wire.

**3.2 SURFACE CONDUITS**

- .1 Run parallel or perpendicular to building lines.
- .2 Locate conduits behind infrared or gas fired heaters with 1.5 m clearance.
- .3 Run conduits in flanged portion of structural steel.
- .4 Group conduits wherever possible on suspended or surface channels.
- .5 Do not pass conduits through structural members except as indicated.
- .6 Do not locate conduits less than 75 mm parallel to steam or hot water lines with minimum of 25 mm at crossovers.

**3.3 CONCEALED CONDUITS**

- .1 Run parallel or perpendicular to building lines.
- .2 Do not install horizontal runs in masonry walls.
- .3 Do not install conduits in terrazzo or concrete toppings.

**3.4 CONDUITS UNDERGROUND**

- .1 Slope conduits to provide drainage.
- .2 Waterproof joints (pvc excepted) with heavy coat of bituminous paint.

**3.5 CLEANING**

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 Clean all underground ducts with a mandrel prior to pulling cables.

**END OF SECTION**

**Part 1            General**

**1.1                RELATED SECTIONS**

- .1        Section 01 74 19 - Construction/Demolition Waste Management And Disposal.
- .2        Section 31 23 10 - Excavating, Trenching and Backfilling.
- .3        Section 26 05 01 - Common Work Results - Electrical.

**1.2                REFERENCES**

- .1        Canadian Standards Association, (CSA International)
- .2        Insulated Cable Engineers Association, Inc. (ICEA)

**1.3                WASTE MANAGEMENT AND DISPOSAL**

- .1        Separate and recycle waste materials in accordance with Section 01 74 19 - Construction/Demolition Waste Management And Disposal.
- .2        Remove from site and dispose of all packaging materials at appropriate recycling facilities.
- .3        Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard and other recyclable packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4        Unused material must not be disposed of into sewer system, into streams, lakes, onto ground or in other location where it will pose health or environmental hazard.
- .5        Divert unused metal and wiring materials from landfill to metal recycling facility as approved by Engineer.
- .6        Do not dispose of preservative treated wood through incineration.
- .7        Do not dispose of preservative treated wood with other materials destined for recycling or reuse.
- .8        Dispose of treated wood, end pieces, wood scraps and sawdust at sanitary landfill approved by Engineer.
- .9        Fold up metal banding, flatten and place in designated area for recycling.

**Part 2 Products**

**2.1 NOT USED**

.1 NOT USED

**Part 3 Execution**

**3.1 CABLE INSTALLATION IN DUCTS**

.1 Install cables as indicated in ducts.

.1 Do not pull spliced cables inside ducts.

.2 Install multiple cables in duct simultaneously.

.3 Use CSA approved lubricants of type compatible with cable jacket to reduce pulling tension.

.4 To facilitate matching of colour coded multi-conductor control cables reel off in same direction during installation.

.5 Before pulling cable into ducts and until cables are properly terminated, seal ends of lead covered cables with wiping solder; seal ends of non-leaded cables with moisture seal tape.

.6 After installation of cables, seal duct ends with duct sealing compound.

**3.2 FIELD QUALITY CONTROL**

.1 Perform tests in accordance with Section 26 05 01 - Common Work Results – Electrical.

.2 Perform tests using qualified personnel. Provide necessary instruments and equipment.

.3 Check phase rotation and identify each phase conductor of each feeder.

.4 Check each feeder for continuity, short circuits and grounds. Ensure resistance to ground of circuits is not less than 50 megohms.

.5 Pre-acceptance tests.

.1 After installing cable but before splicing and terminating, perform insulation resistance test with 1000 V megger on each phase conductor.

.2 Check insulation resistance after each splice and/or termination to ensure that cable system is ready for acceptance testing.

.6 Acceptance Tests

.1 Ensure that terminations and accessory equipment are disconnected.

.2 Ground shields, ground wires, metallic armour and conductors not under test.

.3 High Potential (Hipot) Testing.

- .1 Conduct hipot testing at in accordance with manufacturer's recommendations.
- .4 Leakage Current Testing.
  - .1 Raise voltage in steps from zero to maximum values as specified by manufacturer for type of cable being tested.
  - .2 Hold maximum voltage for specified time period by manufacturer.
  - .3 Record leakage current at each step.
- .7 Provide Departmental Representative with list of test results showing location at which each test was made, circuit tested and result of each test.
- .8 Remove and replace entire length of cable if cable fails to meet any of test criteria.

**END OF SECTION**

**Part 1            General**

**1.1                SECTION INCLUDES**

- .1        Materials for moulded-case circuit breakers.

**1.2                RELATED SECTIONS**

- .1        Section 01 33 00 - Submittal Procedures.
- .2        Section 01 74 19 - Construction/Demolition Waste Management and Disposal.

**1.3                REFERENCES**

- .1        Canadian Standards Association (CSA International).
  - .1        CSA-C22.2 No. 5-09, Moulded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures (Tri-national standard with UL 489, tenth edition, and the second edition of NMX-J-266-ANCE).

**1.4                SUBMITTALS**

- .1        Submit product data in accordance with Section 01 33 00 - Submittal Procedures.
- .2        Include time-current characteristic curves for breakers with ampacity of 20 A and over or with interrupting capacity of 22,000 A symmetrical (rms) and over at system voltage.
- .3        Include time-current characteristic curves for all 600V breakers.

**1.5                WASTE MANAGEMENT AND DISPOSAL**

- .1        Separate and recycle waste materials in accordance with Section 01 74 19 - Construction/Demolition Waste Management And Disposal.
- .2        Remove from site and dispose of all packaging materials at appropriate recycling facilities.
- .3        Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard and other recyclable packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4        Divert unused metal materials from landfill to metal recycling facility as approved by Engineer.
- .5        Fold up metal banding, flatten and place in designated area for recycling.

**Part 2 Products**

**2.1 BREAKERS GENERAL**

- .1 Moulded-case circuit breakers: to CSA C22.2 No. 5
- .2 Bolt-on moulded case circuit breaker: quick- make, quick-break type, for manual and automatic operation with temperature compensation for 40 degrees C ambient.
- .3 Common-trip breakers: with single handle for multi-pole applications.
- .4 Magnetic instantaneous trip elements in circuit breakers to operate only when value of current reaches setting.
  - .1 Trip settings on breakers with adjustable trips to range from 3-8 times current rating (600V breakers).
- .5 Circuit breakers with interchangeable trips as indicated.
- .6 Circuit breakers to have the following minimum symmetrical rms interrupting capacity rating:
  - .1 120/240V Breakers: 10kA
  - .2 600V Breakers 25kA

**2.2 THERMAL MAGNETIC BREAKERS**

- .1 Moulded case circuit breaker to operate automatically by means of thermal and magnetic tripping devices to provide inverse time current tripping and instantaneous tripping for short circuit protection.
  - .1 Circuit breaker for heat trace circuit shall be of the type recommended by the heat trace manufacturer.

**Part 3 Execution**

**3.1 INSTALLATION**

- .1 Install circuit breakers as indicated.

**END OF SECTION**