



1 LIGHTING AND FIRE ALARM DEMOLITION WORK
E2 1:100

- DRAWING NOTES / NOTES DU DESSIN**
- 1 TYPICAL:
DISCONNECT AND REMOVE EXISTING ELECTRICAL DEVICES AS INDICATED. REMOVE CONDUIT AND WIRING BACK TO NEAREST ACCESSIBLE CEILING JUNCTION BOX AND MAKE SAFE. RETAIN CIRCUITS FOR USE IN NEW LAYOUT.
- 2 TYPICAL:
DISCONNECT AND REMOVE AND/OR RELOCATE EXISTING FIRE ALARM BELL AS INDICATED. EXTEND CONDUIT AND WIRING AS REQUIRED.
- 3 TYPICAL:
DISCONNECT AND REMOVE AND/OR RELOCATE EXISTING PICTOGRAM "RUNNING MAN" TYPE EXIT SIGN. REFER TO DRAWING E3 FOR NEW LAYOUT.
- 4 DISCONNECT AND REMOVE EXISTING FIRE ALARM CONDUIT TO ACCOMMODATE CONSTRUCTION OF NEW WALL. REINSTATE UPON COMPLETION OF WORK. ENSURE EXISTING FIRE ALARM BELLS FED FROM THIS CONDUIT REMAINS OPERATIONAL.

Canada

Public Works and
Government Services
Canada

Travaux publics et
services gouvernementaux
Canada

Goodkey Weedmark
Consulting Engineers

GOODKEY WEEDMARK & ASSOCIATES LIMITED
1688 Woodward Dr. 613 727-5111 Voice
Ottawa Ontario 613 727-5115 Fax
Canada K2C 3R8 www.gwal.com Web
Gwal Project: 2017-233



Contractor to verify all dimensions
& conditions on site and immediately
notify the departmental representative
of all discrepancies.

1	ISSUED FOR TENDER	2017/06/30
0	ISSUED FOR REVIEW	2017/06/16
revisions	description	date

A	A detail no. no. du detail	A
C	B location drawing no. sur dessin no.	B
	C drawing no. dessin no.	C

project projet

**CANADA REVENUE AGENCY
MAIL PROCESSING ROOM**

1050 NOTRE DAME AVE.,
SUDBURY, ON.

drawing dessin

**LIGHTING AND FIRE
ALARM - DEMOLITION
WORK**

Designed By	A.GIRARD	Conçu par	
Date		(yyyy/mm/dd)	
Drawn By	A.GIRARD	Dessiné par	
Date		(yyyy/mm/dd)	
Reviewed By	R.BOIVIN	Examiné par	
Date		(yyyy/mm/dd)	
Approved By	R.BOIVIN	Approuvé par	
Date		(yyyy/mm/dd)	
Tender	CRIS BORS	Soumission	
Project Manager	Administrateur de projets		
Project no.	No. du projet		
	R.087411.001		
Drawing no.	No. du dessin		
	E2		