



Addendum # 1

Date: July 14, 2017

Projet: "Turnkey project" proposed greenhouse - Chapais Farm

Bidders must make sure that their bids are based on the latest version of the tender documents published and take into consideration the following amendments and information, including any information provided on amendments or Q&A previously published for this project.

Bidders that do not comply with this requirement will be discarded.

1. Appendix E Technical Plans & Specifications, section 1.10 Mechanical components and systems

HEATING

Replace:

"The set point will be at 20 dg C daytime and 15 dg C night time. Set point will be ± 2 dg C. These set points are for heat load calculation, not for the summer ventilation calculation."

By:

The required greenhouse temperature set point will be adjustable, either at 10 dg C or 15 dg C, depending on research needs. Set point will be precise at ± 2 dg C. This set point is for heat load calculation, not for the summer ventilation calculation.

All other terms and conditions remain the same