



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

AMENDMENT / MODIFICATION

005

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
 Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
 Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Water and Wastewater Controls Replacement Prince Albert National Park		
Solicitation No. - No. de l'invitation 5P420-17-5122/A		Date: July 18, 2017
GETS Reference No. - No de reference de SEAG PW-17-00782424		Amendment No. - N° de la modif. 005
Solicitation Closes:		
at - à 02:00 PM	on - le July 20, 2017	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à :		
Jen Maheu		
Telephone No. - No de téléphone		Fax No. - No de FAX:
(403) 292-8502		(403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:		
See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Amendment 05

This amendment is being raised to distribute answers to bidder questions.

A) BIDDER QUESTIONS

Q3 We would like to propose the attached fibre optic cable as an alternate to the specified cable.

A3 Please bid as per specifications. Alternates may be considered for the successful bidder after contract award.

Q4 Amendment 1 states that trenches must be backfilled and tamped, and brought back to original surface condition. In the limited area for this trenching, we propose using a chain trencher with a 6" wide chain to keep the disturbance to a minimum, however this will not be possible to compact the ground in a 6" trench. Will this method be acceptable?

A4 Yes, 6" chain trenching is acceptable. Run wheels of tractor over filled-in trench for compaction. Prior to end of warranty period, fill in any trench areas that have settled.

Q5 Do you have a specific pull box make and model that should be used on this project?

A5 No. A suitable product is to be submitted with shop drawings for review.

Q6 Would an in-ground pull box be considered for this installation instead of the above ground post mounted type?

A6 No.

Q7 Please specify the method of attaching conduit to the tower leg that would be acceptable. We would propose using Hilti steel threaded studs, shot into the steel leg; is this acceptable?

A7 Yes, provided that the method does not compromise the corrosion protection on the steel.

Q8 Please specify where the power supply required in the compound building is to be fed from, for the ethernet radio and switch.

A8 The existing SCADA workstation receptacle is presently powered from a generator-supplied circuit. This circuit is to be intercepted in the ceiling space of the office and used to also power the 24Vdc power supply for the Ethernet radio and switch. The SCADA workstation is located on the S-W exterior wall of the office, rather than the East wall as indicated on the plan. If it is impractical to install a flush-mounted data outlet on the exterior wall, it can be located on the interior wall, and run the Ethernet cable to the PC in wiremold. The antenna location can be moved to better accommodate running of coax cable into office ceiling space, as discussed at site meeting.

Q9 Will the site meeting questions / responses, be issued in an amendment?

A9 Refer to Amendment 001.

All other terms and conditions remain unchanged.