

PART 1 - GENERAL

- 1.1 REFERENCES
- .1 Canada Green Building Council (CaGBC)
 - .1 LEED Canada-NC-2009, LEED (Leadership in Energy and Environmental Design): Green Building Rating System for New Construction and Major Renovations.
 - .2 CSA International
 - .1 CSA B111-1974(R2003), Wire Nails, Spikes and Staples.
 - .2 CSA O121-08, Douglas Fir Plywood.
 - .3 CSA O141-05(R2009), Softwood Lumber.
 - .4 CSA O151-0, Canadian Softwood Plywood.
 - .5 CAN/CSA-O325.0-07, Construction Sheathing.
 - .3 Forest Stewardship Council (FSC)
 - .1 FSC-STD-01-001-2004, FSC Principle and Criteria for Forest Stewardship.
 - .4 Green Seal Environmental Standards (GS)
 - .1 GS-11-11, Paints and Coatings.
 - .5 National Lumber Grades Authority (NLGA)
 - .1 Standard Grading Rules for Canadian Lumber 2010.
 - .6 South Coast Air Quality Management District (SCAQMD), California State, Regulation XI. Source Specific Standards
 - .1 SCAQMD Rule 1113-A2011, Architectural Coatings.
- 1.2 ACTION AND INFORMATIONAL SUBMITTALS
- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for rough carpentry work and include product characteristics, performance criteria, physical size, finish and limitations.
-

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Lumber: unless specified otherwise, softwood, S4S, moisture content 19% or less in accordance with following standards:
 - .1 CAN/CSA-0141.
 - .2 NLGA Standard Grading Rules for Canadian Lumber.
 - .3 FSC certified.

- .2 Furring, blocking, nailing strips, grounds, rough bucks, cants, curbs, fascia backing and sleepers:
 - .1 S2S is acceptable for all use.
 - .2 Board sizes: "Standard" or better grade.
 - .3 Dimension sizes: "Standard" light framing or better grade.
 - .4 Post and timbers sizes: "Standard" or better grade.

- .3 Panel Materials:
 - .1 Canadian softwood plywood (CSP): to CSA 0151, standard construction.
 - .1 Urea-formaldehyde free.

- .4 Wood Preservative:
 - .1 Surface-applied wood preservative: coloured, copper naphthenate or 5% pentachlorophenol solution, water repellent preservative.
 - .2 Pentachlorophenol use is restricted to building components that are in ground contact and subject to decay or insect attack only. Where used, pentachlorophenol-treated wood must be covered with two coats of an appropriate sealer.
 - .3 Structures built with wood treated with pentachlorophenol and inorganic arsenicals must not be used for storing food nor should the wood come in contact with drinking water.

- .5 Primers, Paints, Coatings: in accordance with manufacturer's recommendations for surface conditions.

2.2 ACCESSORIES

- .1 Fasteners: to CAN/CSA-G164, for exterior work and interior highly humid areas pressure-preservative lumber.
- .2 Nails, spikes and staples: to CSA B111.
- .3 Bolts: 12.5 mm diameter unless indicated otherwise, complete with nuts and washers.
- .4 Proprietary fasteners: toggle bolts, expansion shields and lag bolts, screws and lead or inorganic fibre plugs, explosive actuated fastening devices, recommended for purpose by manufacturer.
- .5 Fasteners for strapping to sheathing to structural steel studs; #10 x 100 mm long self-drilling/tapping screws with Robertson screw heads.
- .6 Fasteners for prefinished wood siding: to Specification Section No. 07 46 23.
- .7 Construction adhesive:
 - .1 Heavy duty, high grab, interior/exterior adhesive.
 - .2 Premium grade solvent - based material, to acceptance of Departmental Representative.

PART 3 - EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify conditions of substrates previously installed under other Sections or Contracts are acceptable for rough carpentry installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 PREPARATION

- .1 Treat surfaces of material with wood preservative, before installation.
- .2 Apply preservative by dipping, or by brush to completely saturate and maintain wet film on surface for minimum 3 minute soak on lumber and 1 minute soak on plywood.
- .3 Re-treat surfaces exposed by cutting, trimming or boring with liberal brush application of preservative before installation.
- .4 Treat material as follows:
 - .1 Wood cants, fascia backing, curbs, nailers, sleepers on roof deck.
 - .2 All wood furring on outside surface of exterior walls.
 - .3 Wood sleepers supporting wood subflooring over concrete slabs in contact with ground or fill.

3.3 INSTALLATION

- .1 Comply with requirements of NBC, supplemented by the following paragraphs.
 - .2 Install vertical wood strapping through plywood sheathing into structural steel studs using stainless steel screws @ 400 mm o.c. vertically.
 - .3 Install furring and blocking as required to space-out and support casework, cabinets, wall and ceiling finishes, facings, fascia, soffit, siding and other work as required.
 - .4 Align and plumb faces of furring and blocking to tolerance of 1:600.
 - .5 Install rough bucks, nailers and linings to rough openings as required to provide backing for frames and other work.
 - .6 Install wood cants, fascia backing, nailers, curbs and other wood supports as required and secure using galvanized steel fasteners.
-

- 3.3 INSTALLATION
(Cont'd)
- .7 Install wood backing, dressed, tapered and recessed slightly below top surface of roof insulation for roof hopper.
 - .8 Install sleepers as indicated.
 - .9 Frame, anchor, fasten, tie and brace members to provide necessary strength and rigidity.
 - .10 Countersink bolts where necessary to provide clearance for other work.
 - .11 For multi-layer plywood application:
 - .1 Secure layers to each other using construction adhesive applied in a serpentine manner using 8 mm diameter beads of adhesive at 300 mm o.c.
 - .2 Fasten assembled plywood to structural steel studs as per Section 05 41 00 - Structural Metal Stud Framing.

- 3.4 CLEANING
- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
 - .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
 - .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.