

PART 1 - GENERAL

1.1 REFERENCES

- .1 American Society of Mechanical Engineers (ASME)
 - .1 ASME B31.1-07, Power Piping.
- .2 ASTM International
 - .1 ASTM A 125-1996(2007), Standard Specification for Steel Springs, Helical, Heat-Treated.
 - .2 ASTM A 307-07b, Standard Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
 - .3 ASTM A 563-07a, Standard Specification for Carbon and Alloy Steel Nuts.
- .3 Canada Green Building Council (CaGBC)
 - .1 LEED Canada-NC-2009, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Package For New Construction and Major Renovations.
- .4 Factory Mutual (FM)
- .5 Manufacturer's Standardization Society of the Valves and Fittings Industry (MSS)
 - .1 MSS SP 58-2002, Pipe Hangers and Supports - Materials, Design and Manufacture.
 - .2 MSS SP 69-2003, Pipe Hangers and Supports - Selection and Application.
 - .3 MSS SP 89-2003, Pipe Hangers and Supports - Fabrication and Installation Practices.
- .6 Underwriter's Laboratories of Canada (ULC)

1.2 ACTION AND
INFORMATIONAL
SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Product Data:
 - .1 Provide manufacturer's printed product literature and data sheets for hangers and supports and include product characteristics, performance criteria, physical size, finish and limitations.
-

1.2 ACTION AND
INFORMATIONAL
SUBMITTALS
(Cont'd)

- .3 Shop Drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in the Province of Newfoundland and Labrador, Canada.
 - .2 Submit shop drawings for:
 - .1 Bases, hangers and supports.
 - .2 Connections to equipment and structure.
 - .3 Structural assemblies.
- .4 Certificates:
 - .1 Submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .5 Manufacturers' Instructions:
 - .1 Provide manufacturer's installation instructions.
 - .1 Departmental Representative will make available 1 copy of systems supplier's installation instructions.
- .6 Sustainable Design Submittals:
 - .1 LEED Canada-NC-2009 Submittals: in accordance with Section 01 35 21 - LEED Requirements.

1.3 CLOSEOUT
SUBMITTALS

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.4 DELIVERY,
STORAGE AND
HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements:
 - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse or return of pallets, crates, padding, banding, and packaging materials as specified

1.4 DELIVERY, STORAGE AND HANDLING <u>(Cont'd)</u>	.3 Packaging Waste Management: (Cont'd) in Construction Waste Management Plan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal and Section 01 35 21 - LEED Requirements.
---	--

PART 2 - PRODUCTS

2.1 SYSTEM DESCRIPTION <u> </u>	.1 Design Requirements: .1 Construct pipe hanger and support to manufacturer's recommendations utilizing manufacturer's regular production components, parts and assemblies. .2 Base maximum load ratings on allowable stresses prescribed by ASME B31.1 or MSS SP 58. .3 Ensure that supports, guides, anchors do not transmit excessive quantities of heat to building structure. .4 Design hangers and supports to support systems under conditions of operation, allow free expansion and contraction, prevent excessive stresses from being introduced into pipework or connected equipment. .5 Provide for vertical adjustments after erection and during commissioning. Amount of adjustment in accordance with MSS SP 58.
--	---

2.2 SUSTAINABLE REQUIREMENTS <u> </u>	.1 Materials and products in accordance with Section 01 35 21 - LEED Requirements.
--	---

2.3 GENERAL <u> </u>	.1 Fabricate hangers, supports and sway braces in accordance with MSS SP 58. ANSI B31.1 .2 Use components for intended design purpose only. Do not use for rigging or erection purposes.
--	--

2.4 PIPE HANGERS <u> </u>	.1 Finishes: .1 Pipe hangers and supports: galvanized after manufacture. .2 Use hot dipped galvanizing process.
---	--

2.4 PIPE HANGERS
(Cont'd)

- .1 Finishes: (Cont'd)
 - .3 Ensure steel hangers in contact with copper piping are epoxy coated.
 - .2 Upper attachment structural: suspension from lower flange of I-Beam:
 - .1 Cold piping NPS 2 maximum: malleable iron C-clamp with hardened steel cup point setscrew, locknut and carbon steel retaining clip.
 - .1 Rod: 13 mm FM approved.
 - .2 Cold piping NPS 2 1/2 or greater, hot piping: malleable iron beam clamp, eye rod, jaws and extension with carbon steel retaining clip, tie rod, nuts and washers, FM approved to MSS-SP 58.
 - .3 Upper attachment structural: suspension from upper flange of I-Beam:
 - .1 Cold piping NPS 2 maximum: ductile iron top-of-beam C-clamp with hardened steel cup point setscrew, locknut and carbon steel retaining clip, FM approved to MSS SP 69.
 - .2 Cold piping NPS 2 1/2 or greater, hot piping: malleable iron top-of-beam jaw-clamp with hooked rod, spring washer, plain washer and nut FM approved.
 - .4 Upper attachment to concrete:
 - .1 Ceiling: carbon steel welded eye rod, clevis plate, clevis pin and cotters with weldless forged steel eye nut. Ensure eye 6 mm minimum greater than rod diameter.
 - .2 Concrete inserts: wedge shaped body with knockout protector plate FM approved to MSS SP 69.
 - .5 Shop and field-fabricated assemblies:
 - .1 Trapeze hanger assemblies.
 - .2 Steel brackets.
 - .6 Hanger rods: threaded rod material to MSS SP 58:
 - .1 Ensure that hanger rods are subject to tensile loading only.
 - .2 Provide linkages where lateral or axial movement of pipework is anticipated.
 - .3 Do not use 22 mm or 28 mm rod.
-

- 2.4 PIPE HANGERS
(Cont'd)
- .7 Pipe attachments: material to MSS SP 58:
 - .1 Attachments for steel piping: carbon steel galvanized.
 - .2 Use insulation shields for hot pipework.
 - .3 Oversize pipe hangers and supports.
 - .8 Adjustable clevis: material to MSS SP 69 FM approved, clevis bolt with nipple spacer and vertical adjustment nuts above and below clevis.
 - .1 Ensure "U" has hole in bottom for rivetting to insulation shields.
 - .9 Yoke style pipe roll: carbon steel yoke, rod and nuts with cast iron roll, to MSS SP 69.
 - .10 U-bolts: carbon steel to MSS SP 69 with 2 nuts at each end to ASTM A 563.
 - .1 Finishes for steel pipework: galvanized.
 - .11 Pipe rollers: cast iron roll and roll stand with carbon steel rod to MSS SP 69.
- 2.5 RISER CLAMPS
- .1 Steel: galvanized carbon steel to MSS SP 58, type 42, FM approved.
 - .2 Copper pipe: carbon steel copper plated to MSS SP 58, type 42.
 - .3 Bolts: to ASTM A 307.
 - .4 Nuts: to ASTM A 563.
- 2.6 INSULATION
PROTECTION SHIELDS
- .1 Insulated cold piping:
 - .1 4 kg/m³ density insulation plus insulation protection shield to: MSS SP 69, galvanized sheet carbon steel. Length designed for maximum 3 m span.
 - .2 Insulated hot piping:
 - .1 Curved plate 300 mm long, with edges turned up, welded-in centre plate for pipe sizes NPS 12 and over, carbon steel to comply with MSS SP 69.
-

2.7 CONSTANT
SUPPORT SPRING
HANGERS

- .1 Springs: alloy steel to ASTM A 125, shot peened, magnetic particle inspected, with +/-5% spring rate tolerance, tested for free height, spring rate, loaded height and provided with Certified Mill Test Report (CMTR).
- .2 Load adjustability: 10% minimum adjustability each side of calibrated load. Adjustment without special tools. Adjustments not to affect travel capabilities.
- .3 Provide upper and lower factory set travel stops.
- .4 Provide load adjustment scale for field adjustments.
- .5 Total travel to be actual travel + 20%. Difference between total travel and actual travel 25 mm minimum.
- .6 Individually calibrated scales on each side of support calibrated prior to shipment, complete with calibration record.

2.8 VARIABLE
SUPPORT SPRING
HANGERS

- .1 Vertical movement: 13 mm minimum, 50 mm maximum, use single spring pre-compressed variable spring hangers.
 - .2 Vertical movement greater than 50 mm: use double spring pre-compressed variable spring hanger with 2 springs in series in single casing.
 - .3 Variable spring hanger complete with factory calibrated travel stops. Provide certificate of calibration for each hanger.
 - .4 Steel alloy springs: to ASTM A 125, shot peened, magnetic particle inspected, with +/-5 % spring rate tolerance, tested for free height, spring rate, loaded height and provided with CMTR.
-

2.9 EQUIPMENT SUPPORTS .1 Fabricate equipment supports not provided by equipment manufacturer from structural grade steel meeting requirements of Section 05 12 23 - Structural Steel for Buildings. Submit calculations with shop drawings.

2.10 EQUIPMENT ANCHOR BOLTS AND TEMPLATES .1 Provide templates to ensure accurate location of anchor bolts.

2.11 HOUSE-KEEPING PADS .1 Provide 100 mm high concrete housekeeping pads for base-mounted equipment; size pads 50 mm larger than equipment; chamfer pad edges.
.2 Concrete: to Section 03 30 00 - Cast-in-Place Concrete.

2.12 OTHER EQUIPMENT SUPPORTS .1 Fabricate equipment supports from structural grade steel meeting requirements of Section 05 12 23 - Structural Steel for Buildings.
.2 Submit structural calculations with shop drawings.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION .1 Install in accordance with:
.1 Manufacturer's instructions and recommendations.
.2 Vibration Control Devices:
.1 Install on piping systems at pumps and other equipment as required.

3.2 INSTALLATION
(Cont'd)

- .3 Clamps on riser piping:
 - .1 Support independent of connected horizontal pipework using riser clamps and riser clamp lugs welded to riser.
 - .2 Bolt-tightening torques to industry standards.
 - .3 Steel pipes: install below coupling or shear lugs welded to pipe.
 - .4 Cast iron pipes: install below joint.
- .4 Clevis plates:
 - .1 Attach to concrete with 4 minimum concrete inserts, one at each corner.
- .5 Provide supplementary structural steelwork where structural bearings do not exist or where concrete inserts are not in correct locations.
- .6 Use approved constant support type hangers where:
 - .1 Vertical movement of pipework is 13 mm or more,
 - .2 Transfer of load to adjacent hangers or connected equipment is not permitted.
- .7 Use variable support spring hangers where:
 - .1 Transfer of load to adjacent piping or to connected equipment is not critical.
 - .2 Variation in supporting effect does not exceed 25 % of total load.

3.3 HANGER SPACING

- .1 Plumbing piping: to Canadian Plumbing Code.
 - .2 Fire protection: to applicable fire code.
 - .3 Gas and fuel oil piping: up to NPS 1/2: every 1.8 m.
 - .4 Flexible joint roll groove pipe: in accordance with table below for steel, but not less than one hanger at joints. Table listings for straight runs without concentrated loads and where full linear movement is not required.
 - .5 Within 300 mm of each elbow.
-

3.3 HANGER SPACING .5 (Cont'd)

Maximum Pipe Size : NPS	Maximum Spacing Steel	Copper
up to 1-1/4	2.4 m	
1-1/2	3.0 m	
2	3.0 m	
2-1/2	3.7 m	
3	3.7 m	
3-1/2	3.7 m	
4	3.7 m	
5	4.3 m	
6	4.3 m	
8	4.3 m	
10	4.9 m	
12	4.9 m	

- 3.4 HANGER INSTALLATION
- .1 Install hanger so that rod is vertical under operating conditions.
 - .2 Adjust hangers to equalize load.
 - .3 Support from structural members. Where structural bearing does not exist or inserts are not in suitable locations, provide supplementary structural steel members.

- 3.5 HORIZONTAL MOVEMENT
- .1 Angularity of rod hanger resulting from horizontal movement of pipework from cold to hot position not to exceed 4 degrees from vertical.
 - .2 Where horizontal pipe movement is less than 13 mm, offset pipe hanger and support so that rod hanger is vertical in the hot position.

- 3.6 FINAL ADJUSTMENT
- .1 Adjust hangers and supports:
 - .1 Ensure that rod is vertical under operating conditions.
 - .2 Equalize loads.

- 3.6 FINAL
ADJUSTMENT
(Cont'd)
- .2 Adjustable clevis:
.1 Tighten hanger load nut securely to ensure proper hanger performance.
.2 Tighten upper nut after adjustment.
- .3 C-clamps:
.1 Follow manufacturer's recommended written instructions and torque values when tightening C-clamps to bottom flange of beam.
- .4 Beam clamps:
.1 Hammer jaw firmly against underside of beam.
- 3.7 FIELD QUALITY
CONTROL
- .1 Verification requirements in accordance with Section 01 35 21 - LEED Requirements, include:
.1 Materials and resources.
.2 Storage and collection of recyclables.
.3 Construction waste management.
.4 Resource reuse.
.5 Recycled content.
.6 Local/regional materials.
.7 Certified wood.
.8 Low-emitting materials.
- 3.8 CLEANING
- .1 Clean in accordance with Section 01 74 11 - Cleaning.
.1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal and Section 01 35 21 - LEED Requirements.