

PART 1 - GENERAL

- 1.1 RELATED REQUIREMENTS
- .1 Section 31 23 33.01 - Excavating, Trenching and Backfilling.
  - .2 Section 33 05 16 - Maintenance Holes and Catch Basin Structures.
- 1.2 REFERENCES
- .1 ASTM International
    - .1 ASTM D 698-07e1, Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Standard Effort (12,400 ft-lbf/ft<sup>3</sup> (600 kN-m/m<sup>3</sup>)).
  - .2 Canada Green Building Council (CaGBC)
    - .1 LEED Canada-NC-2009, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Package For New Construction and Major Renovations.
  - .3 CSA International
    - .1 CAN/CSA-B1800-06, Thermoplastic Non-pressure Pipe Compendium - B1800 Series.
  - .4 Washington State Department of Ecology.
    - .1 Stormwater Management Manual for Western Washington, Volume II, Construction Pollution Prevention (2015 edition).
  - .5 Newfoundland and Labrador Department of Municipal Affairs.
    - .1 Municipal Water, Sewer and Roads Construction Specifications, latest revisions.
  - .6 National Association of Sewer Services Companies (NASSCO) Performance Specification Guidelines.
- 1.3 SCHEDULING
- .1 Schedule Work to minimize interruptions to existing services and to maintain existing flow during construction.
  - .2 Submit schedule of expected interruptions for approval and adhere to approved schedule.
-

- 1.4 ACTION AND INFORMATIONAL SUBMITTALS
- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Product Data:
    - .1 Submit manufacturer's instructions, printed product literature and data sheets for pipes, and backfill and include product characteristics, performance criteria, physical size, finish and limitations.
    - .3 Shop Drawings:
      - .1 Shop drawings to indicate proposed method for installing carrier pipe for undercrossings.
      - .2 Submit drawings stamped and signed by professional engineer registered or licensed in the Province of Newfoundland and Labrador, Canada.
    - .4 Samples:
      - .1 Inform Departmental Representative at least 4 weeks prior to beginning Work, of proposed source of bedding materials and provide access for sampling.
      - .2 Submit to Departmental Representative for testing, at least 2 weeks prior to beginning Work, following samples of materials proposed for use: pipe bedding and surround material.
  - .5 Certification to be marked on pipe.
  - .6 Test and Evaluation Reports: submit manufacturer's test data and certification at least 2 weeks prior to beginning Work.
  - .7 Manufacturer's Instructions: submit to Departmental Representative 1 copy of manufacturer's installation instructions.
  - .8 Sustainable Design Submittals:
    - .1 LEED Canada Submittals: in accordance with Section 01 35 21 - LEED Requirements.
    - .2 Erosion and Sedimentation Control: submit copy of erosion and sedimentation control plan in accordance with EPA 832/R-92-2005, authorities having jurisdiction and Section 01 35 21 - LEED Requirements.
-



- 1.5 DELIVERY,  
STORAGE AND  
HANDLING  
(Cont'd)
- .4 (Cont'd)  
accordance with Section 01 35 21 - LEED  
Requirements.
- .5 Packaging Waste Management: remove for reuse  
or return of pallets, crates, padding,  
banding, and packaging materials as specified  
in Construction Waste Management Plan in  
accordance with Section 01 74 21 -  
Construction/Demolition Waste Management and  
Disposal and Section 01 35 21 - LEED  
Requirements.

PART 2 - PRODUCTS

- 2.1 PLASTIC PIPE .1 Type PSM Poly Vinyl Chloride (PVC): to  
CAN/CSA-B1800.  
.1 Standard Dimensional Ratio (SDR): 35.  
.2 Locked-in gasket and integral bell  
system.  
.3 Nominal lengths: 6 m.
- 2.2 PIPE BEDDING  
AND SURROUND  
MATERIAL .1 Type 1 bedding in accordance with Section  
02223 of the Newfoundland and Labrador  
Municipal Water, Sewer and Roads Master  
Construction Specifications.
- 2.3 BACKFILL  
MATERIAL .1 Type 3 fill in accordance with Section 31 23  
33.01 - Excavating, Trenching and Backfilling.
- 2.4 GROUT .1 Non-shrink grout to Section 33 05 16 -  
Maintenance Holes and Catch Basin Structures.
- 2.5 MARKER TAPE .1 Detectable underground marker tape with  
aluminum backing. Yellow in colour and marked  
"CAUTION BURIED SEWER LINE BELOW".
-

PART 3 - EXECUTION

- 3.1 PREPARATION .1 Temporary Erosion and Sedimentation Control:
- .1 Provide temporary erosion and sedimentation control measures to prevent soil erosion and discharge of soil-bearing water runoff or airborne dust to adjacent properties and walkways, according to sediment and erosion control drawings.
  - .2 Inspect, repair, and maintain erosion and sedimentation control measures during construction until permanent vegetation has been established.
  - .3 Remove erosion and sedimentation controls and restore and stabilize areas disturbed during removal.
- .2 Clean pipes and fittings of debris and water before installation, and remove defective materials from site to approval of Departmental Representative.
- 3.2 TRENCHING .1 Do trenching Work in accordance with Section 31 23 33.01 - Excavating, Trenching and Backfilling.
- .2 Protect trench from contents of sewer.
  - .3 Trench alignment and depth to approval of Departmental Representative prior to placing bedding material and pipe.
- 3.3 GRANULAR BEDDING .1 Place bedding in unfrozen condition.
- .2 Place granular bedding material in uniform layers not exceeding 150 mm compacted thickness to depth as indicated.
  - .3 Shape bed true to grade and to provide continuous, uniform bearing surface for pipe.
    - .1 Do not use blocks when bedding pipes.
  - .4 Shape transverse depressions as required to suit joints.
-

- 3.3 GRANULAR BEDDING  
(Cont'd)
- .5 Compact each layer full width of bed to at least 95 % maximum density to ASTM D 698.
  - .6 Fill excavation below bottom of specified bedding adjacent to manholes or catch basins with compacted bedding material.
- 3.4 INSTALLATION
- .1 Lay and join pipe in accordance with manufacturer's recommendations and to approval of Departmental Representative.
  - .2 Handle pipe using methods approved by Departmental Representative.
    - .1 Do not use chains or cables passed through rigid pipe bore so that weight of pipe bears upon pipe ends.
  - .3 Lay pipes on prepared bed, true to line and grade with pipe inverts smooth and free of sags or high points.
    - .1 Ensure barrel of each pipe is in contact with shaped bed throughout its full length.
  - .4 Begin laying at outlet and proceed in upstream direction with socket ends of pipe facing upgrade.
  - .5 Joint deflection permitted within limits recommended by pipe manufacturer.
  - .6 Water to flow through pipes during construction only as permitted by Departmental Representative.
  - .7 Whenever Work is suspended, install removable watertight bulkhead at open end of last pipe laid to prevent entry of foreign materials.
  - .8 Install plastic pipe and fittings in accordance with CAN/CSA-B1800.
  - .9 When any stoppage of Work occurs, restrain pipes as directed by Departmental Representative, to prevent "creep" during down time.
  - .10 Cut pipes as required for special inserts, fittings or closure pieces, as recommended by
-

- 3.4 INSTALLATION .10 (Cont'd)  
(Cont'd) pipe manufacturer, without damaging pipe or its coating and to leave smooth end at right angles to axis of pipe.
- .11 Make watertight connections to manholes and catch basins.  
.1 Use shrinkage compensating grout when suitable gaskets are not available.
- .12 Temporarily plug open upstream ends of pipes with removable watertight concrete, steel or plastic bulkheads.
- 
- 3.5 PIPE SURROUND .1 Place surround material in unfrozen condition.
- .2 Upon completion of pipe laying, and after Departmental Representative has inspected pipe joints, surround and cover pipes as indicated.  
.1 Leave joints and fittings exposed until field testing is completed.
- .3 Hand place surround material in uniform layers not exceeding 150 mm compacted thickness as indicated.  
.1 Do not dump material within 1m of pipe.
- .4 Place layers uniformly and simultaneously on each side of pipe.
- .5 Compact each layer from pipe invert to mid height of pipe to at least 95 % maximum density to ASTM D 698.
- .6 Compact each layer from mid height of pipe to underside of backfill to at least 90 % maximum density to ASTM D 698.
- .7 When field test results are acceptable to Departmental Representative, place surround material at pipe joints.
-

- 3.6 BACKFILL
- .1 Place backfill material in unfrozen condition.
  - .2 Place backfill material, above pipe surround, in uniform layers not exceeding 150 mm compacted thickness up to grades as indicated.
  - .3 Under paving and walks, compact backfill to at least 95 % maximum density to ASTM D 698. In other areas, compact backfill to at least 90 % maximum density to ASTM D 698.
  - .4 Install marker tape as indicated.
- 3.7 TESTING
- .1 Inspection and testing of pipe bedding, surround and backfill material will be carried out by independent inspection and testing agency designated by Departmental Representative. Costs of these tests will be paid by Contractor in accordance with Sections 01 29 83 - Payment Procedures for Testing Laboratory Services and 01 45 00 - Quality Control.
- 3.8 FIELD TESTS AND INSPECTIONS
- .1 Repair or replace pipe, pipe joint or bedding found defective.
  - .2 Remove foreign material from sewers and related appurtenances by flushing with water.
- 3.9 DEFLECTION TESTING
- .1 Measure deflection of each plastic pipe, by pulling a deflection gauge through each pipe from end to end after backfilling.
  - .2 Provide deflection gauges to measure a 5% and 7 1/2% deflection. Gauges to be a "Go-No-Go" mandrel device. The device shall meet the requirements of the pipe manufacturer and shall be subject to the approval of the Departmental Representative.
  - .3 Within thirty days after installation, pull a deflection gauge measuring 5% deflection through the installed section of pipeline. If
-

3.9 DEFLECTION .3 (Cont'd)  
TESTING this test fails, proceed with 7 1/2%  
(Cont'd) deflection test. If 7 1/2% deflection test  
fails, locate defect and repair. Retest using  
same methodology.

.4 Provide deflection test report.

3.10 CLOSED CIRCUIT .1 Conduct closed circuit television inspection  
TELEVISION procedures to meet National Association of  
INSPECTION Sewer Services Companies (NASSCO) Performance  
Specification Guidelines.

.2 Equipment:

.1 Provide equipment meeting following  
requirements:

.1 Self-contained, self-leveling  
monitoring unit and pan-tilt camera with  
remotely controlled lighting system  
capable of varying the illumination.

.2 Picture quality shall produce  
continuous 600-line resolution picture,  
showing entire periphery of pipe.

.3 A meter device with readings above  
ground or marking on cable to clearly  
identify exact location of camera.

.3 Inspection:

.1 Perform inspection of pipe from manhole  
to manhole by passing TV camera through sewer  
in direction of flow.

.2 Classify results in accordance with  
National Association of Sewer Service  
Companies (NASSCO) Performance Specification  
Guidelines.

.4 Records:

.1 Maintain inspection record in log form,  
during television inspection.

.2 Log to include location of each fault  
and service lateral distance measured from  
centreline of reference manhole and position  
referenced to axis of pipe.

.3 Photograph fault from the television  
screen. All photographs to be clear and  
precise with distinct definition of fault.

---

- 3.10 CLOSED CIRCUIT .4  
TELEVISION  
INSPECTION  
(Cont'd)
- 
- Records: (Cont'd)
- .4 Include detailed technical description with photographs as supporting data for each fault.
  - .5 Provide minimum of two (2) photographs for each sewer main section televised, detailing typical joint, and typical building service lateral.
  - .6 All photos and videos to be in colour.
- .5 Reports:
- .1 Provide a composite report of TV inspection. Enclose report in binder on letter-size paper. Include following pages and information:
    - .1 Title page identifying project, camera operator and dates of inspection.
    - .2 Index page identifying section from manhole to manhole, page number or numbers where information for section is contained.
  - .2 Organize inspection records in sequence from upstream; manhole to downstream manhole.
  - .3 Report on each sewer main section to contain:
    - .1 Heading:
      - .1 Manhole numbers applicable to section.
      - .2 Reference drawing number, if applicable.
      - .3 Weather on the day of inspection.
      - .4 Statement of soil condition in area of inspection, i.e. dry. damp, wet, frozen.
    - .4 Key Plan, showing corresponding manhole numbers, magnetic north, horizontal distance, pipe and material between manholes, and direction of flow.
    - .5 Inspection findings for each sewer main section to include:
      - .1 Location of all faults.
      - .2 Photographs of all faults.
      - .3 Location of all service laterals.
      - .4 One photograph each of typical joint and typical service lateral when faults are not found.
    - .6 Mount photographs on left-hand page and place corresponding description on right-hand page. Number all photographs in order. Number

- 3.10 CLOSED CIRCUIT .5 Reports: (Cont'd)  
TELEVISION .6 (Cont'd)  
INSPECTION beside photograph to correspond with  
(Cont'd) description number.  
.7 Enclose all pages of report in  
transparent sheet protector.
- .6 Accuracy:  
.1 Maximum permissible error in accuracy to  
be within following limits of fault location:  
.1 Up to 375 mm pipe: ± 75 mm per  
100 m of length.  
.2 450 mm - 600 mm pipe: ± 150 mm per  
100 m of length.  
.3 750 mm - 900 mm pipe: ± 225 mm per  
100 m of length.
- .7 Video Record:  
.1 Supply a complete record of all  
inspections in digital format.  
.2 Index all files, listing sections of  
inspections.  
.3 Submit DVD with written reports to  
Departmental Representative.
- .8 Repeat Inspection:  
.1 Prior to repairs, the methods are to be  
approved by the Departmental Representative.  
Repair faults detected during television  
inspection. Repeat television inspection at no  
cost to Owner.
- 3.11 CLEANING .1 Progress Cleaning: clean in accordance with  
Section 01 74 11 - Cleaning.  
.1 Leave Work area clean at end of each  
day.
- .2 Final Cleaning: upon completion remove  
surplus materials, rubbish, tools and  
equipment in accordance with Section 01 74 11  
- Cleaning.
- .3 Waste Management: separate waste materials  
for reuse and recycling in accordance with  
Section 01 74 21 - Construction/Demolition
-

- 3.11 CLEANING  
(Cont'd)
- .3 Waste Management:(Cont'd)  
Waste Management and Disposal and Section  
01 35 21 - LEED Requirements.  
.1 Remove recycling containers and bins  
from site and dispose of materials at  
appropriate facility.