1 M5.1 SPRINKLER LAYOUT
1:125

GENERAL NOTES:

1. SPRINKLER SYSTEM INSTALLATION SHALL STRICTLY CONFORM WITH NFPA 13 AND ALL AUTHORITIES HAVING JURISDICTION.
2. ALL PIPE LOCATIONS TO BE MEASURED ON SITE BY THE FIRE PROTECTION CONTRACTOR PRIOR TO FABRICATION AND INSTALLATION.
3. ALL DIMENSIONS SHOWN ARE CENTER TO CENTER.
4. SPRINKLER MAINS, BRANCHLINES ROUTING AND FINAL LOCATIONS AND HEIGHT OF SPRINKLER HEADS TO BE COORDINATED TO THE EXISTING LOCATIONS OF MECHANICAL EQUIPMENTS AND ROUTING OF DUCTS BY THE FIRE PROTECTION CONTRACTOR.
5. WHERE CEILING HEIGHTS ARE CHANGED, RELOCATE ALL SERVICES AND EQUIPMENT TO SUIT ADJUSTED CEILING HEIGHT. REFER TO ARCHITECTURAL DRAWINGS.
6. ALL SPRINKLER HEADS TO BE REMOVED/RELOCATED SHALL BE REPLACED WITH NEW SPRINKLER HEADS.
7. FIRE EXTINGUISHER TO BE 10lbs. IN CABINET OR WALL MOUNTED SUPPLIED BY OWNER. CONFIRM WITH ARCHITECT OR OWNER FOR INSTALLATION REQUIREMENT.
8. CAP-OFF ALL SPRINKLER PIPING WHERE SPRINKLER HEADS TO BE DEMOLISHED AND SPRINKLER PIPING THAT WILL NOT BE UTILIZED.

DRAWING KEYNOTES:

1. EXISTING FIRE EXTINGUISHER TO BE RELOCATED.
2. NEW LOCATION FIRE EXTINGUISHER
3. NEW 10 LBS. ABC TYPE FIRE EXTINGUISHER. COORDINATE WITH ARCHITECT TYPE OF INSTALLATION.
4. EXISTING FIRE EXTINGUISHER TO REMAIN.

Public Works and Government Services Canada
Travaux publics et Services gouvernementaux Canada
REAL PROPERTY SERVICES
Western Region
SERVICES IMMOBILIERS
Région de l'ouest

REPUBLIC ARCHITECTURE INC
374 Donald Street, First Floor
Winnipeg, MB R3B 2J2
T 204 989 0102
F 204 989 0094
www.republicarchitecture.ca

HDK CONSULTING INCORPORATED
2633 Portage Avenue
Winnipeg, Manitoba
Canada, R3J 0P7
T: 204.818.0390
F: 204.818.0388
www.hdkconsulting.com
info@hdkconsulting.com
Mechanical|Electrical|Communications|Security Engineering

REGISTERED PROFESSIONAL ENGINEER
D.A. HO
LICENSEE
NT/NU

PERMIT TO PRACTICE
HDK CONSULTING INCORPORATED
Signature
Date May 19/17
PERMIT NUMBER: P 1060
NT/NU Association of Professional Engineers and Geoscientists

Revision	Description	Date
5		
4		
3	ISSUED FOR CONSTRUCTION	May 19, 2017
2	ISSUED FOR REVIEW 99% CONSTRUCTION DOCUMENTS	Apr. 25, 2017
1	66% CD SUBMISSION	Feb. 24, 2017
0	DESIGN DEVELOPMENT SUBMISSION	Jan. 20, 2017

Client / client
PSPC/SPAC
5th Floor, 10025 Jasper Avenue
Edmonton. AB

Project title / Projet
5101 50th Avenue
Yellowknife, NWT

4th Floor Tenant Fit-Up
Greenstone Building

Designed by / Conçu par: **PA**
Drawn by / Dessiné par: **FD**
Approved by / Approuvé par: **DH**
PWGSC Project Manager / Administrateur de Projets TPSGC: **Brenda Embury**

Drawing title / Titre du dessin
SPRINKLER LAYOUT

Project no./No. du projet	Drawing no./No. du dessin	Revision no.
R.060383	M5.1 OF 12	3

PWGSC – A1 – 841X594
0 10 20 30 40 50 60 70 80 90 100mm
M5.1