



#### GENERAL NOTES:

- DO NOT SCALE THIS DRAWING. CONTRACTOR SHALL VERIFY ALL DIMENSIONS PRIOR TO INSTALLATION AND REPORT ANY DISCREPANCY TO THE DEPARTMENTAL REPRESENTATIVE.
- THE DRAWING ONLY SHOWS A GENERAL SCHEMATIC OF NEW SYSTEMS. ROUTING OF DUCTWORK AND UNITS LOCATIONS SHALL SUIT SITE CONDITIONS AND MAY HAVE TO BE CHANGED TO AVOID CONFLICTS WITH STRUCTURE, DUCTS AND PIPES. WHEN CONFLICT CANNOT BE AVOIDED, THE DUCTWORK SHALL BE MODIFIED AS REQUIRED.
- CONTRACTOR SHALL INCLUDE FOR AND PROVIDE ALL COORDINATION BETWEEN TRADES AND CONSULTANT ON AND OFF SITE AS REQUIRED FOR INSTALLATION OF MECHANICAL AND ELECTRICAL SYSTEMS, WHERE MINOR REROUTING OF DUCTWORK OR SERVICES IS REQUIRED DUE TO ONSITE CONDITIONS, IT SHALL BE PERFORMED AT NO ADDITIONAL COST.
- COORDINATE ALL GRILLE AND DIFFUSER LOCATIONS WITH LIGHTING LAYOUT.
- CONFORM TO SPECIFICATIONS AND MANUFACTURER GUIDES FOR MATERIALS AND UNITS' INSTALLATION DETAILS.

#### DRAWING NOTES:

- DEMOLISH BACK EXHAUST DIFFUSER AND BRANCH DUCT TO THIS POINT.
- PREPARE AND MODIFY FOR NEW DUCT CONNECTION. REFER TO DRAWING NEW CEILING HVAC LAYOUT FOR NEW LOCATION.
- EXISTING GRILLE TO BE RELOCATED INTO NEW EX-1 OFFICE. EXTEND GRILLE INTO ROOM WITH RIGID DUCTWORK. REFER TO DRAWING NEW CEILING HVAC LAYOUT FOR NEW LOCATION.
- EXISTING GRILLE TO BE RELOCATED INTO THE NEW BULKHEAD. REFER TO DRAWING NEW CEILING HVAC LAYOUT FOR NEW LOCATION.
- EXISTING GRILLES TO REMAIN. TYPICAL.

## REPUBLIC ARCHITECTURE INC

374 Donald Street, First Floor  
Winnipeg, MB R3B 2J2

T 204 989 0102

F 204 989 0094

[www.republicarchitecture.ca](http://www.republicarchitecture.ca)

**HDK**  
HDK CONSULTING  
INCORPORATED  
2633 Portage Avenue  
Winnipeg, Manitoba  
Canada, R3J 0P7  
T: 204.818.0390  
F: 204.818.0388  
[www.hdkconsulting.com](http://www.hdkconsulting.com)  
info@hdkconsulting.com  
Mechanical | Electrical | Communications | Security Engineering



PERMIT TO PRACTICE  
HDK CONSULTING INCORPORATED  
Signature: *Daniel P. Ho*  
Date: *May 19, 2017*  
PERMIT NUMBER: P 1060  
NT/NU Association of Professional  
Engineers and Geoscientists

Revision	Description	Date
5		
4		
3	ISSUED FOR CONSTRUCTION	May 18, 2017
2	ISSUED FOR REVIEW 99% CONSTRUCTION DOCUMENTS	Apr. 25, 2017
1	66% CD SUBMISSION	Feb. 24, 2017
0	DESIGN DEVELOPMENT SUBMISSION	Jan. 20, 2017

Client: client

#### PSPC/SPAC

5th Floor, 10025 Jasper Avenue  
Edmonton. AB

Project title: Project

5101 50th Avenue  
Yellowknife, NWT

4th Floor Tenant Fit-Up  
Greenstone Building

Designed by: Conçu par

PA

Drawn by: Dessiné par

FD

Approved by: Approuvé par

DH

PWGSC Project Manager: Administrateur de Projets TPSGC

Brenda Embury

Drawing title: Titre du dessin

EXISTING CEILING  
HVAC LAYOUT

Project no./No. du projet: Drawing no./No. du dessin: Revision no.

R.060383

M1.1

3

OF 12