



GENERAL NOTES:

- DO NOT SCALE THIS DRAWING. CONTRACTOR SHALL VERIFY ALL DIMENSIONS PRIOR TO INSTALLATION AND REPORT ANY DISCREPANCY TO THE DEPARTMENTAL REPRESENTATIVE.
- THE DRAWING ONLY SHOWS A GENERAL SCHEMATIC OF NEW SYSTEMS. ROUTING OF DUCTWORK AND UNITS LOCATIONS SHALL SUIT SITE CONDITIONS AND MAY HAVE TO BE CHANGED TO AVOID CONFLICTS WITH STRUCTURE, DUCTS AND PIPES. WHEN CONFLICT CANNOT BE AVOIDED, THE DUCTWORK SHALL BE MODIFIED AS REQUIRED.
- CONTRACTOR SHALL INCLUDE FOR AND PROVIDE ALL COORDINATION BETWEEN TRADES AND CONSULTANT ON AND OFF SITE AS REQUIRED FOR INSTALLATION OF MECHANICAL AND ELECTRICAL SYSTEMS, WHERE MINOR REROUTING OF DUCTWORK OR SERVICES IS REQUIRED DUE TO ONSITE CONDITIONS, IT SHALL BE PERFORMED AT NO ADDITIONAL COST.
- COORDINATE ALL GRILLE AND DIFFUSER LOCATIONS WITH FURNITURE LAYOUT.
- CONFORM TO SPECIFICATIONS AND MANUFACTURER GUIDES FOR MATERIALS AND UNITS' INSTALLATION DETAILS.

DRAWING NOTES:

- EXISTING FAN COIL THERMOSTAT AND ASSOCIATED WIRING TO BE REMOVED. FAN COIL CONTROL WILL BE BASED ON NEW TERMINAL UNIT THERMOSTATS.
- THERMOSTAT TO BE RELOCATED. EXTEND WIRING AS REQUIRED. REFER TO NEW RAISED FLOOR HVAC LAYOUT FOR NEW LOCATION OF THERMOSTAT.
- EXISTING THERMOSTAT TO REMAIN.
- RELOCATE EXISTING 200mm ROUND FLOOR DIFFUSERS TO SUIT NEW ROOM LAYOUT. REFER TO RAISED FLOOR - NEW LAYOUT FOR RECOMMENDED LOCATION OF ROUND FLOOR DIFFUSERS. INFORM THE ENGINEER FOR ANY DISCREPANCIES.

REPUBLIC  
ARCHITECTURE  
INC

374 Donald Street, First Floor  
Winnipeg, MB R3B 2J2

T 204 989 0102

F 204 989 0094

www.republicarchitecture.ca

HDK CONSULTING  
INCORPORATED  
2633 Portage Avenue  
Winnipeg, Manitoba  
Canada, R3J 0P7  
T: 204.818.0390  
F: 204.818.0388  
www.hdkconsulting.com  
info@hdkconsulting.com  
Mechanical | Electrical | Communications | Security Engineering



PERMIT TO PRACTICE  
HDK CONSULTING INCORPORATED  
Signature *Daniel Z...*  
Date *May 19/17*  
PERMIT NUMBER: P 1060  
NT/NU Association of Professional  
Engineers and Geoscientists

5		
4		
3	ISSUED FOR CONSTRUCTION	May 19, 2017
2	ISSUED FOR REVIEW 99% CONSTRUCTION DOCUMENTS	Apr. 25, 2017
1	66% CD SUBMISSION	Feb. 24, 2017
0	DESIGN DEVELOPMENT SUBMISSION	Jan. 20, 2017
Revision	Description	Date
Client		client

PSPC/SPAC

5th Floor, 10025 Jasper Avenue  
Edmonton, AB

Project title  
5101 50th Avenue  
Yellowknife, NWT

4th Floor Tenant Fit-Up  
Greenstone Building

Designed by PA	Conçu par
Drawn by FD	Dessiné par
Approved by DH	Approuvé par
PWGSC Project Manager Brenda Embury	Administrateur de Projets TPSGC
Drawing title	Titre du dessin

EXISTING RAISED FLOOR  
HVAC LAYOUT

Project no./No. du projet	Drawing no./No. du dessin	Revision no.
R.060383	M1.2 OF 12	3