



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A :**

Bid Receiving/Réception des sousmissions
Procurement & Contracting Services
c/o Commissionaires, F Division
6101 Dewdney Ave
Regina, SK S4P 3K7

Fax No. - No de FAX:
(306) 780-5232

**SOLICITATION
AMENDMENT**

**MODIFICATION DE
L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments: - Commentaries :

THIS DOCUMENT DOES NOT CONTAIN A SECURITY REQUIREMENT

LE PRÉSENT DOCUMENT NE COMPORTE PAS UNE EXIGENCE EN MATIÈRE DE SÉCURITÉ

Title – Sujet: Fire Alarm Monitoring, Multiple Locations Across Alberta		Date : July 20, 2017
Solicitation No. – N° de l'invitation M5000-18-0128/A – PW-17-00782661		Amendment No. – N° de la modification 002
Client Reference No. - No. De Référence du Client 201800128		
Solicitation Closes – L'invitation prend fin		
At / à :	2 :00 PM	CST (Central Standard Time) HNC (Heure Normale du Centre)
On / le :	August 8, 2017	
Incoterms 2010 "DDP Delivered Duty Paid" See herein — Voir aux présentes	GST – TPS See herein — Voir aux présentes	Duty – Droits See herein — Voir aux présentes
Destination of Goods and Services – Destinations des biens et services See herein — Voir aux présentes		
Instructions See herein — Voir aux présentes		
Address Inquiries to – Adresser toute demande de renseignements à Tania Sentes, Procurement Officer		
Telephone No. – No. de téléphone 639-625-3463	Facsimile No. – No. de télécopieur 306-780-5232	
Delivery Required – Livraison exigée N/A	Delivery Offered – Livraison proposée N/A	
Vendor/Firm Name, Address and Representative – Raison sociale, adresse et représentant du fournisseur/de l'entrepreneur:		
Telephone No. – No. de téléphone	Facsimile No. – No. de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) – Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)		
Signature	Date	



This amendment is raised to address the following:

- To respond to questions received during the solicitation period; and
- To revise the solicitation accordingly, as applicable.

QUESTIONS AND ANSWERS

Question 4: You are asking for monthly fee only to monitor and complete a yearly service as per ULC standards, what if there is additional costs at certain locations (see below) is that invoiced at a separate cost

Answer 4: Please see Annex "A" for confirmation on the Statement of Work. Any additional work requires pre-approval in writing from the Contract Authority.

Question 5: Do all GSM's in place support Bell / Telus as required (do we need to assume cost to replace or just order new sim cards) were does this additional cost go into the RFP.

Answer 5: All GSM's in place support Bell or Telus. New SIM cards are required for all GSM's. If a GSM is not operable and requires replacement pre-approval will be required in writing from the Contract Authority, this cost would not be included in the RFP as it would be invoiced as additional work.

Question 6: Are there any GSM's in place that are 2G if so where does the additional cost to replace go in the RFP.

Answer 6: Unknown if any current GSM's are 2G. Replacement would only be required if the GSM is inoperable. Pre-approval will be required in writing from the Contract Authority, this cost would not be included in the RFP as it would be invoiced as additional work.

Question 7: A list of Fire panel equipment was supplied but no list for the security panels is this possible.

Answer 7: The Fire panel GSM will not be connected to the Security alarm panel. The security panel information will not be provided.

Question 8: The attached Fire Alarm equipment document does provide a List of the Detachment FIRE ALARM PANELS, however as the Monitoring company, Tyco would not directly connect to this. If the Fire alarm Panels are being monitored now, these panels are connected to an alarm monitoring panel that in the event of a fire alarm would call out to the monitoring station. We are interested in what manufacture and model these alarm panels are? The reason is that we want to ensure that our monitoring station can accept the signals from these panels.

Answer 8: DSC PC1832 ULC Control Panel, DSC GSM Radio, DSC RM1c ULC Rated Relays are installed in all Detachments.



SOLICITATION REVISIONS

1) On page one-(1)

DELETE:

Solicitation Closes – L'invitation prend fin		
At / à :	2 :00 PM	CST (Central Standard Time) HNC (Heure Normale du Centre)
On / le :	July 25, 2017	

INSERT:

Solicitation Closes – L'invitation prend fin		
At / à :	2 :00 PM	CST (Central Standard Time) HNC (Heure Normale du Centre)
On / le :	August 8, 2017	

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME