



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Capacitor Bank Replacement	
Solicitation No. - N° de l'invitation K4A22-171457/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client K4A22-171457	Date 2017-07-21
GETS Reference No. - N° de référence de SEAG PW-\$PWU-066-11127	
File No. - N° de dossier PWU-7-40056 (066)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-07-28	Time Zone Fuseau horaire Mountain Daylight Saving Time MDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lee, Mony	Buyer Id - Id de l'acheteur pwu066
Telephone No. - N° de téléphone (780) 224-6675 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
K4A22-171457/A
Client Ref. No. - N° de réf. du client
K4A22-171457

Amd. No. - N° de la modif.
001
File No. - N° du dossier
PWU-7-40056

Buyer ID - Id de l'acheteur
pwu066
CCC No./N° CCC - FMS No/ N° VME

SOLICITATION AMENDMENT No. 001

Revision 1:

See attached Addendum 1

All other terms and conditions of the Invitation to Tender remain unchanged.

GENERAL

The following changes / clarifications in the tender documents are effective IMMEDIATELY. This Addendum will form part of the Contract Documents.

SPECIFICATIONS

None

DRAWINGS

Electrical No.1 (E1) Notes:

1. Main fire alarm panel (Notifier) located in Room 2651
2. Smoke detector in existing capacitor bank is device Z-10/47

Electrical No.2 (E2) Notes:

1. Team Power Solutions is approved as equal as a testing company to provide complete retesting of the existing capacitor bank breaker including megger and relay testing, and cleaning of breaker (Refer to Note 2 on drawing).

CLARIFICATIONS

Optional Site Visit Contractor Attendance List

Team Power Solutions
Alliance Energy
Aim Electric
Triad Power
Amtech Electric

Comments/Clarifications given during Optional Site Visit 2017-07-18

1. All questions comments regarding this tender shall be sent to Mony Lee at PSPC (Mony.Lee@tpsgc-pwgsc.gc.ca)
2. The customer metering is believed to be ahead of the utility meter based on the information we received previously from Flyer Electric. A shut down is required for correction of this issue. If this condition is not present upon opening of equipment further discussion will need to be held with the Environment and Climate Change Canada (Owner). If the customer metering equipment cannot be relocated then it will have to be removed and/or further discussion will be needed with the Owner.
3. Electrical outages should be kept to a minimum
4. 72 hour notice required before an electrical shut down
5. Typical business hours are Monday to Friday 08:00h to 16:00h
6. 48 hour notice required before any work outside of typical work hours
7. Jack hammering and any other loud work shall be conducted outside of typical business hours
8. 2 to 3 parking spots will be available for contractors use

-
9. Contractors may use site washrooms
 10. Routing of new/existing equipment shown on drawing and walked through on site
 11. Existing capacitor bank may need modification to fit through existing doorways
 12. Existing customer metering accuracy to be verified as switching in and out steps in the existing capacitor bank did not produce expected results.
 13. Floor finish shall match existing (Dark Gray)

Question Received by PWGSC on 2017-07-19

1. The project requires that a smoke/heat detector be relocated. Is this cost to be included in your price for this project?

Yes, the cost to relocate the smoke/heat detector and the cost to have the device verified by SITE approved Canadian Fire Alarm Association (CFAA) Fire Alarm Technician shall be included in the project. SITE approved technician shall be supplied by Alsask Fire Equipment Ltd. (306-934-4774)

END OF ADDENDUM 1