

Project No.: R.079454.001

July 27, 2017

The following changes to the tender documents are effective immediately and will form part of the contract documents:

This Addendum is issued prior to Bid due date to revise the Bid/Contract Documents and as such is part of those documents; value of all items shall be included in Bid. After acceptance of Bid, claims for costs will not be considered by reason of failure by Bidder to have read Addenda.

Drawing and Detail Sheets issued with this Addendum:
Drawing # E1

1.1 EMERGENCY POWER WIRING

Reference: Drawing 1/E1

a) Distance between emergency generator building and fire pump room is approximately 135 meters. Contractor to verify exact distance on site prior to ordering of materials.

1.2 FIRE ALARM WIRING

Reference: Drawing 1/E1

b) Distance between fire pump room and fire alarm panel is approximately 70 meters. Contractor to verify exact distance on site prior to ordering of materials.

END OF ADDENDUM NO. 3