



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9
Bid Fax: (506) 636-4376

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Officer, Email address: gisele.doucet@pwgsc.gc.ca.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

| | |
|---|--|
| Title - Sujet Chignecto Multipurpose Bldg, Alma | |
| Solicitation No. - N° de l'invitation EC015-180661/A | Amendment No. - N° modif. 002 |
| Client Reference No. - N° de référence du client EC015-180661 | Date 2017-07-27 |
| GETS Reference No. - N° de référence de SEAG PW-\$PWB-004-4157 | |
| File No. - N° de dossier PWB-7-40042 (004) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-08-03 | |
| Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT | |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Doucet, Gisele PWB | Buyer Id - Id de l'acheteur pwb004 |
| Telephone No. - N° de téléphone (506) 636-4541 () | FAX No. - N° de FAX (506) 636-4376 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|---|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

EC015-180661 /A

002

pwb004

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

CCC No./N° CCC - FMS No./N° VME

R.075816.001

PWB-7-40042

This Solicitation Amendment No. two (2) is raised to include the following addendum no. 2.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 2.

1. SPECIFICATIONS & DRAWINGS

1. Mechanical General

- .2 The following products are provided equivalent status for supply to the project providing the specification including features, qualities, and dimensions are met:
 - .1 Specification Section 23 24 14.2.2 Expansion Tank: FLOFAB
 - .2 Specification Section 23 24 14.3 Pump: FLOFAB
 - .3 Specification Section 23 51 00 Breaching: Van Packer
 - .4 Specification Section 23 52 00 Boilers: Viessman
 - .5 Specification Section 23 83 00 Radiant Tube: Gordon Ray
 - .6 Specification Section 22 42 00 Commercial Plumbing
Fixtures: Novanni, Zurn,
Haws, Sloan, Chicago, Acorn
- .2 **Reference Mechanical Specification Section 23 83 00 – Radiant Heating Units and Mechanical Drawings M-3 Floor Plan Heating Schematic & Details – Propane Gas-Fired Heater Schedule**
 - .1 Revise to read: 1RH-1 and 1RH-2 to be Swank Model STS-UZ @ 9,000mm with a heating capacity of 60,000 BTUH.

2. QUESTION / ANSWER

Q1. I was wondering if the Chignecto South Building going up in fundy has to be designed Post Disaster or if the Commercial code is sufficient.

A1. This building is not a post disaster building.