

Project No.: R.079454.001

July 28, 2017

The following changes to the tender documents are effective immediately and will form part of the contract documents:

This Addendum is issued prior to Bid due date to revise the Bid/Contract Documents and as such is part of those documents; value of all items shall be included in Bid. After acceptance of Bid, claims for costs will not be considered by reason of failure by Bidder to have read Addenda.

Drawing and Detail Sheets issued with this Addendum:

None

1.1 FIRE PUMP TEST HEADER

Reference: Specification Section 213000

a) Refer to article 2.7.1 of Section 213000. Revise paragraph to be read as; "FOUR-WAY WALL MOUNTED TYPE WITH FLANGED INLET AND 2.5" N.P.T. OUTLETS WITH 2.5 INCH N.P.T. NIPPLES AND RISING STEM FIRE PUMP TEST VALVES WITH 2.5 INCH FEMALE N.P.T. INLETS AND 2.5" MALE HOSE THREAD OUTLETS WITH CAPS AND CHAINS; WALL ESCUTCHEON WITH "PUMP TEST CONN." CAST INTO IT; ALL BRASS WITH POLISHED FINISH."

END OF ADDENDUM NO. 4