



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9
Bid Fax: (506) 636-4376

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Officer, Email address: gisele.doucet@pwgsc.gc.ca.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

Title - Sujet Chignecto Multipurpose Bldg, Alma	
Solicitation No. - N° de l'invitation EC015-180661/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client EC015-180661	Date 2017-07-31
GETS Reference No. - N° de référence de SEAG PW-\$PWB-004-4157	
File No. - N° de dossier PWB-7-40042 (004)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-08-03	
Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Doucet, Gisele PWB	Buyer Id - Id de l'acheteur pwb004
Telephone No. - N° de téléphone (506) 636-4541 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment No. three (3) is raised to include the following addendum no. 3.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 3

1. SPECIFICATIONS

.1 Reference Section 04 43 26 Dimension Stone Veneer Cladding

.1 Add 2.3.2 as follows:

.1 Acceptable alternate:

.1 Brunswick Limestone next door to the park in Hillsborough

.2 Reference Section 08 11 13 Glazed Aluminum Curtain Walls

.1 Revise 2.5.1 to read as follows:

.1 Not used.

.2 Revise 2.5.3 to read as follows:

.3 Not used.

.3 Revise 2.5.4 to read as follows:

.4 Not used.

.4 Delete 2.9.10 in its entirety.

.5 Delete 3.2.13 in its entirety.

.3 Reference Section 08 11 16 Aluminum Doors and Frames

- .1 Revise 2.2.1.1 to read as follows:
 - .2 Heavy Duty Door, 150mm stiles, 250mm mid rail, 150mm top rail, 200mm bottom rail, 51mm thickness.
- .2 Revise 2.3.4 to read as follows:
 - .4 Not used.
- .3 Revise 2.3.5 as follows:
 - .3 Door Hardware see Door / Hardware Schedule.
- .4 Delete 2.5.8 in its entirety.
- .5 Revise 3.2.7 as follows:
 - .7 Coordinate installation of doors and frames with installation of hardware specified Door / Hardware Schedule.

.4 Reference Section 08 80 50 Glazing

- .1 Add 2.1.5 as follows:
 - .4 Spandrel Glass: CAN/CGSB 12.9, clear tempered, organic coating of colour selected by Consultant; 6 mm thick.

.5 Reference Section 23 33 14

- .1 Add to 2.5.1.9 as follows:
 - .9 Acceptable alternate – Alumavent 3900 Series

2. DRAWINGS**.1 Reference Drawing A07 – Door, Frame, Window, Wall, & Roof Types Interior Finish / Door Schedules & Details – Detail 2**

Revise Note on Roof Types R1 and R2 to read:
 “New Metal Roofing Profile (0.60 mm)”

3. QUESTION / ANSWER

Q1. We will need more information regarding mechanical units HRV-1 & HRV-2 such as where exactly they are located and how much each one weighs.

A1. HRV-1 & HRV-2 weigh 93 Kg each; location as shown on drawings S-1 and M-4.