



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Public Works Government Services Canada- Bid  
Receiving / Réception des soumissions  
189 Prince William Street  
Room 405  
Saint John  
New Brunswick  
E2L 2B9  
Bid Fax: (506) 636-4376

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Officer, Email address: gisele.doucet@pwgsc.gc.ca.

### Vendor/Firm Name and Address

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

### Issuing Office - Bureau de distribution

Public Works Government Services Canada- Bid  
Receiving / Réception des soumissions  
189 Prince William Street  
Room 405  
Saint John  
New Brunswick  
E2L 2B9

<b>Title - Sujet</b> Chignecto Multipurpose Bldg, Alma	
<b>Solicitation No. - N° de l'invitation</b> EC015-180661/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> EC015-180661	<b>Date</b> 2017-07-31
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-004-4157	
<b>File No. - N° de dossier</b> PWB-7-40042 (004)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-08-03</b>	
<b>Time Zone</b> Fuseau horaire Atlantic Daylight Saving Time ADT	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Doucet, Gisele PWB	<b>Buyer Id - Id de l'acheteur</b> pwb004
<b>Telephone No. - N° de téléphone</b> (506) 636-4541 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Cette modification à l'invitation numéro trois (3) est soumise pour inclure l'addenda numéro 3 suivant.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

Addenda numéro 3.

**1. DEVIS**

**.1 Reference Section 04 43 26 Dimension Stone Veneer Cladding**

.1 Add 2.3.2 as follows:

.1 Acceptable alternate:

.1 Brunswick Limestone next door to the park in Hillsborough

**.2 Reference Section 08 11 13 Glazed Aluminum Curtain Walls**

.1 Revise 2.5.1 to read as follows:

.1 Not used.

.2 Revise 2.5.3 to read as follows:

.3 Not used.

.3 Revise 2.5.4 to read as follows:

.4 Not used.

.4 Delete 2.9.10 in its entirety.

.5 Delete 3.2.13 in its entirety.

### **.3 Reference Section 08 11 16 Aluminum Doors and Frames**

- .1 Revise 2.2.1.1 to read as follows:
  - .2 Heavy Duty Door, 150mm stiles, 250mm mid rail, 150mm top rail, 200mm bottom rail, 51mm thickness.
- .2 Revise 2.3.4 to read as follows:
  - .4 Not used.
- .3 Revise 2.3.5 as follows:
  - .3 Door Hardware see Door / Hardware Schedule.
- .4 Delete 2.5.8 in its entirety.
- .5 Revise 3.2.7 as follows:
  - .7 Coordinate installation of doors and frames with installation of hardware specified Door / Hardware Schedule.

### **.4 Reference Section 08 80 50 Glazing**

- .1 Add 2.1.5 as follows:
  - .4 Spandrel Glass: CAN/CGSB 12.9, clear tempered, organic coating of colour selected by Consultant; 6 mm thick.

### **.5 Reference Section 23 33 14**

- .1 Add to 2.5.1.9 as follows:
  - .9 Acceptable alternate – Alumavent 3900 Series

## **2. DESSINS**

### **.1 Reference Drawing A07 – Door, Frame, Window, Wall, & Roof Types Interior Finish / Door Schedules & Details – Detail 2**

Revise Note on Roof Types R1 and R2 to read:  
 “New Metal Roofing Profile (0.60 mm)”

## **3. QUESTION / RÉPONSES**

Q1. We will need more information regarding mechanical units HRV-1 & HRV-2 such as where exactly they are located and how much each one weighs.

R1. HRV-1 & HRV-2 weigh 93 Kg each; location as shown on drawings S-1 and M-4.