



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Mechanical Systems Energy Upgrade	
Solicitation No. - N° de l'invitation K4A22-180000/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client	Date 2017-08-01
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-8091	
File No. - N° de dossier PWY-7-40047 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-08-04	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 363-7968 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: EC - Pacific Environmental Science Centre - North Vancouver, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
K4A22-180000/A

Amd. No. - N° de la modif.
005

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°

CCC - FMS No./N° VME

Les documents français seront disponibles sur demande.

The Solicitation Amendment 005 is raised to issue Addendum 002 and to publish the attendees of the 2nd optional site visit:

- 1) Please see Addendum 002 herein.
- 2) A 2nd optional site visit was held on July 31, 2017.

The companies that attended the site visit are as follows:

ESC Automation Inc.
Davidson Bros. Mech Contractors Ltd.

All other terms and conditions remain unchanged.

GENERAL

**The following changes in the Tender Documents are effective IMMEDIATELY.
This addendum will form part of the Contract Documents**

SPECIFICATIONS

1. Section 23 06 01 HVAC Equipment Manufacturers
 - .1 Add “Phase Change Material: ENRG Blanket, Infinite R”

QUESTIONS RECEIVED TO JULY 28, 2017

1. Q. “We are looking for some clarification on the Phase Change Material on page 50 of the specifications for the Mechanical Systems Energy Upgrade.... Please could the Engineer advise where this material can be sourced from or if there is an alternate that would be suitable?”
 - .1 A. The specified product is available from Aim Energy Pros Ltd. - 1-877-454-2246. Alternates are the following: ENRG Blanket, Infinite R.
2. Q. “Under the Mechanical Scope (Page 6) Line # 7 - Is the Temporary Heater included in the new equipment Schedule?”
 - .1 Yes, section 23 06 00 Table 2.13 has the specified equipment requirements
3. Q. “Please provide the current Active AHRI certificate”
 - .1 The certificate issued in Addendum 1 has been confirmed by AHRI to be active. This can be verified through the AHRI website entering in the following information or calling them directly:

AHRI Certified Ref Number:	2122016
Date:	05/19/2016
Certificate No:	131081545707493965

(<https://www.ahridirectory.org/ahridirectory/pages/VerifyCertificate.aspx>)

END OF ADDENDUM 2