

Stantec Consulting Ltd.
200-325 25 Street SE
Calgary AB T2A 7H8
Phone: (403) 716-8000
Fax: (403) 716-8109

File : 116500398
Addendum No. : 2
Date: July 31, 2017
Owner : Government of Canada
Tender No.: **M5000-18-1048/A**

This addendum is to be read with and constitutes part of the tender document.

INSTRUCTIONS :

1. Amend your copy of the tender/quotation/proposal in accordance with the detail below.
2. Retain one (1) copy for your file; sign and return a 2nd copy and attach to your submission as confirmation that the Addendum was taken into account in your bid submission.
3. Failure to sign and return this form may result in a non-compliant bid.

DETAILS OF ADDENDUM:

The following questions were submitted. Responses and additional information follow each question

- 1. I noticed what seems to be a permanent 90% road ban on the road to the facility from the highway. Would the county be willing to allow us 100% loads for the hauling of the gravel materials to the work site?**
The application to the county for temporary road ban changes would need to come directly from the contractor.
- 2. Does the gravel quantities in Schedule C include the gravel required under the pavers and sidewalk etc.?**
No, the gravel quantities in Schedule C does not include the gravel required under the concrete and pavers.
- 3. Do the glass fence post have to be round? A square alternate has been suggested**
Substitutions will be reviewed on an individual basis to ensure that they are equivalent to that which was originally specified. Provide separate pricing for alternate glass railing and modified footings. On award of contract, contractor to submit proposed alternative design stamped by engineer for approval.
- 4. Does the glass thickness have to be 12mm? A more common 10mm thickness has been suggested. Still very strong.**
Substitutions will be reviewed on an individual basis to ensure that they are equivalent to that which was originally specified. Provide separate pricing for alternate glass railing and modified

footings. On award of contract, contractor to submit proposed alternative design stamped by engineer for approval.

5. **I would like to price a City of Red Deer spec asphalt. It appears City of Calgary may be in the tender specs. Will Red Deer's 12.5mm Spec be acceptable? It is widely used in the area.**
Red Deer County specs (Section 02741) Mix Type 5b(1) (which uses 12.5 mm aggregate size) is acceptable. <https://reddeercounty.civicweb.net/document/5644>
6. **I will be submitting a value added price to construct and install the Phase 2 electrical shown on the plans. It would be much more efficient to have our electrical contractor execute that work while on site performing this Phase 1 Work. Should budget permit, would this be something you would be interested in having done?**
Additional options may be submitted as additional optional items on the tender, however, at this time, no Addendum to the contract to provide additional services is expected to be issued.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED

STANTEC CONSULTING LTD.

Micheal E. Williamson, MBCSLA, CSLA, M.L.Arch., B.Env.D
Design Consultant, Planning and Landscape Architecture
Phone: (403) 716-8242
micheal.williamson@stantec.com

Attachment: 330-23.pdf

c. C.C.

Name of Firm

Authorized Signature

Printed Name

Date