



STAIR #1 SECTION

1  
E8



STAIR #2 SECTION


2  
E8



OVERHEAD DOOR HEAT TRACE DETAIL

3  
E8


SCALE : NTS



FIRE ALARM RISER

4  
E8

SCALE : NTS




CCTV RISER

5  
E8

SCALE : NTS

- NOTES:
1. BOX SIZES AND CABLES MAY VARY DEPENDING ON MANUFACTURER'S REQUIREMENTS.
  2. LOCATION OF DVR, POWER SUPPLY AND MONITOR TO BE CONFIRMED ON SITE WITH OWNER'S REPRESENTATIVE BEFORE ROUGH-IN.




DOOR ACCESS CONTROL

6  
E8

SCALE : NTS


- NOTES:
1. LIGHTS WILL NOT TURN ON AUTOMATICALLY WHEN ENTERING THE ROOM. THE OCCUPANT WILL TURN ON ONE GROUP OR ALL FOUR GROUPS OF LIGHT FIXTURES TYPE 'C' WITH WALL MOUNTED WIRELESS DIMMER SWITCHES NEAR THE DOOR.
  2. LIGHT FIXTURES TYPE 'C' CAN BE DIMMED TO APPROXIMATELY 1%.
  3. THE OPERATOR TECHNICIANS WILL MANUALLY TURN ON TASK LIGHT FIXTURE TYPE 'M' AT EACH CONSOLE WITH INDIVIDUAL WIRELESS DIMMER SWITCHES. LIGHT FIXTURES TYPE 'M' CAN BE DIMMED TO 1%. THE LOCATION OF THE SWITCHES WILL BE DETERMINED ON SITE, ATTACHED TO CONSOLE.
  4. WHEN THE ROOM IS VACATED FOR A PREDETERMINED LENGTH OF TIME, THE CEILING MOUNTED VACANCY WILL AUTOMATICALLY TURN OFF LIGHT FIXTURES TYPE 'C'.
  5. SYSTEM TO INCLUDE ALL NECESSARY POWER PACKS, DIMMING MODULES, INTERCONNECTING CONTROL WIRES AND ALL MISCELLANEOUS DEVICES REQUIRED TO PERFORM THE REQUIRED OPERATION.
  6. EXACT MOUNTING HEIGHT AND POSITIONING OF TYPE 'M' LIGHT FIXTURES TO BE DETERMINED AFTER CONSOLES ARE INSTALLED. CONTRACTOR TO ALLOW FOR ADDITIONAL SUSPENSION CABLES AND INCLUDE ADJUSTABLE SUSPENSION HEIGHT FITTINGS.



LIGHTING CONTROL DETAIL - OPERATIONS ROOM

8  
E8

SCALE : NTS



SECTION DETAIL ROOM 107

7  
E8

SCALE : NTS

NOTE:  
EXACT LOCATION OF CABLE TRAY AND SUPPORTS TO BE CONFIRMED ON SITE WITH OWNER'S REPRESENTATIVE.

C	ISSUED FOR TENDER	JUN 28 2017
B	ISSUED FOR 99% REVIEW	MAY 25 2017
A	ISSUED FOR CLIENT REVIEW	APR 28 2017
revisions		date
project		project

MCTS CENTRE  
PORT AUX BASQUES

designed	conçu
date	JUNE 28 2017
drawn	dessiné
date	JUNE 28 2017
approved	approuvé
date	JUNE 28 2017
Tender	Project Manager
Project Manager	Adm. des projets TPSCG
project number	no. du projet
R.082780.004	
drawing no.	no. du dessin
E8	