

PART 1 - GENERAL

- 1.1 REFERENCES
- .1 ASTM International
 - .1 ASTM C 553-13, Standard Specification for Mineral Fibre Blanket Thermal Insulation for Commercial and Industrial Applications.
 - .2 ASTM C 665-12, Standard Specification for Mineral-Fiber Blanket Thermal Insulation for Light Frame Construction and Manufactured Housing.
 - .3 ASTM C 1320-10, Standard Practice for Installation of Mineral Fiber Batt and Blanket Thermal Insulation for Light Frame Construction.
 - .2 Canada Green Building Council (CaGBC)
 - .1 LEED Canada 2009 for Design and Construction Leadership in Energy and Environmental Design Green Building Rating System Reference Guide.
 - .3 CSA Group
 - .1 CSA B111-1974 (R2003), Wire Nails, Spikes and Staples.
 - .4 Underwriters Laboratories of Canada (ULC)
 - .1 CAN/ULC-S702-2012, Standard for Mineral Fibre Insulation for Buildings.
- 1.2 ACTION AND INFORMATIONAL SUBMITTALS
- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for blanket insulation and include product characteristics, performance criteria, physical size, finish and limitations.
 - .3 Certificates:
 - .1 Submit product certificates signed by manufacturer certifying materials comply with specified performance characteristics and criteria and physical requirements.
-

- 2.1 INSULATION (Cont'd)
- .2 Acoustic batt insulation: (Cont'd)
 - .1 Unfaced glass fiber acoustical insulation to ASTM C665, Type 1, thickness as indicated.
 - .1 Flame spread: 10 to ASTM E84.
 - .2 Smoke development: 10 to ASTM E84.
 - .3 Sound transmission Class: STC 49.
 - .4 Dimensional stability: linear shrinkage less than 0.1%.
 - .3 Mineral fibre to CAN/ULS-S702, Type 1 specifically identified for fire rated partitions: Mineral fibre processed from rock or slag with density of 45 kg/m².

PART 3 - EXECUTION

- 3.1 EXAMINATION
- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for blanket insulation application in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.
- 3.2 INSULATION INSTALLATION
- .1 Install insulation to maintain continuity of thermal protection to building elements and spaces and to ASTM C 1320.
 - .2 Fit insulation closely around electrical boxes, pipes, ducts, frames and other objects in or passing through insulation.
 - .3 Do not compress insulation to fit into spaces.

3.2 INSULATION
INSTALLATION
(Cont'd)

- .4 Keep insulation minimum 75 mm from heat emitting devices such as recessed light fixtures.
- .5 Do not enclose insulation until it has been inspected and approved by Departmental Representative.

3.3 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal and Section 01 35 21 - LEED Requirements.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.