

PART 1 - GENERAL

- 1.1 REFERENCES .1 Canada Green Building Council (CaGBC)
 - .1 LEED Canada-NC-2009, LEED (Leadership in Energy and Environmental Design): Green Building Rating System for New Construction and Major Renovations 2009.
 - .2 CSA International
 - .1 CAN/CSA-C22.2 No.18, Outlet Boxes, Conduit Boxes and Fittings.
 - .2 CAN/CSA-C22.2 No.65, Wire Connectors (Tri-National Standard with UL 486A-486B and NMX-J-543-ANCE-03).
 - .3 National Electrical Manufacturers Association (NEMA).

 - 1.2 ACTION AND INFORMATIONAL SUBMITTALS .1 Sustainable Design Submittals:
 - .1 LEED Canada submittals: in accordance with Section 01 35 21 - LEED Requirements.
 - .2 Construction Waste Management:
 - .1 Submit project Waste Management Plan highlighting recycling and salvage requirements.
 - .2 Submit calculations on end-of-project recycling rates, salvage rates, and landfill rates demonstrating that 75% of construction wastes were recycled or salvaged.

 - 1.3 DELIVERY, STORAGE AND HANDLING .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
 - .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
 - .3 Develop Construction Waste Management Plan related to Work of this Section and in
-

- 1.3 DELIVERY, STORAGE AND HANDLING
(Cont'd)
- .3 (Cont'd)
accordance with Section 01 35 21 - LEED Requirements.
- .4 Packaging Waste Management: remove for reuse or return of pallets, crates, padding, banding, and packaging materials as specified in Construction Waste Management Plan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal and Section 01 35 21 - LEED Requirements.

PART 2 - PRODUCTS

- 2.1 MATERIALS
- .1 Pressure type wire connectors to:
CAN/CSA-C22.2 No.65, with current carrying parts of copper sized to fit copper conductors as required.
- .2 Fixture type splicing connectors to:
CAN/CSA-C22.2 No.65, with current carrying parts of copper sized to fit copper conductors 10 AWG or less.
- .3 Bushing stud connectors: to EEMAC 1Y-2 to consist of:
.1 Connector body and stud clamp for stranded copper aluminum and conductors bar.
.2 Clamp for stranded copper conductors.
.3 Stud clamp bolts.
.4 Bolts for copper conductors and bar.
.5 Sized for conductors and bars as indicated.
- .4 Clamps or connectors for armoured cable, TECK cable and flexible conduit.
-

PART 3 - EXECUTION

- 3.1 INSTALLATION .1 Remove insulation carefully from ends of conductors and cables and install in accordance with manufacturer's instructions.
- 3.2 CLEANING .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
.1 Leave Work area clean at end of each day.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal and Section 01 35 21 - LEED Requirements.
.1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.