

PART 1 - GENERAL

- 1.1 USE OF SYSTEMS .1 Use of new permanent heating and ventilating systems for supplying temporary heating or ventilation is not permitted.
- .2 The operation of mechanical systems during construction can have a negative impact on the indoor air quality post occupancy and will not be permitted on this project.
- .3 All installed ductwork, diffusers, grilles, fan coil units and all other heating and ventilation equipment must be protected from dust and debris throughout construction. If improperly protected, and cleaning is deemed to be necessary, systems must be cleaned in their entirety at the Contractor's expense.

PART 2 - PRODUCTS

- 2.1 NOT USED .1 Not Used.

PART 3 - EXECUTION

- 3.1 NOT USED .1 Not Used.

