






CONSTRUCTION ASSEMBLY LIST	
FLOOR CONSTRUCTION - TYPE 1	ROOF CONSTRUCTION - TYPE 3
- CONCRETE SLAB ON GRADE	- ROOFING MEMBRANES
- VAPOUR RETARDER	- RECOVERY BOARD
- CRUSHED STONE	- 2 x 76 mm POLYISOCYANURATE INSULATION (RSI 6.72)
	- VAPOUR RETARDER
	- THERMAL BARRIER
	- 38 mm METAL ROOF DECK
	- JOISTS/BEAMS (SLOPED)
FLOOR CONSTRUCTION - TYPE 2	ROOF CONSTRUCTION - TYPE 4
- NON-RATED FIRE SEPARATION	- ROOFING MEMBRANES
- CONCRETE TOPPING	- RECOVERY BOARD
- 38 mm METAL FLOOR DECK	- TAPERED INSULATION (MINIMUM 1% SLOPE)
- OPEN WEB STEEL JOISTS	- VAPOUR RETARDER
	- THERMAL BARRIER
	- 38 mm METAL ROOF DECK
	- JOISTS/BEAMS (SLOPED)
WALL CONSTRUCTION - TYPE 1	SOFFIT CONSTRUCTION - TYPE 1
- PRE-FINISHED WOOD SIDING ON 25 mm VERTICAL FURRING @ 400 OC (CENTRE FURRING ON STUDS)	- PRE-FINISHED 'FLAT' WOOD SIDING ON 25 mm FURRING @ 400 OC
- 38 mm POLYISOCYANURATE INSULATION (RSI 1.63)	- 38 mm POLYISOCYANURATE INSULATION (RSI 1.63)
- PEEL/STICK AIR BARRIER MEMBRANE	- PEEL/STICK AIR BARRIER MEMBRANE
- 16 mm EXTERIOR GRADE PLYWOOD	- 16 mm EXTERIOR GRADE PLYWOOD
- 152 mm STRUCTURAL STEEL STUDS @ 400 OC	- 152 mm STRUCTURAL STEEL STUDS @ 400 OC
- 152 mm SPRAY-FOAM INSULATION (RSI 6.34)	- 152 mm SPRAY-FOAM INSULATION (RSI 6.34)
- VAPOUR RETARDER	- VAPOUR RETARDER
- 16 mm GYPSUM BOARD	- 16 mm GYPSUM BOARD
ROOF CONSTRUCTION - TYPE 1	SOFFIT CONSTRUCTION - TYPE 2
- ROOFING MEMBRANES	- PRE-FINISHED 'FLAT' WOOD SIDING ON 25 mm FURRING @ 400 OC
- RECOVERY BOARD	- 38 mm POLYISOCYANURATE INSULATION (RSI 6.72)
- TAPERED INSULATION (MINIMUM 1% SLOPE)	- INSULATION (RSI 1.63)
- 2 x 76 mm POLYISOCYANURATE INSULATION (RSI 6.72)	- PEEL/STICK AIR BARRIER MEMBRANE
- VAPOUR RETARDER	- 16 mm EXTERIOR GRADE PLYWOOD
- THERMAL BARRIER	- 152 mm STRUCTURAL STEEL STUDS @ 400 OC
- 38 mm METAL ROOF DECK	- VAPOUR RETARDER
- JOISTS/BEAMS	- 16 mm GYPSUM BOARD
ROOF CONSTRUCTION - TYPE 2	
- ROOFING MEMBRANES	
- RECOVERY BOARD	
- TAPERED INSULATION (MINIMUM 1% SLOPE)	
- 2 x 76 mm POLYISOCYANURATE INSULATION (RSI 6.72)	
- VAPOUR RETARDER	
- THERMAL BARRIER	
- 38 mm METAL ROOF DECK	
- JOISTS/BEAMS	



ELEVATOR ROOF 'POP-UP' (4 A5)
 SCALE : 1:5
 0mm 100mm 200mm 300mm 400mm 500mm



ROOF/WALL INTERFACE AT STAIR #2 (5 A5)
 SCALE : 1:5
 0mm 100mm 200mm 300mm 400mm 500mm

revisions	date	project
D	ISSUED FOR TENDER	JUN 28 2017
C	ISSUED FOR 99% REVIEW	MAY 26 2017
B	ISSUED FOR CLIENT REVIEW	APR 24 2017
A	ISSUED FOR 66% REVIEW	MAR 24 2017

MCTS CENTRE
 PORT AUX BASQUES
 WALL SECTIONS AND DETAILS

designed	date	approved
drawn	JUNE 28, 2017	approved
date	JUNE 28, 2017	date
approved	JUNE 28, 2017	date
date	JUNE 28, 2017	date
Project Manager	Admirateur des projets TPSC	no. du projet
R.082780.004		
drawing no.		no. du dessin
A7		