

PART 1 - GENERAL

1.1 REFERENCES

- .1 American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE)
 - .1 ASHRAE Standard 90.1-2007, Energy Standard for Buildings Except Low-Rise Residential Buildings (IESNA co-sponsored; ANSI approved; Continuous Maintenance Standard).

- .2 American Society for Testing and Materials International (ASTM)
 - .1 ASTM B 209M-04, Standard Specification for Aluminum and Aluminum Alloy Sheet and Plate Metric.
 - .2 ASTM C 335-04, Standard Test Method for Steady State Heat Transfer Properties of Horizontal Pipe Insulation.
 - .3 ASTM C 411-04, Standard Test Method for Hot-Surface Performance of High-Temperature Thermal Insulation.
 - .4 ASTM C 449/C 449M-00, Standard Specification for Mineral Fiber-Hydraulic-Setting Thermal Insulating and Finishing Cement.
 - .5 ASTM C 533-2004, Calcium Silicate Block and Pipe Thermal Insulation.
 - .6 ASTM C 547-2003, Mineral Fiber Pipe Insulation.
 - .7 ASTM C 921-03a, Standard Practice for Determining the Properties of Jacketing Materials for Thermal Insulation.

- .3 Canadian General Standards Board (CGSB)
 - .1 CGSB 51-GP-52Ma-89, Vapour Barrier, Jacket and Facing Material for Pipe, Duct and Equipment Thermal Insulation.
 - .2 CAN/CGSB-51.53-95, Poly (Vinyl Chloride) Jacketing Sheet, for Insulated Pipes, Vessels and Round Ducts

- .4 Department of Justice Canada (Jus)
 - .1 Canadian Environmental Assessment Act (CEAA), 1995, c. 37.
 - .2 Canadian Environmental Protection Act (CEPA), 1999, c. 33.
 - .3 Transportation of Dangerous Goods Act (TDGA), 1992, c. 34.

- 1.1 REFERENCES (Cont'd)
- .5 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
 - .6 Manufacturer's Trade Associations
 - .1 Thermal Insulation Association of Canada (TIAC): National Insulation Standards (Revised 2004).
 - .7 Underwriters' Laboratories of Canada (ULC)
 - .1 CAN/ULC-S102-03, Surface Burning Characteristics of Building Materials and Assemblies.
 - .2 CAN/ULC-S701-01, Thermal Insulation, Polystyrene, Boards and Pipe Covering.
 - .3 CAN/ULC-S702-1997, Thermal Insulation, Mineral Fibre, for Buildings
 - .4 CAN/ULC-S702.2-03, Thermal Insulation, Mineral Fibre, for Buildings, Part 2: Application Guidelines.
- 1.2 DEFINITIONS
- .1 For purposes of this section:
 - .1 "CONCEALED" - insulated mechanical services in suspended ceilings and non-accessible chases and furred-in spaces.
 - .2 "EXPOSED" - will mean "not concealed" as specified.
 - .2 TIAC ss:
 - .1 CRF: Code Rectangular Finish.
 - .2 CPF: Code Piping Finish.
- 1.3 ACTION AND INFORMATIONAL SUBMITTALS
- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
-

1.3 ACTION AND
INFORMATIONAL
SUBMITTALS
(Cont'd)

- .3 Shop Drawings:
 - .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Shop drawings: submit drawings stamped and signed by professional engineer registered or licensed in the Province of Newfoundland and Labrador, Canada.
 - .4 Samples:
 - .1 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Submit for approval: complete assembly of each type of insulation system, insulation, coating, and adhesive proposed. Mount sample on 12 mm plywood board. Affix label beneath sample indicating service.
 - .5 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Instructions: submit manufacturer's installation instructions.
 - .1 Departmental Representative will make available 1 copy of systems supplier's installation instructions.

1.4 QUALITY
ASSURANCE

- .1 Qualifications:
 - .2 Installer: specialist in performing work of this Section, and have at least 3 years successful experience in this size and type of project, qualified to standards of TIAC.
 - .3 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.
-

- 1.5 DELIVERY,
STORAGE AND
HANDLING
- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with manufacturer's written instructions and Section 01 61 00 - Common Product Requirements.
 - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
 - .3 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
 - .2 Storage and Protection:
 - .1 Protect from weather, construction traffic.
 - .2 Protect against damage.
 - .3 Store at temperatures and conditions required by manufacturer.
 - .3 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .2 Place excess or unused insulation and insulation accessory materials in designated containers.
 - .3 Divert unused metal materials from landfill to metal recycling facility approved by Departmental Representative.
 - .4 Dispose of unused adhesive material at official hazardous material collections site approved by Departmental Representative.

PART 2 - PRODUCTS

- 2.1 SUSTAINABLE
REQUIREMENTS
- .1 Materials and products in accordance with Section 01 47 15 - Sustainable Requirements: Construction
 - .1 Choose products and materials with recycled content or resource efficient characteristics whenever possible. Use least toxic sealants, adhesives, sealers and finishes necessary to comply with the requirements of the project.
-

-
- 2.2 FIRE AND SMOKE RATING .1 In accordance with CAN/ULC-S102.
.1 Maximum flame spread rating: 25.
.2 Maximum smoke developed rating: 50.
- 2.3 INSULATION .1 Mineral fibre specified includes glass fibre, rock wool, slag wool.
- .2 Thermal conductivity ("k" factor) not to exceed specified values at 24 degrees C mean temperature when tested in accordance with ASTM C 335.
- .3 TIAC Code A-1: rigid moulded mineral fibre without factory applied vapour retarder jacket.
.1 Mineral fibre: to CAN/ULC-S702.
.2 Maximum "k" factor: to CAN/ULC-S702.
- .4 TIAC Code A-2: rigid moulded calcium silicate in sections and blocks, and with special shapes to suit project requirements.
.1 Insulation to: ASTM C533.
.2 Maximum "k" factor: 0.075 W/m°C @ 500°C.
.3 Design to permit periodic removal and re-installation.
- .5 TIAC Code A-3: rigid moulded mineral fibre with factory applied vapour retarder jacket.
.1 Mineral fibre: to CAN/ULC-S702.
.2 Jacket: to CGSB 51-GP-52Ma.
.3 Maximum "k" factor: to CAN/ULC-S702.
- .6 TIAC Code C-2: mineral fibre blanket faced with factory applied vapour retarder jacket (as scheduled in PART 3 of this section).
.1 Mineral fibre: to CAN/ULC-S702.
.2 Jacket: to CGSB 51-GP-52Ma.
.3 Maximum "k" factor: to CAN/ULC-S702.
- .7 TIAC Code A-6: flexible unicellular tubular elastomer.
.1 Insulation: with vapour retarder jacket.
.2 Jacket: to CGSB 51-GP-52Ma.
.3 Maximum "k" factor: to CAN/ULC-S702.
.4 Certified by manufacturer: free of potential stress corrosion cracking corrodants.
-

- 2.4 INSULATION SECUREMENT
- .1 Tape: self-adhesive, aluminum, reinforced, 50 mm wide minimum.
 - .2 Contact adhesive: quick setting. (All adhesives must adhere to VOC Limits as required by SCAQMD Rule 1168).
 - .3 Canvas adhesive: washable. (All adhesives must adhere to VOC Limits as required by SCAQMD Rule 1168).
 - .4 Tie wire: 1.5 mm diameter stainless steel.
 - .5 Bands: stainless steel, 19 mm wide, 0.5 mm thick.
- 2.5 CEMENT
- .1 Thermal insulating and finishing cement:
 - .1 Hydraulic setting or Air drying on mineral wool, to ASTM C 449/C 449M.
- 2.6 VAPOUR RETARDER LAP ADHESIVE
- .1 Water based, fire retardant type, compatible with insulation.
- 2.7 INDOOR VAPOUR RETARDER FINISH
- .1 Vinyl emulsion type acrylic, compatible with insulation.
- 2.8 OUTDOOR VAPOUR RETARDER FINISH
- .1 Vinyl emulsion type acrylic, compatible with insulation.
 - .2 Reinforcing fabric: fibrous glass, untreated 305 g/m².
- 2.9 JACKETS
- .1 Polyvinyl Chloride (PVC):
 - .1 One-piece moulded type and sheet to CAN/CGSB-51.53 with pre-formed shapes as required.
 - .2 Colours: by Departmental Representative.
 - .3 Minimum service temperatures: -20 degrees C.
-

- 2.9 JACKETS (Cont'd)
- .1 (Cont'd)
 - .4 Maximum service temperature: 65 degrees C.
 - .5 Moisture vapour transmission: 0.02 perm.
 - .6 Thickness: 0.75 mm.
 - .7 Fastenings:
 - .1 Use solvent weld adhesive compatible with insulation to seal laps and joints.
 - .2 Tacks.
 - .3 Pressure sensitive vinyl tape of matching colour.
 - .8 Special requirements:
 - .1 Outdoor: UV rated material at least 0.5 mm thick.
 - .2 Canvas:
 - .1 220 and 120 gm/m² cotton, plain weave, treated with dilute fire retardant lagging adhesive to ASTM C 921.
 - .2 Lagging adhesive: compatible with insulation.
- 2.10 WEATHERPROOF CAULKING FOR JACKETS INSTALLED OUTDOORS
- .1 Caulking to: Section 07 92 00 - Joint Sealants.

PART 3 - EXECUTION

- 3.1 MANUFACTURER'S INSTRUCTIONS
- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.
- 3.2 PRE-INSTALLATION REQUIREMENT
- .1 Pressure testing of piping systems and adjacent equipment to be complete, witnessed and certified.
 - .1 Surfaces clean, dry, free from foreign material.

- 3.3 INSTALLATION
- .1 Install in accordance with TIAC National Standards.
 - .2 Apply materials in accordance with manufacturers instructions and this specification.
 - .3 Use two layers with staggered joints when required nominal wall thickness exceeds 75 mm.
 - .4 Maintain uninterrupted continuity and integrity of vapour retarder jacket and finishes.
 - .1 Install hangers, supports outside vapour retarder jacket.
 - .5 Supports, Hangers:
 - .1 Apply high compressive strength insulation, suitable for service, at oversized saddles and shoes where insulation saddles have not been provided.
- 3.4 REMOVABLE, PRE-FABRICATED, INSULATION AND ENCLOSURES
- .1 Application: at expansion joints, valves, primary flow measuring elements flanges and unions at equipment.
 - .2 Design: to permit movement of expansion joint and to permit periodic removal and replacement without damage to adjacent insulation.
 - .3 Insulation:
 - .1 Insulation, fastenings and finishes: same as system.
 - .2 Jacket: PVC.
- 3.5 INSTALLATION OF ELASTOMERIC INSULATION
- .1 Insulation to remain dry. Overlaps to manufacturers instructions. Ensure tight joints.
 - .2 Provide vapour retarder as recommended by manufacturer.
-

- 3.6 PIPING INSULATION SCHEDULES
- .1 Includes valves, valve bonnets, strainers, flanges and fittings unless otherwise specified.
 - .2 TIAC Code: A-1.
 - .1 Securements: SS bands at 300 mm on centre.
 - .2 Seals: lap seal adhesive, lagging adhesive.
 - .3 Installation: TIAC Code 1501-H.
 - .3 TIAC Code: A-3.
 - .1 Securements: SS bands at 300 mm on centre.
 - .2 Seals: VR lap seal adhesive, VR lagging adhesive.
 - .3 Installation: TIAC Code: 1501-C.
 - .4 TIAC Code: A-6.
 - .1 Insulation securements: bands at 300 mm on centre.
 - .2 Seals: lap seal adhesive, lagging adhesive.
 - .3 Installation: TIAC Code: 1501-H.
 - .5 TIAC Code: C-2 with vapour retarder jacket.
 - .1 Insulation securements: bands at 300 mm on centre.
 - .2 Seals: lap seal adhesive, lagging adhesive.
 - .3 Installation: TIAC Code: 1501-C.
 - .6 TIAC Code: A-2.
 - .1 Insulation securements: 18 ga SS Wire or 12 mm x 0.51 mm SS bands at 300 mm on centre.
 - .2 Seals: lap seal adhesive, lagging adhesive.
 - .3 Installation: TIAC Code: 1501-H.
 - .7 Thickness of insulation as listed in following table.
 - .1 Run-outs to individual units and equipment not exceeding 4000 mm long.
 - .2 Do not insulate exposed runouts to plumbing fixtures, chrome plated piping, valves, fittings.

Applica- tion	Temp degrees	TIAC code	Pipe sizes (NPS) and insulation thickness (mm)
------------------	-----------------	--------------	---

3.6 PIPING .7 (Cont'd)
 INSULATION .2 (Cont'd)
 SCHEDULES
 (Cont'd)

	Run out		to 1	1 1/4 to 2	2 1/2 to 4	5 to 6	8 & over
Conden sate Return	60 - 94	A- 1	25	38	38	38	38
Pumped Conden sate return	up to 94	A- 1	25	38	38	38	38
Domestic HWS		A- 1	25	25	25	38	38
Domestic HW Recirculation		A-1	25	25	25	38	38
Domestic CWS		A- 3	25	25	25	25	25
Domestic CWS with vapour retarder		C- 2	25	25	25	25	25
Plumbing Vent Pipe		A-3	25	25	25	25	25
Refrig- erant hot gas liquid suction	4 - 13	A- 6	25	25	25	25	25
Refrig- erant hot gas liquid suction	below 4	A- 6	25	25	38	38	38

3.6 PIPING INSULATION SCHEDULES (Cont'd)	.7 (Cont'd) .2 (Cont'd)						
RWL and RWP	C- 2	25	25	25	25	25	25
Cooling Coil cond. drain	C- 2	25	25	25	25	25	25
Diesel generator exhaust system	A- 2	38	65	65	100	100	100

- .8 Finishes:
 - .1 Exposed indoors: canvas or PVC jacket.
 - .2 Exposed in mechanical rooms: PVC jacket.
 - .3 Concealed, indoors: canvas on valves, fittings. No further finish.
 - .4 Use vapour retarder jacket on TIAC code A-3 insulation compatible with insulation.
 - .5 Outdoors: water-proof PVC jacket.
 - .6 Finish attachments: SS bands, at 150 mm on centre. Seals: closed.
 - .7 Installation: to appropriate TIAC code CRF/1 through CPF/5.

3.7 FIELD QUALITY CONTROL	.1	Verification requirements in accordance with Section 01 47 17 - Sustainable Requirements: Contractor's Verification, include: <ul style="list-style-type: none"> .1 Materials and resources. .2 Storage and collection of recyclables. .3 Construction waste management. .4 Resource reuse. .5 Recycled content. .6 Local/regional materials. .7 Certified wood. .8 Low-emitting materials.
------------------------------	----	---

- 3.8 CLEANING .1 Proceed in accordance with Section 01 74 11 -
Cleaning.
- .2 Upon completion and verification of
performance of installation, remove surplus
materials, excess materials, rubbish, tools
and equipment.