

PART 1 - GENERAL

- 1.1 REFERENCES
- .1 Canadian Standards Association (CSA International)
 - .1 CAN/CSA C22.1 No.126.1-02, Metal Cable Tray Systems.
 - .2 CAN/CSA C22.1 No.126.2-02, Non Metallic Cable Tray Systems.
 - .2 National Electrical Manufacturers Association (NEMA)
 - .1 NEMA FG 1-1993, Fibreglass and Cable Tray Systems.
 - .2 NEMA VE 1-2002, Metal Cable Tray Systems.
 - .3 NEMA VE 2-2001, Cable Tray Installation Guidelines.
- 1.2 ACTION AND INFORMATIONAL SUBMITTALS
- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Product Data: submit manufacturer's product data sheets for cable tray indicating dimensions, materials, and finishes, including classifications and certifications.
 - .3 Shop Drawings: submit shop drawings showing materials, finish, dimensions, accessories, layout, and installation details.
 - .4 Identify types of cabletroughs used.
 - .5 Show actual cabletrough installation details and suspension system.
- 1.3 WASTE MANAGEMENT AND DISPOSAL
- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
-

PART 2 - PRODUCTS

- 2.1 CABLETROUGH
- .1 Fibreglass ladder tray and steel wire basket tray.
 - .2 Ladder trays: fibreglass reinforced, 228 mm wide with depth of 100 mm unless otherwise noted.
 - .3 Basket tray: 200 mm wide with depth of 100 mm.
 - .4 Fittings: horizontal elbows, end plates, tees, wyes, expansion joints and reducers where required, manufactured accessories for cabletrough supplied.
 - .1 Radii on fittings: 300 mm minimum.
 - .5 Barriers where different voltage systems are in same cabletrough.
 - .6 Ground metal cable trays with #2 AWG bare copper conductor attached to each tray section in accordance with CEC requirements.
- 2.2 SUPPORTS
- .1 Provide splices, supports as required.

PART 3 - EXECUTION

- 3.1 INSTALLATION
- .1 Ladder tray to be supported on fiberglass struct with threaded rods on each side.
 - .2 Support wall mounted tray on surface mounted struct.
 - .3 Support basket tray on floor pedestals, 25 mm high.
 - .4 Remove sharp burrs or projections to prevent damage to cables or injury to personnel.
 - .5 Tray installation in equipment room and Operations Room includes two parallel runs.
-

3.1 INSTALLATION .5 (Cont'd)
(Cont'd) Ensure that runs are properly aligned and evenly spaced. Exact locations and routing to be confirmed with the Departmental Representative before purchasing material.