

PART 1 - GENERAL

1.1 REFERENCES

- .1 American Society of Mechanical Engineers (ASME)
  - .1 ASME B16.1-05, Cast Iron Pipe Flanges and Flanged Fittings.
- .2 ASTM International Inc.
  - .1 ASTM A 49-01(2006), Standard Specification for Heat-Treated Carbon Steel Joint Bars.
  - .2 ASTM A 126-04, Standard Specification for Gray Iron Castings for Valves, Flanges, and Pipe Fittings.
  - .3 ASTM A 536-84(2004)e1, Standard Specification for Ductile Iron Castings.
  - .4 ASTM B 61-08, Standard Specification for Steam or Valve Bronze Castings.
  - .5 ASTM B 62-02, Standard Specification for Composition Bronze or Ounce Metal Castings.
  - .6 ASTM B 85/B 85M-08, Standard Specification for Aluminum-Alloy Die Castings.
  - .7 ASTM B 209-07, Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate.
- .3 Canada Green Building Council (CaGBC)
  - .1 LEED Canada-NC Version -2009, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Package For New Construction and Major Renovations.
- .4 Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS)
  - .1 MSS SP-61-03, Pressure Testing of Steel Valves.
  - .2 MSS SP-70-06, Grey Iron Gate Valves, Flanged and Threaded Ends.
  - .3 MSS SP-71-05, Grey Iron Swing Check Valves, Flanged and Threaded Ends.
  - .4 MSS SP-82-1992, Valve Pressure Testing Methods.
  - .5 MSS SP-85-2002, Cast Iron Globe and Angle Valves, Flanged and Threaded Ends.

- |   |    |   |
|---|----|---|
| 1.2 ACTION AND<br>INFORMATIONAL<br>SUBMITTALS | .1 | Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.  |
|   | .2 | Product Data:<br>.1 Provide manufacturer's printed product literature, specifications and datasheets for valves and include product characteristics, performance criteria, physical size, finish and limitations. |
|   | .3 | Shop Drawings:<br>.1 Provide drawings stamped and signed by professional engineer registered or licensed in Province of Newfoundland and Labrador, Canada.  |
|   | .4 | Sustainable Design Submittals:<br>.1 LEED Submittals: in accordance with Section 01 35 21 - LEED Requirements.  |
| 1.3 CLOSEOUT<br>SUBMITTALS                    | .1 | Submit maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.  |
| 1.4 DELIVERY,<br>STORAGE AND<br>HANDLING      | .1 | Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.   |
|   | .2 | Delivery and Acceptance Requirements:<br>.1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.  |
|   | .3 | Packaging Waste Management: remove for reuse or return of pallets crates padding and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.             |
-

1.5 MAINTENANCE  
MATERIAL SUBMITTALS

- .1 Extra Materials/Spare Parts:
- .2 Furnish following spare parts:
  - .1 Valve seats: one for every 10 valves each size, minimum 1.
  - .2 Discs: one for every 10 valves, each size, minimum 1.
  - .3 Stem packing: one for every 10 valves, each size, minimum 1.
  - .4 Valve handles: 2 of each size.
  - .5 Gaskets for flanges: one for every 10 flanged joints.
- .3 Tools:
  - .1 Furnish special tools for maintenance of systems and equipment.
  - .2 Include following:
    - .1 Lubricant gun for expansion joints.

PART 2 - PRODUCTS

2.1 MATERIAL

- .1 Sustainable Requirements:
  - .1 Use least toxic sealants, adhesives, sealers and finishes necessary to comply with the requirements of the project.
- .2 Valves:
  - .1 Except for specialty valves, to be of single manufacturer.
- .3 Standard specifications:
  - .1 Gate valves: MSS SP-70.
  - .2 Globe valves: MSS SP-85.
  - .3 Check valves: MSS SP-71.
- .4 Requirements common to valves, unless specified otherwise:
  - .1 Body, bonnet: cast iron to ASTM B 209 Class B ductile iron to ASTM A 536 Grade 65-45-12.
  - .2 Connections: flanged ends with 2 mm raised face with serrated finish to ANSI B16.1.
  - .3 Inspection and pressure testing: to MSS SP-82.
  - .4 Bonnet gasket: non-asbestos.

2.1 MATERIAL  
(Cont'd)

- .4 (Cont'd)
  - .5 Stem: to have precision-machined Acme or 60 degrees V threads, top screwed for handwheel nut.
  - .6 Stuffing box: non-galling two-piece ball-jointed packing gland, gland bolts and nuts.
  - .7 Gland packing: non-asbestos.
  - .8 Handwheel: die-cast aluminum alloy to ASTM B 85/B 85M or malleable iron to ASTM A 49. Nut of bronze to ASTM B 62.
  - .9 Identification tag: with catalogue number, size, other pertinent data.
- .5 All products to have CRN registration numbers.

2.2 GATE VALVES

- .1 NPS 2 1/2 - 8, non rising stem, inside screw, bronze trim, solid wedge disc:
  - .1 Body and multiple-bolted bonnet: with bosses in body and bonnet for taps and drains, full length disc guides designed to ensure correct re-assembly, Class 125.
  - .2 Disc: solid offset taper wedge, bronze to ASTM B 62.
  - .3 Seat rings: renewable bronze to ASTM B 62, screwed into body.
  - .4 Stem: bronze to ASTM B 62.

2.3 UNDERWRITERS  
APPROVED GATE VALVE

- .1 NPS 2 1/2 - 14, OS&Y:
  - .1 Approvals: UL and FM approved for fire service.
  - .2 UL and FM Label: on valve yoke.
  - .3 Body, Bonnet: cast iron to ASTM A 126 Class B. Wall thicknesses to ANSI B16.1 and ULC C-262 (B) ductile iron to ASTM A 536 Grade 65-45-12.
  - .4 Bonnet bushing, yoke sleeve: bronze, to FM requirements.
  - .5 Packing gland: bronze.
  - .6 Stem: manganese bronze. Diameter to ULC C-262 (B). Brass, ASTM B 16.
  - .7 Stuffing box dimensions, gland bolt diameter: to ULC C-262 (B).
  - .8 Bosses for bypass valve, drain: on NPS 4 and over.

- 2.3 UNDERWRITERS .1 (Cont'd)  
APPROVED GATE VALVE  
(Cont'd)
- .9 Disc: solid taper wedge. Up to NPS 3: bronze. NPS 4 and over: EPDM coated cast iron with bronze disc rings.
  - .10 Disc seat ring: self-aligning, Milwood undercut on NPS 3 - 12.
  - .11 Pressure rating:
    - .1 NPS 2-1/2 - 12: 1.7 Mpa CWP.
  - .12 Operator: handwheel.
  - .13 Bypass: complete with union and NPS gate valve as Section 23 05 23.01 - Valves - Bronze.
- 2.4 VALVE OPERATORS .1 Install valve operators as follows:
- .1 Handwheel: on valves except as specified.
  - .2 Handwheel with chain operators: on valves installed more than 2400 mm above floor in boiler rooms and mechanical equipment rooms.
- 2.5 CHECK VALVES .1 Swing check valves, Class 125:
- .1 Body and bolted cover: with tapped and plugged opening on each side for hinge pin. Grooved or flanged ends: plain faced with smooth finish.
    - .1 Up to NPS 16: cast iron to ASTM A 126 Class B.
    - .2 NPS 18 and over: cast iron to ASTM A 126 Class C.
  - .2 Ratings:
    - .1 NPS 2 1/2 - 12: 860 kPa steam; 1.4 MPa CWP.
  - .3 Disc: rotating for extended life.
    - .1 Up to NPS 6: bronze to ASTM B 62 stainless steel type 316.
  - .4 Seat rings: renewable bronze to ASTM B 62 screwed into body.
  - .5 Hinge pin, bushings: renewable bronze to ASTM B 62 stainless steel.
- .2 Swing check valves, NPS 2 1/2 - 8 Class 250:
- .1 Body and bolted cover: cast iron to ASTM A 126 Class B with tapped and plugged opening on each side for hinge pin.

- 2.5 CHECK VALVES .2 (Cont'd)
- (Cont'd)
- .2 Flanged ends: 2 mm raised face with serrated finish.
  - .3 Rating: 250 psi steam; 500 psi CWP.
  - .4 Disc: rotating for extended life.
    - .1 Up to NPS 3: bronze to ASTM B 61.
    - .2 NPS 4 - 8: iron faced with ASTM B 61 bronze.
  - .5 Seat rings: renewable bronze to ASTM B 61, screwed into body.
  - .6 Hinge pin, bushings: renewable, bronze to ASTM B 61.
  - .7 Hinge: galvanized malleable iron.
  - .8 Identification tag: fastened to cover.

- 2.6 SILENT CHECK VALVES .1 Construction:
- .1 Body: malleable or ductile iron with integral seat.
  - .2 Pressure rating: Class 125, WP = 860 kPa.
  - .3 Connections: grooved ends.
  - .4 Disc: bronze or stainless steel renewable rotating disc.
  - .5 Seat: renewable, EPDM.
  - .6 Stainless steel spring, heavy duty.

PART 3 - EXECUTION

- 3.1 INSTALLATION .1 Install rising stem valves in upright position with stem above horizontal.
- 3.2 CLEANING .1 Clean in accordance with Section 01 74 11 - Cleaning.
- .2 Clean installed products in accordance to manufacturer's recommendation.
  - .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal 01 35 21 - LEED Requirements.