



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**

Bid Receiving
PWGSC
33 City Centre Drive
Suite 480C
Mississauga
Ontario
L5B 2N5
Bid Fax: (905) 615-2095

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Ontario Region
33 City Centre Drive
Suite 480
Mississauga
Ontario
L5B 2N5

Title - Sujet Moving Shop Equipment	
Solicitation No. - N° de l'invitation W6854-139157/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client W6854-139157	Date 2017-08-09
GETS Reference No. - N° de référence de SEAG PW-\$TOR-008-7325	
File No. - N° de dossier TOR-7-40024 (008)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-08-14	
Time Zone Fuseau horaire Eastern Daylight Saving Time EDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leslie, Sandra	Buyer Id - Id de l'acheteur tor008
Telephone No. - N° de téléphone (905) 615-2069 ()	FAX No. - N° de FAX (905) 615-2060
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation Amendment 003 is being issued to respond to questions from companies that attended the mandatory site visit.

BIDDER QUESTIONS:

Q1: Please provide clarification of the requirements for electrical and compressed air disconnections/reconnections.

R1: Electrical and compressed air disconnections/reconnections will be performed by RP Ops Det Borden. This scope is not included in the contract.

Q2: Please provide the strength of the exterior concrete pathways at building S-165 and clarify requirements for moving equipment.

R2: The concrete pathways outside building S-165 consist of a permeable concrete that is susceptible to damage. As such, the Contractor is required to place steel plates with a plywood base over the pathways when they are being used to move equipment.

Q3: Can propane forklifts be used and is there a requirement for the forklift tire type?

R3: Both electric and/or propane forklifts will be accepted, however the Contractor is responsible to ensure that Ontario and Federal legislative requirements for the use of forklifts indoors are satisfied. All forklifts must be equipped with tires that will not damage the exposed concrete floors in both Building S-165 and A-142.

Q4: There are currently floor boxes installed in Lathe/Milling section of Building S-165. Can these support the forklift and equipment?

R4: No, these floor boxes are not designed to support the weight of the forklift and equipment. These must be avoided or covered with metal plates during the move.

Q5: Does the equipment on the CRTT workbenches (e.g. drill press, vice, grinder, etc.) need to be removed from the workbench prior to removing?

R5: No, the Contractor's expertise will be relied upon in determining how best to move the equipment.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME AND IN FULL EFFECT