



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Cableway Deconstruction & Site Rehab	
Solicitation No. - N° de l'invitation K4E21-170162/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client	Date 2017-08-09
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-8110	
File No. - N° de dossier PWY-7-40073 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-08-14	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 363-7968 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Cableway Deconstruction and Site Rehabilitation – Texas Creek, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
K4E21-170162/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°

CCC - FMS No./N° VME

Les documents seront disponibles en français sur demande.

The Solicitation Amendment 002 is raised to issue Addendum 001.

Please see Addendum 001 herein.

All other terms and conditions remain unchanged.

THE FOLLOWING ADDENDUM SUPERCEDES INFORMATION CONTAINED IN DRAWINGS AND SPECIFICATIONS ISSUED FOR THE PROJECT TO THE EXTENT REFERENCED. THIS ADDENDUM FORMS PART OF THE TENDER DOCUMENTS AND IS SUBJECT TO ALL OF THE CONDITIONS SET OUT IN THE CONTRACT CONDITIONS.

Tender Questions

Q. There is a section that the foundations are to be removed to 300 and then others that read that all must be removed. Please clarify

A. The foundations are to be removed as per the drawings. Some foundations are to be completely removed, while others are to be removed to 300mm. These vary from foundation to foundation and are intentionally variable.

Q. #011155.1.24.4 request a professional surveyor; is that really needed for this demolition?

A. It does not need to be done by a professional surveyor, as long as they describe with measurements and details what exactly has been removed or "left" in place and where it is located. The production of drawings will still be required.

Q. #028311, this work would require a WCB nop and work procedure approval. If the contractor work procedures meet with WCB approval then that would meet with your approval or???

A. The lead paint should be dealt with in accordance with the specifications and the environmental assessment provided in Appendix A.

Q. Tender reads that we drop the cables into the water and drag out. Will that be allowed, has all approvals been secured or is there any permits required?

A. The dragging out of the cables through the water will be allowed, as long as it is done within the prescribed window (refer to Appendix A in Specifications). All necessary permits for working in and around streams will be handled by third party.

Q. There is a live power line and pumphouse directly under the cable on the east shore, see the attached picture. The power line will have to be deactivated, removed and replaced to facilitate lowering the cables onto the ground. How will this work be paid?

A. The powerline deactivation, removal and replacement will be coordinated by ECCC and all cost will be incurred directly to ECCC with no cost to the contractor.

Q. There is also a power line that feeds the land owners irrigation pump that is in conflict, does the same apply for that line?

A. ECCC will be coordinating the deactivation, removal and replacement of this powerline and will be responsible for the consent from the landowner. All cost will be directly incurred by ECCC and the contractor will not be responsible for any cost associated with the work described previously.

Q. Also please clarify note 2 on methodology shown on drawing S4, can the cables be lowered onto the river bottom and then dragged onto the east bank for disposal?

A. The cable can be lowered into the river and pulled from the east bank as long as it is done within the prescribed window (refer to Appendix A in Specifications) and upon landowner consent to access the land which will be coordinated by ECCC. This work must be completed in one (1) day if it occurs before September 30th. If the work occurs after September 30th, it must be completed before October 7th. ECCC will provide environmental monitoring during this time and coordinate access through the landowner's property.

Drawings

1.1

ON PAGE S4 TO THE METHODOLOGY SECTION, ADD THE FOLLOWING:

All steel reinforcement and anchoring rods should be cut off at the elevation of the remaining concrete face and should not be sticking out. All metals should be removed and disposed of appropriately.

END OF ADDENDUM NO. 01