

Addendum / Addenda

Project Description / Description de projet M54 Re-Roof section #1		
Solicitation No./N° de sollicitation 17-22037	Project No./N° de projet 5371	W.O. No./N° d'ordre de travail A1-011396-01-01
Departmental Representative / représentant ministériel Kirk Williams		Date August 3, 2017
Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		Nota: Cet addenda fait partie intégrale des dossiers d'appel; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.

General

- Q. Please confirm that only roof section 1 is to be done.
- A. Only roof section #1 is in the scope for this contract.

- 1.1 Section 07 52 00, Item 2.3: Tremco AVC Membrane is an acceptable alternate.
- 1.2 Section 07 52 00, Item 2.4: Johns Manville is an acceptable alternate manufacturer, including products JM Dynabase, JM Dynabase Grip, JM Dynaweld 180S, JM Dynaweld 180 Cap, JM Permafash Adhesive, JM One Step Foamable Adhesive, JM MBR Cold Application Adhesive.
- 1.3 Section 07 52 00, Item 2.4:6: The TRA membrane requires only a one ply application.
- 1.4 Section 07 52 00, Item 2.11.2: MBR Cold application Adhesive and IKO Cold Gold Adhesive shall be an acceptable alternates, providing all adhesive is completely covered by the white stone.



National Research
Council Canada

Conseil national de
recherches Canada

Canada 