
MCTS CENTRE AND C&P BUILDING PLACENTIA, NL

Addendum 2

DATE: 11 August 2017

Reference No.: R.081781.004

The following, including attachments if any, shall be included in the scope of the Work of this project.

PART A – REQUEST FOR CLARIFICATIONS

1. Acceptable Alternative Materials:

General Note (Acceptable Alternative Materials) - All alternate products must satisfy requirements for quality and performance as specified on the design drawings and specifications. Products must be CSA and/or ULC certified as required (ie. if any of the manufacturers' products referenced below, and in the attachments, are not approved for use in Canada, shop drawing submittals will be rejected). Acceptance of these products for alternate submission does not guarantee approval during shop drawing review, the products must meet the design, performance specs and service requirements before final approval. Any extra costs, delays, or problems associated with the use and installation of this equipment will be the responsibility of the Contractor.

Q. I would like to request that Madsen Power Systems be added to the list of approved generator manufacturers for the above mentioned project. Specification 26 32 13.01 section 2.11.1

A. The product listed below is accepted for alternative submission, but must satisfy all requirements of the design and restrictions as listed in the General Note above.

<u>Section</u>	<u>Equipment</u>	<u>Alternate Product</u>
26 32 13.01	Generators	Madsen Power Systems

- Q** Section 08 80 50 mentions plastic film, just wondering if there is a spec for that. It doesn't mention anything about the plastic film in 08 80 50 Part 2 under materials.
- A** Any film in the laminate safety glazing would be assembled in the factory when they manufactured the glazing in accordance with Clause 2.1.2.3, therefore this Clause 3.9 shall be deleted.

PART B – SPECIFICATIONS

1. Section 08 80 00 – Glazing

Delete Clause 3.9 – Installation Plastic Film and re-number the remaining Clauses this Section accordingly.

END OF ADDENDUM