



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> First Stage In Situ Remediation	
<b>Solicitation No. - N° de l'invitation</b> EZ897-180850/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2017-08-15
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-004-8128	
<b>File No. - N° de dossier</b> PWY-7-40138 (004)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-08-23</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Mestry, Ruth (PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy004
<b>Telephone No. - N° de téléphone</b> (778) 995-4613 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> PWGSC - Muncho Lake & Fireside Maintenance Camps, km 698 & km 839 - Alaska Highway, BC	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

## **Addendum No. 2**

The following changes/clarifications in the tender documents are effective immediately. This Addendum will form part of the Contract Documents.

Question 1: Is the oxidant and catalyst product also to be procured by the contractor and included in the bid price or is this separate from this bid?

Answer 1: The oxidant, catalyst, citric acid, and potassium citrate products are to be procured, supplied, and delivered to the Sites by the contractor and included in the bid price.

Question 2: Is it required that the Muncho Lake and Fireside sites have separate support facilities setup or can they be moved between the sites during the different portions of the project?

Answer 2: The Hydrogen Peroxide Storage Area and Emergency Shower and Eye and Face Wash Equipment shall be installed at the sites prior to delivery of hydrogen peroxide, catalyst, citric acid, or potassium citrate to the site, and shall remain on the sites while hydrogen peroxide, catalyst, citric acid, or potassium citrate are stored at the sites. These Hydrogen Peroxide Storage Area and Emergency Shower and Eye and Face Wash Equipment can be moved or removed from a site provided the storage or handling of hydrogen peroxide, catalyst, citric acid, or potassium citrate is not taking place.

Question 3: If water is required for mixing/diluting oxidant, can this be obtained from a clean surface water or groundwater source or is a certified standard (i.e. town supply) required?

Answer 3: Water shall be supplied as indicated in section 02 61 00.05, Part 2 Products, 2.1.6 (2.1.6.1 – 2.1.6.7). No certified standard is required (surface or groundwater source is acceptable). Water will be subject to acceptance by the Departmental Representative.

Question 4: Can oxidant be delivered and stored at concentrations greater than 17.5%?

Answer 4: Yes. Transportation of oxidant, catalyst, and enhancements shall be in accordance with the Transportation of Dangerous Goods Act, and Transportation of Dangerous Goods Regulations.

END OF ADDENDUM NO. 2