


A. ALL ELECTRICAL WORK SHALL BE DONE IN COMPLETE COMPLIANCE WITH 2011 MANITOBA BUILDING CODE AND 2015 CANADIAN ELECTRICAL CODE.

- 1) CONNECT ALL EMERGENCY LIGHTING TO UNSWITCHED NIGHT LIGHTING/UNSWITCHED LIGHTING CIRCUIT IN THE AREA.
- 2) TELEVISION OUTLETS. COORDINATE MOUNTING HEIGHT WITH ARCHITECT PRIOR TO INSTALLATION.
- 3) PROVIDE DEDICATED 15A, 120V CIRCUIT FOR STANDALONE EXIT SIGNS.
- 4) ALL STAND ALONE CO ALARM DEVICES SHALL BE NFPA 720 (AND BY EXTENSION, UL2075 & UL2034) COMPLIANT, NON-RESIDENTIAL, COMMERCIAL LIFE SAFETY GRADE, LOW VOLTAGE, FULLY SUPERVISABLE DEVICES.
- 5) CONFIRM ALL BREAKER SIZES FOR MECHANICAL EQUIPMENT WITH EQUIPMENT NAMEPLATE AND COORDINATE THEIR EXACT LOCATIONS WITH MECHANICAL CONTRACTOR.
- 6) CONFIRM EXACT LOCATION OF GAS FIRED TANKLESS WATER HEATER WITH MECHANICAL CONTRACTOR.
- 7) EMERGENCY LIGHTING BATTERY BANK SHALL BE SIZED TO PROVIDE A MINIMUM 50% FOR 2HR AND SHALL INCLUDE AUTO SELF-DIAGNOSTIC CHARGING AND TRANSIENT VOLTAGE SURGE SUPPRESSOR ON SUPPLY SIDE AS PER CSA C282-09.
- 8) CONFIRM EXACT LOCATION OF BOOT DRYER RACK WITH ARCHITECT.
- 9) COUNTERTOP RECEPTION MILLWORK RECEPTACLES. EC TO COORDINATE WITH GC AND SCAN AND CORE AS REQUIRED. CONFIRM MOUNTING HEIGHT AND EXACT LOCATION WITH ARCHITECT.
- 10) BOARDROOM FLOOR OUTLETS. EC TO COORDINATE WITH GC AND SCAN AND CORE AS REQUIRED. CONFIRM EXACT LOCATION WITH ARCHITECT.
- 11) ALL DESKTOP OUTLETS TO BE MOUNTED 914MM (36") ON CENTRE AFF. CONFIRM EXACT MOUNTING HEIGHT WITH ARCHITECT PRIOR TO INSTALLATION.



5
TYP. CU
2
0-39,41

SCALE: 1:50

Revision	Description	Date
Client		client

Project title	Project
---------------	---------

Designed by	Conçu par
PC	

Drawn by VRR	Dessiné par
------------------------	-------------

Approved by DKG	Approuvé par
---------------------------	--------------

PWGSC Project Manager	Administrateur de Projets TPSGC
-----------------------	---------------------------------

Drawing title	Titre du dessin
---------------	-----------------

Projet no 416 du projet	Drawing no 416 du dessin	Revision no
-------------------------	--------------------------	-------------

2

OF 10