



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency
National Contracting Services**

**3, passage du Chien-d 'Or
Quebec, QC
G1R 3Z8**

INVITATION TO TENDER
APPEL D'OFFRES

AMENDMENT #1 TO:

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission à: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
3, passage du Chien-d 'Or
Quebec, QC, G1R 3Z8

Title-Sujet Rehabilitation of the ventilation systems at the National Historic Site of the Forges du St-Maurice		Date August 16th, 2017					
Solicitation No. - No. de l'invitation 5P201-17-5059		Client Ref. No. – No. de réf du client.					
GETS Reference No. – No de reference de SEAG							
Solicitation Closes L'invitation prend fin – at – à 2:00 PM on – le August 30th 2017		Time Zone Fuseau horaire - EASTERN DAYLIGHT TIME (EDT)					
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>							
Address Inquiries to: - Adresser toute demande de renseignements à : Josée Gagnon, josee.gagnon@pc.gc.ca							
Telephone No. - No de téléphone 418 648-2502		Fax No. – No de FAX: 418 649-6971					
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein							
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur Telephone No. - No de téléphone: _____ Facsimile No. - N° de télécopieur: _____ Email - Courriel : _____							
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur <table style="width:100%; border:none;"> <tr> <td style="width:50%; border-top:1px solid black; text-align:center;">Name / Nom</td> <td style="width:50%; border-top:1px solid black; text-align:center;">Title / Titre</td> </tr> <tr> <td style="width:50%; border-top:1px solid black; text-align:center;">Signature</td> <td style="width:50%; border-top:1px solid black; text-align:center;">Date</td> </tr> </table>				Name / Nom	Title / Titre	Signature	Date
Name / Nom	Title / Titre						
Signature	Date						



Amendment #1

THE PURPOSE OF THIS AMENDMENT IS TO PROVIDE DETAILS TO THE TECHNICAL SPECIFICATIONS.

YOU MUST CONSIDER THE INFORMATION IN THE ANSWERS BELOW, IN THE EVALUATION OF YOUR BID.

1. APPENDIX 1, LUMP SUM PRICE FORM - Revision 1

This amendment replaces Appendix 1 in its entirety. The Lump Sum Price Form Revision 1 must be used in your bid to be deemed admissible. Bids submitted using the Combined Price Form will be evaluated as non-compliant.

2. Q Painting of the equipment: To the estimate, section 26 05 05 p. 9, it is stated that the electrical equipment must be painted but according to Marc-André Trépanier of Stantec, no painting is to be done. Can you confirm?

A The finish for cabinets, transformers, disconnectors, etc, is to be done in factory. Non painting is to be done on site.

3. Q Identification of conduits and cables: To the estimate, section 26 05 15 p.11, it is indicated that conduits and cables must be identified. Required for the project?

A It is required

4. Q "Arc Flash" markings: To the estimate, section 26 05 05 p.14 it is indicated that all electrical equipment must be labeled. Can you give more details on the requirements if applicable?

A It is not required to do an arc flash study but to affix arc warning and shock warning labels on electrical equipment such as electrical panel's transformers. See model CSA Z462 standard.

5. Q Switch with window: To the estimate, section 26 05 05 p. 29, it is indicated that the switches must have a window showing the contacts. Required for this project?

A The window is not required for the switches



6. Q Installation on plywood: To the estimate, section 26 05 05 p. 29 it is indicated that the switches must be mounted on a steel profile and plywood when not detailed. Since the equipment will be installed in different locations and not always grouped together, can we anchor them directly in the wall without a steel profile or plywood?
- A The building is very old and historic. In general, interrupters and switches must be installed on steel profiles, however, if the composition of the wall allows it, then it is possible to fix them directly to the wall.

End of section.

THE BID CLOSING DATE REMAINS WEDNESDAY, THE 30TH OF AUGUST 2PM EDT.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

**Signed copy of this amendment should accompany each tender. If your tender has already been submitted please sign and fax the amendment along with any revisions to tender price, to this office before the close of Tender.
Fax: 418 649-6971.**