



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Fume Hood Recapitalization	
Solicitation No. - N° de l'invitation EZ899-180611/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client	Date 2017-08-15
GETS Reference No. - N° de référence de SEAG PW-\$PWY-031-8120	
File No. - N° de dossier PWY-7-40106 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-08-22	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leung, Janie	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (778) 919-3273 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: EC - Pacific Environmental Science Centre (PESC) - North Vancouver, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Amendment #001 is raised to address questions:

Q1. Can you provide shop drawings for the existing fume hoods with make and model numbers indicate the panel that needs to be replaced? Ref. Drawing M-1, items M1D.1 and M1.1

A1. The shop drawing for the existing fume hoods are not available. Panels for the fume hood to be provided by H H Hawkins (or equivalent) as the basis of design to match the fume hoods as noted on the drawings and Specifications.

Q2. Can you provide a schedule c/w **make and model** of all new mechanical equipment required for this Project; Air Terminal Units, fans, split AC unit also existing AHU-5E?

A2. Schedules are provided in the Specifications;

The basis of design are the following:

- Existing AHU-5: Scott Springfield model AHU-10000-HC
- Split Air Conditioning Units: Mitsubishi Electric Model PLA-A428A4 (indoor)/Puy-A42NHA5 (outdoor)
- Variable Air Volume Air Terminal Units: Phoenix Controls
- Temporary Fume Exhaust Fan: Greenheck model VEKTOR-H-10
- Exhaust Fan EF-B1: Greenheck model SQ-120-VG
- Exhaust Fan EF-B2: Greenheck model SQ-130HP-VG
- Laboratory Exhaust System PDEF-1 : Strobic Air Corporation model TS1S050B12 one running/one redundant

Equivalent makes / models are acceptable as long as specifications are met.

Please note that Tender documents issued for PWGSC will not permit equipment brand names and models.

Q3. Is the roof under warrantee and who is the roofing company?

A3. No.

Q4. Do you have the base building Controls Contractor contact info.?

A4. Johnson Controls, **Aaron Mc Carthy** , Controls Technician, 3680 East 2nd Ave. Vancouver, BC V5M 0A4

Q5. Can you provide the make and model of the existing MCC, panels and breakers.

A5. The existing equipment is of Westinghouse/Cutler Hammer manufacture.

MCC - Westinghouse Series 21.
600V panels Cutler Hammer - Powerline 1A
208V panels Westinghouse – PRL1

All other terms and conditions remain unchanged.