



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Réception des soumissions - TPSGC / Bid Receiving -
PWGSC

1550, Avenue d'Estimauville

1550, D'Estimauville Avenue

Québec

Québec

G1J 0C7

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

TPSGC/PWGSC

601-1550, Avenue d'Estimauville

Québec

Québec

G1J 0C7

Title - Sujet Réaménag. Centre Fiscal Jonquière	
Solicitation No. - N° de l'invitation EF245-180260/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client EF245-180260	Date 2017-08-16
GETS Reference No. - N° de référence de SEAG PW-\$QCL-018-17155	
File No. - N° de dossier QCL-7-40082 (018)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-08-24	Time Zone Fuseau horaire Heure Avancée de l'Est HAE
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Piras, Gabriel	Buyer Id - Id de l'acheteur qcl018
Telephone No. - N° de téléphone (418) 649-2870 ()	FAX No. - N° de FAX (418) 648-2209
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CENTRE FISCAL DE JONQUIÈRE JONQUIERE TAX CENTER 2251, Boul. René-Lévesque Jonquière (Québec) G7S 5J1	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

**TITLE : Jonquiere Tax Center - Ground floor work Gilles Marceau building
AMENDMENT 004**

Included in the present amendment :

- Questions and answers 5 to 9
 - Approvals of alternative materials 1 and 2
-

Questions and answers

Question 5

We want to bid on the electrical work of the project and we have a question: On Drawing E05 / 09, it is mentioned that the cable trays are supplied and installed by others. On the other hand, in Specifications' section 26 05 36, Cablethrough hangers and support for electrical, it is said that we must supply and install them. Do we have to include them in our Bid?

Answer : No. The cable trays will be provided and installed by others as shown on Plan E05. The specification section 26 05 36 is cancelled.

Question 6

In the "NOTES - CONSTRUCTION" on sheet A05, the letter "J" indicates to "clean the expansion joint-cover gasket". I would like to have more information, if possible

Answer : See sheet A08, picture C (note 9). Clean the center zone (rubber) on full length: clean with a vacuum cleaner, brush and soap.

Question 7

I have just read Addendum A1 and I was wondering: the supplier Beaulieu Canada mentions that they do not have 19 " x19 "carpets, but in the addendum, they are listed as acceptable manufacturer. So can the size of the rug be 24"x24 " or 18"x36 " since the company Beaulieu Canada have only these two sizes?

Answer : The 24" x 24" size is accepted. Adjust the installation plan (sheet A05) accordingly, keeping the same number of highlight color tiles TAP-2 and TAP-3.

Question 8

Does the plenum of the new diffusers have to be thermally insulated?

Answer : Air supply ducts must be thermally insulated up to grids and diffusers (reference specification section 23 07 13). Therefore, plenums must be thermally insulated.

Question 9

What is the thickness of the insulation on the hot water piping, as well as the supply and return of heating Glycol/Water Solution?

Answer : The thickness should be as shown in the table below.

Piping	Temp. °C	ACIT Code	Nominal pipe diameter (DN) and insulation thickness (mm)				
			Up to 25	from 32 to 50	from 65 to 100	from 125 to 150	200 and over
Supply and recirculation hot water	Inside	A-1	25	25	38	38	38
	Outside	A-1	65	65	75	90	90
Heating glycol/water Solution	61 – 93	A-1	25	25	38	38	38
	Up to 60	A-1	25	25	25	38	38

Approval of alternative materials 1

Can the following equivalent products be used for door hardware?

Product specified			Proposed product		
Product	Finish	Manufac.	Product	Finish	Manufac.
L9040 ND ATHENS L283-722	626	SCHLAGE	8802 MOR	626	YALE
L9080 ND ATHENS	626	SCHLAGE	8805 MOR	626	YALE
CX35A-EO	628	VD	7200 D	628	YALE
8916 AF89	689	DORMA	7500	689	NORTON
DP89	689	DORMA	7788	689	NORTON
SL11HD x EPT x 83"	CLR	SELECT	112HD x EPT	CLR	IVES
EA280	689	ABLOY	EPT	689	SECURITRON
PS902	600	VD	BPS-24-1	600	SECURITRON
236W	626	HAGER	250	626	GALLERY
910S	626	RIXSON	SERIE 1	626	RIXSON

Answer: The proposal for equivalence is accepted. The Contractor must ensure compatibility between the electrified hardware components, the electrified panic power supply and the proposed power supply box.

Approval of alternative materials 2

We would like to offer our GRADA high induction diffusers model SRT350 in equivalence to the diffusers (specified in ventilation) of brand NAD. For the ventilation grids item B and C in the table of grids we propose our equivalent models of brand Krueger EGC5-AL as well as model 600A.

Answer: The proposals for equivalence are accepted.

*** All the other clauses and conditions remain unchanged ***