



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave. Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6  
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6

<b>Title - Sujet</b> Beef Feedlot Water Renovation	
<b>Solicitation No. - N° de l'invitation</b> EP922-180336/B	<b>Amendment No. - N° modif.</b> 005
<b>Client Reference No. - N° de référence du client</b> EP922-180336	<b>Date</b> 2017-08-17
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-066-11146	
<b>File No. - N° de dossier</b> PWU-7-40041 (066)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-08-23</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Mountain Daylight Saving Time MDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Lee, Mony	<b>Buyer Id - Id de l'acheteur</b> pwu066
<b>Telephone No. - N° de téléphone</b> (780) 224-6675 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EP922-180336/B  
Client Ref. No. - N° de réf. du client  
AAFC EP922-180336

Amd. No. - N° de la modif.  
005  
File No. - N° du dossier  
PWU-7-40041

Buyer ID - Id de l'acheteur  
pwu066  
CCC No./N° CCC - FMS No/ N° VME

---

## **MODIFICATION DE L'INVITATION No. 005**

Voir les questions et réponses ci-jointes à partir de la visite du site.

Voir la liste de présence de la visite du site ci-jointe.

Toutes les autres modalités et conditions de l'Appel d'offres restent inchangées.

**PWGSC Project Number R.082927.001**

**AAFC Beef Feedlot Water Renovation & Expansion**

**Lacombe, Alberta**

## **Answers to Industry Questions dated August 11, 2017**

**Lacombe Contractors' Site Visit**

**Prepared by DGH Engineering Ltd.**

**2017-08-16**

Question 1: Will a fixture schedule be provided?

**Response 1: The information is provided in the plans and specs. No additional schedule is contemplated.**

Question 2: Is the new pump house to be supplied by the electrical or mechanical sub-trade?

**Response 2: All work indicated in the plans and specifications is to be completed by the contractor. Any division of labour by sub-trades is at the discretion of the contractor bidding, and is not determined by PWGSC.**

Question 3: Is the voltage of the pump house light provided on the specification correct?

**Response 3: No. Section 26 50 00 – Lighting, item 2.1.2.5 lists the voltage incorrectly as 277V. This should read 120V.**

Question 4: Is the heat trace run to the waterers to be supplied by the electrical or mechanical sub-trade?

**Response 4: All work indicated in the plans and specifications is to be completed by the contractor. Any division of labour by sub-trades is at the discretion of the contractor bidding, and is not determined by PWGSC.**

Question 5: There is a junction box for each individual waterer on the current installation. Is this required for the new construction?

**Response 5: Whether or not a junction box is required will be dependent on the waterer being installed. If the water has integral provisions for connection, no junction box will be required.**

Question 6: The conduit for the light standard pile is shown on the drawings as 250mm.

**Response 6: The conduit for the light standard pile should read 25mm.**

Question 7: Where is excess fill to be disposed of? Does it need to be hauled away or can it be stockpiled on-site?

**Response 7: Stockpile excess fill on-site at location to be determined by Department Representative in the immediate vicinity of the feedlot.**

Question 8: Can directional drilling be used in place of open trenching?

**Response8: Yes, directional drilling can be used as an option to run the waterlines.**

Question 9: Does the concrete need to be repaired where the old waterers are being replaced?

**Response 9: Yes, concrete pedestals at the old waterers are to be repaired and refurbished. Finished concrete should be in accordance with the typical waterer foundation details in the plans.**

Question 10: Do the pipe support blocks need to be placed every 1,220mm as indicated on the plans? Would a block at each tee to a waterer be sufficient?

**Response 10: The pipe needs to be adequately supported by placement on bedding materials. Blocks at corners will be sufficient, provided appropriate installation care is provided.**

Question 11: Will the contractor be responsible to remove trees, or will AAFC be removing them with their own forces?

**Response 11: Contractor is to remove and dispose of trees.**

Question 12: Will there be restrictions on access and working times at the site?

**Response 12: Contractors will have unrestricted access to the site. Co-ordinate work times with the Department Representative.**

# ATTENDANCE REGISTER PUBLIC SERVICE AND PROCUREMENT CANADA SITE VISIT









PLACE: Lacombe Research Centre, 6000 C&E Trail, Lacombe, Alberta.

SOLICITATION NO: EP922-180336/B

PROJECT NO: R.073123.001

DATE: Aug 11 at 10:30 am  
MST

TITLE: AAFC Beef Feed Lot Expansion and Renovation

COMPANY NAME	SIGNATURE	PRINT NAME	PHONE NO.	E-MAIL ADDRESS
Whissell Enterprises Ltd		GEORGE WHISSALL	780-293-9657	GEORGE.WHISSALL@WHISSALL.COM
Whissell Enterprises Ltd		HENRY WHISSALL	780-291-3731	111111
Q2 ELECTRICAL		Craig Greenwell	403-588-1382	craig@g2electric.com
C.M.S. Certified Mech.		Scott Nikula	403-556-0981	scnikula@gmail.com
Bosco ENR		Lee Koush	780-942-9597	leek@bosco.ca
Anderson Construction		ANDREW THOMPSON	780-497-0099	andrew@andersonconstruction.ca
Connected Mechanical		Jade Laster	780-447-1700	info@connectedmech.ca
West River Canada Hydropower			780-236-0408	westriver@canadahydro.com

CHAIRPERSON: \_\_\_\_\_ PHONE: \_\_\_\_\_