

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Division 33.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CSA C22.1-15, Canadian Electrical Code, Part 1, Safety Standard for Electrical Installations.
 - .2 CAN/CSA-C22.3 No. 7-10(R2015), Underground Systems.
 - .3 CAN3-C235-83(R2010), Preferred Voltage Levels for AC Systems, 0 to 50,000 V.
- .2 Electrical and Electronic Manufacturer's Association of Canada (EEMAC)
 - .1 EEMAC 2Y-1-1958, Light Gray Colour for Indoor Switch Gear.
 - .2 Institute of Electrical and Electronics (IEEE)/National Electrical Safety Code Product Line (NESC)
 - .3 IEEE SP1122-2000, The Authoritative Dictionary of IEEE Standards Terms, 7th Edition.
- .3 Installation to be in accordance with National Building Code of Canada (NBCC) and Local Regulations.

1.3 DEFINITIONS

- .1 Electrical and electronic terms: unless otherwise specified or indicated, terms used in these specifications, and on drawings, are those defined by IEEE SP1122.

1.4 DESIGN REQUIREMENTS

- .1 Operating voltages: to CAN3-C235.
 - .2 Motors, electric heating, control and distribution devices and equipment to operate satisfactorily at 60 Hz within normal operating limits established by above standard.
 - .1 Equipment to operate in extreme operating conditions established in above standard without damage to equipment.
 - .3 Language operating requirements: provide identification nameplates and labels for control items in English.
 - .4 Electrical permit required. Pay all associated fees.
-

1.5 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00- Submittal Procedures.
 - .2 Submit for review single line electrical diagrams.
 - .3 Shop drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Nova Scotia, Canada.
 - .2 Submit wiring diagrams and installation details of equipment indicating proposed location, layout and arrangement, control panels, accessories, piping, ductwork, and other items that must be shown to ensure coordinated installation.
 - .3 Identify on wiring diagrams circuit terminals and indicate internal wiring for each item of equipment and interconnection between each item of equipment.
 - .4 Indicate of drawings clearances for operation, maintenance, and replacement of operating equipment devices.
 - .5 All shop drawings shall be submitted in native PDF format, scans and images are not allowed.
 - .4 Quality Control: in accordance with Section 01 45 00 - Quality Control.
 - .1 Provide CSA certified equipment and material.
 - .2 Where CSA certified equipment and material is not available, submit such equipment and material to inspection authorities for special approval before delivery to site.
 - .3 Submit test results of installed electrical systems and controls/ instrumentation.
 - .4 Permits and fees:
 - .1 Submit to local inspection authority the necessary number of drawings and specifications for examination and approval prior to commencement of Work.
 - .2 Pay all associated fees.
 - .3 Notify Departmental Representative of changes required by local Electrical Inspection Authority prior to making changes
 - .5 Submit, upon completion of Work, load balance report as described in PART 3 - LOAD BALANCE.
 - .6 Submit certificate of acceptance from authority having jurisdiction upon completion of Work to Departmental Representative.
-

- .5 Manufacturer's Field Reports: submit to Departmental Representative manufacturer's written report, within 3 days of review, verifying compliance of Work and electrical system and instrumentation testing, as described in PART 3 - FIELD QUALITY CONTROL.

1.6 QUALITY ASSURANCE

- .1 Quality Assurance: in accordance with Section 01 45 00 - Quality Control.
- .2 Qualifications: electrical Work to be carried out by qualified, licensed electricians who hold valid Master Electrical Contractor license or apprentices in accordance with authorities having jurisdiction as per the conditions of Provincial Territorial Act respecting manpower vocational training and qualification.
 - .1 Employees registered in provincial apprentices program: permitted, under direct supervision of qualified licensed electrician, to perform specific tasks.
 - .2 Permitted activities: determined based on training level attained and demonstration of ability to perform specific duties.
- .3 Site Meetings:
 - .1 In accordance with Section 01 32 16.07 - Construction Progress Schedule - Bar (GANTT) Charts.
 - .2 Site Meetings: Schedule site visits, to review Work, at stages listed.
 - .1 Once during progress of Work at 50% complete.
 - .3 Upon completion of Work, after cleaning is carried out.

1.7 DELIVERY, STORAGE AND HANDLING

- .1 Material Delivery Schedule: provide Departmental Representative with schedule within 4 weeks after award of Contract.
 - .2 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
-

1.8 SYSTEM STARTUP

- .1 Instruct Departmental Representative and operating personnel in operation, care and maintenance of systems, system equipment and components.
- .2 Arrange and pay for services of manufacturers' factory service engineer to supervise start-up of installation, check, adjust, balance and calibrate components and instruct operating personnel.
- .3 Provide these services for such period, and for as many visits as necessary to put equipment in operation, and ensure that operating personnel are conversant with aspects of its care and operation.

1.9 OPERATING INSTRUCTIONS

- .1 Provide for each system and principal item of equipment as specified in technical sections for use by operation and maintenance personnel.
- .2 Operating instructions to include following:
 - .1 Wiring diagrams, control diagrams, and control sequence for each principal system and item of equipment.
 - .2 Start up, proper adjustment, operating, lubrication, and shutdown procedures.
 - .3 Safety precautions.
 - .4 Procedures to be followed in event of equipment failure.
 - .5 Other items of instruction as recommended by manufacturer of each system or item of equipment.
- .3 Print or engrave operating instructions and frame under glass or in approved laminated plastic.
- .4 Post instructions where directed.
- .5 Ensure operating instructions will not fade when exposed to sunlight and are secured to prevent easy removal or peeling.

PART 2 - PRODUCTS

2.1 MATERIALS AND EQUIPMENT

- .1 Provide material and equipment in accordance with Section 01 61 00 - Common Product Requirements.
-

- .2 Material and equipment to be CSA certified. Where CSA certified material and equipment are not available, obtain special approval from authority having jurisdiction inspection authorities before delivery to site and submit such approval as described in PART 1 - SUBMITTALS.
- .3 Factory assemble control panels and component assemblies. Full assembly shall be certified by a recognized certification agency, component certification only will not be accepted.

2.2 ELECTRIC MOTORS, EQUIPMENT AND CONTROLS

- .1 Verify installation and co-ordination responsibilities related to motors, equipment and controls, as indicated.
- .2 Control wiring and conduit: in accordance with Section 26 05 21 and 26 05 34 - Wires and Cables (0 - 1000V) and Conduits, Conduit Fastenings and Conduit Fittings, respectively.

2.3 WARNING SIGNS

- .1 Warning Signs: in accordance with requirements of inspection authorities and Departmental Representative.
- .2 Porcelain enamel signs, minimum size 175 x 250 mm.

2.4 WIRING TERMINATIONS

- .1 Ensure lugs, terminals, screws used for termination of wiring are suitable for copper and aluminum conductors.

2.5 EQUIPMENT IDENTIFICATION

- .1 Identify electrical equipment with nameplates and labels as follows:
 - .1 Nameplates: lamicoid 3 mm thick plastic engraving sheet matt white finish face, black core, lettering accurately aligned and engraved into core mechanically attached with double face tape
 - .2 Sizes as follows:

NAMEPLATE	SIZES		
Size 1	10 X 50mm	1 line	3mm high letters
Size 2	12 X 70mm	1 line	5mm high letters
Size 3	12 X 70mm	2 lines	3mm high letters
Size 4	20 X 90mm	1 line	8mm high letters
Size 5	20 X 90 mm	2 lines	5mm high letters
Size 6	25 X 100mm	1 line	12m high letters
Size 7	25 X 100mm	2 lines	6mm high letters

- .2 Labels: embossed plastic labels with 6mm high letters unless specified otherwise.
- .3 Wording on nameplates and labels to be approved by Departmental Representative prior to manufacture.
- .4 Allow for minimum of twenty-five (25) letters per nameplate and label.
- .5 Nameplates for terminal cabinets and junction boxes to indicate system and/or voltage characteristics.
- .6 Identify equipment with Size 3 labels engraved "ASSET INVENTORY NO. XX" as directed by Departmental Representative.
- .7 Disconnects, starters and contactors: indicate equipment being controlled and voltage.
- .8 Terminal cabinets and pull boxes: indicate system and voltage characteristics.
- .9 Transformers: indicate capacity, primary and secondary voltages.
- .10 Switchboards and Panelboards: Indicate designated name of equipment, system and voltage characteristics.

2.6 WIRING IDENTIFICATION

- .1 Identify all wiring with permanent indelible identifying markings, numbered coloured plastic tapes, on both ends of phase conductors of feeders and branch circuit wiring.
 - .2 Maintain phase sequence and colour coding throughout.
 - .3 Colour coding: to CSA C22.1.
 - .4 Use colour coded wires in communication cables, matched throughout system.
-

2.7 CONDUIT AND CABLE IDENTIFICATION

- .1 Colour code conduits, boxes and metallic sheathed cables.
- .2 Code with plastic tape or paint at points where conduit or cable enters wall, ceiling, or floor, and at 15m intervals.
- .3 Colours: 25mm wide prime colour and 20mm wide auxiliary colour.

	<u>Prime</u>	<u>Auxiliary</u>
up to 250V	Yellow	
up to 600V	Yellow	Green
<u>Other Communication Systems</u>	<u>Green</u>	<u>Blue</u>

2.8 FINISHES

- .1 Shop finish metal enclosure surfaces by application of rust resistant primer inside and outside, and at least two coats of finish enamel.
 - .1 Paint indoor switchgear and distribution enclosures light gray.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Do complete installation in accordance with CSA C22.1 except where specified otherwise.
- .2 Complete underground systems installation in accordance with CSA C22.3 No.1 and No. 7 except where specified otherwise.

3.2 NAMEPLATES AND LABELS

- .1 Ensure manufacturer's nameplates, CSA labels and identification nameplates are visible and legible after equipment is installed.

3.3 CONDUIT AND CABLE INSTALLATION

- .1 Install conduit and sleeves prior to pouring of concrete.
 - .1 Sleeves through concrete: schedule 40 steel pipe, sized for free passage of conduit, and protruding 50mm.
-

- .2 Install cables, conduits and fittings embedded or plastered over, close to building structure so furring can be kept to minimum.

3.4 MOUNTING HEIGHTS

- .1 Mounting height of equipment is from finished floor to centre line of equipment unless specified or indicated otherwise.
- .2 If mounting height of equipment is not specified or indicated, verify before proceeding with installation.
- .3 Install electrical equipment at following heights unless indicated otherwise.
 - .1 Local switches: 1200mm.
 - .2 Wall receptacles:
 - .1 General: 300mm.
 - .2 Above top of continuous baseboard heater: 200mm.
 - .3 Above top of counters or counter splash backs: 175mm.
 - .4 In mechanical rooms: 1200mm.
 - .3 Panelboards: as required by Code or as indicated.
 - .4 Telephone and interphone outlets: 300mm.
 - .5 Wall mounted telephone and interphone outlets: 1200mm.
 - .6 Fire alarm stations: 1200mm.
 - .7 Fire alarm bells: 2300mm.
 - .8 Instrumentation Equipment: 1200mm.

3.5 CO-ORDINATION OF PROTECTIVE DEVICES

- .1 Ensure circuit protective devices such as overcurrent trips, relays and fuses are installed to required values and settings.

3.6 FIELD QUALITY CONTROL

- .1 Load Balance:
 - .1 Measure phase current to panelboards with normal loads (lighting) operating at time of acceptance; adjust branch circuit connections as required to obtain best balance of current between phases and record changes.
 - .2 Measure phase voltages at loads and adjust transformer taps to within 2% of rated voltage of equipment.
 - .3 Provide upon completion of work, load balance report as directed in PART 1 - SUBMITTALS: phase and neutral currents on panelboards and dry-type transformers, operating under normal load, as well as hour and date on which each load was measured, and voltage at time of test.

- .2 Conduct following tests in accordance with Section 01 45 00 - Quality Control.
 - .1 Power distribution system including phasing, voltage, grounding and load balancing.
 - .2 Circuits originating from branch distribution panels.
 - .3 Lighting and its control.
 - .4 Motors, heaters and associated control equipment including sequenced operation of systems where applicable.
 - .5 Systems: fire alarm system, communications and intrusion alarm.
 - .6 Insulation resistance testing:
 - .1 Megger circuits, feeders and equipment up to 350V with a 500V instrument.
 - .2 Megger 350-600 V circuits, feeders and equipment with a 1000 V instrument.
 - .3 Check resistance to ground before energizing.
- .3 Submit test results to Departmental Representative.
- .4 Provide instruments, meters, equipment and personnel required to conduct tests during and at conclusion of project.
- .5 Manufacturer's Field Services:
 - .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in PART 1 - SUBMITTALS.
 - .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
 - .3 Schedule site visits, to review Work, as directed in PART 1 - QUALITY ASSURANCE.

3.7 CLEANING

- .1 Clean and touch up surfaces of shop-painted equipment scratched or marred during shipment or installation, to match original paint.
- .2 Clean and prime exposed non-galvanized hangers, racks and fastenings to prevent rusting.

END OF SECTION

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 26 05 21 - Wires and Cables (0-1000 V).

1.2 REFERENCES

- .1 CSA International
 - .1 CAN/CSA-C22.2 No. 18.4-15, Hardware For The Support Of Conduit, Tubing and Cable.
 - .2 CAN/CSA-C22.2 No.65-13, Wire Connectors (Tri-National Standard with UL 486A-486B and NMX-J-543-ANCE-03).
- .2 Electrical and Electronic Manufacturers' Association of Canada (EEMAC)
 - .1 EEMAC 1Y-2-1961, Bushing Stud Connectors and Aluminum Adapters (1200 Ampere Maximum Rating).
- .3 National Electrical Manufacturers Association (NEMA)

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Materials and Equipment and with manufacturer's written instructions.
 - .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
 - .3 Storage and Handling Requirements:
 - .1 Store materials indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect wire and box connectors from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.
 - .4 Packaging Waste Management: remove for reuse and return packaging materials as specified in Construction Waste Management Plan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
-

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Pressure type wire connectors to: CAN/CSA-C22.2 No.65, with current carrying parts of copper sized to fit copper conductors as required.
- .2 Fixture type splicing connectors to: CAN/CSA-C22.2 No.65, with current carrying parts of copper sized to fit copper conductors #10 AWG or less.
- .3 Bushing stud connectors: to EEMAC 1Y-2 to consist of:
 - .1 Connector body and stud clamp for stranded copper conductors.
 - .2 Clamp for copper bar.
 - .3 Stud clamp bolts.
 - .4 Bolts for copper bar.
 - .5 Sized for conductors and bars as indicated.
- .4 Clamps or connectors for armoured cable, TECK cable, flexible conduit, as required to: CAN/CSA-C22.2 No.18.

PART 3 - EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for wire and box connectors installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 INSTALLATION

- .1 Remove insulation carefully from ends of conductors and cables and:
 - .1 Install mechanical pressure type connectors and tighten screws with appropriate compression tool recommended by manufacturer. Installation shall meet
-

secureness tests in accordance with CAN/CSA-C22.2 No.65.
.2 Install fixture type connectors and tighten to
CAN/CSA-C22.2 No.65. Replace insulating cap.
.3 Install bushing stud connectors in accordance with
EEMAC 1Y-2.

3.3 CLEANING

- .1 Progress Cleaning: clean in accordance with Section
01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials,
rubbish, tools and equipment in accordance with Section
01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and
recycling in accordance with Section 01 74 21 -
Construction/Demolition Waste Management and Disposal.

END OF SECTION

PWGSC	WIRES AND CABLES	SECTION 26 05 21
BIO WATER UPGRADES	(0-1000 V)	PAGE 1
DARTMOUTH, NOVA SCOTIA		
PROJECT NO. R.082155.001		2017-07-24

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 26 05 20 - Wire and Box Connectors (0-1000 V).

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International).
 - .1 CSA C22.2 No. 0.3-09(R2014), Test Methods For Electrical Wires and Cables.
 - .2 CAN/CSA C22.2 No. 131-14, Type TECK 90 Cable.

1.3 PRODUCT DATA

- .1 Provide product data in accordance with Section 01 33 00 - Submittal Procedures.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Packaging Waste Management: remove for reuse packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 BUILDING WIRES

- .1 Conductors: stranded for #10 AWG and larger. Minimum size: #12 AWG.
- .2 Copper conductors: size as indicated, with 1000 V insulation of cross-linked thermosetting polyethylene material rated RW90 XLPE and RWU90 XLPE. Use RWU90 for outdoor installations.

2.2 TECK 90 CABLE

- .1 Cable: in accordance with Section 26 05 00 - Common Work Results for Electrical and to CAN/CSA C22.2 No. 131. Rated for hazardous location in areas classified as hazardous.
 - .2 Conductors:
 - .1 Grounding conductor: copper.
 - .2 Circuit conductors: copper, size as indicated.
 - .3 Insulation:
 - .1 Cross-linked polyethylene XLPE.
-

PWGSC	WIRES AND CABLES	SECTION 26 05 21
BIO WATER UPGRADES	(0-1000 V)	PAGE 2
DARTMOUTH, NOVA SCOTIA		
PROJECT NO. R.082155.001		2017-07-24

- .2 Rating: 1000 V.
- .4 Inner jacket: polyvinyl chloride material.
- .5 Armour: interlocking aluminum.
- .6 Overall jacket: thermoplastic polyvinyl chloride, low flame spread/low gas emission (LFS/LGE), fire retardant to CSA C22.2 No. 0.3.
- .7 Fastenings:
 - .1 One hole steel straps to secure surface cables 50 mm and smaller. Two hole steel straps for cables larger than 50 mm.
 - .2 Channel type supports for two or more cables at 1200 mm centers, unless noted otherwise, and as required by Local Authority.
 - .3 Threaded rods: 6 mm diameter to support suspended channels.
- .8 Connectors:
 - .1 Watertight, approved for TECK cable.

PART 3 - EXECUTION

3.1 GENERAL CABLE INSTALLATION

- .1 Install cable in trenches in accordance with Section 26 05 43.01 - Installation of Cables in Trenches and In Ducts.
- .2 Terminate cables in accordance with Section 26 05 20 - Wire and Box Connectors - (0-1000 V).
- .3 Cable Colour Coding: to Section 26 05 00 - Common Work Results for Electrical.
- .4 Conductor length for parallel feeders to be identical.
- .5 Lace or clip groups of feeder cables at distribution centres, pull boxes, and termination points.
- .6 Wiring in walls: typically drop or loop vertically from above to better facilitate future renovations. Generally wiring from below and horizontal wiring in walls to be avoided unless indicated.
- .7 All branch circuits to have dedicated neutral conductors, common neutrals not permitted.

PWGSC	WIRES AND CABLES	SECTION 26 05 21
BIO WATER UPGRADES	(0-1000 V)	PAGE 3
DARTMOUTH, NOVA SCOTIA		
PROJECT NO. R.082155.001		2017-07-24

3.2 INSTALLATION OF BUILDING WIRES

- .1 Install wiring as follows:
 - .1 In conduit systems in accordance with Section 26 05 34 - Conduits, Conduit Fastenings and Conduit Fittings.
 - .2 In underground ducts in accordance with Section 26 05 43.01 - Installation of Cables in Trenches and in Ducts.
 - .3 Provide dedicated neutral for each branch circuit.

3.3 INSTALLATION OF TECK90 CABLE (0-1000 V)

- .1 Group cables wherever possible on channels.
- .2 Group cables, on surface mounted channels where possible.
- .3 Do not secure cable to equipment pertinent to other trade.
- .4 Terminate cables and provide suitable connectors, as specified herein, where required.
- .5 Install cable, securely supported by cable clamps.

END OF SECTION

PART 1 - GENERAL

1.1 REFERENCES

- .1 American National Standards Institute /Institute of Electrical and Electronics Engineers (ANSI/IEEE)
 - .1 ANSI/IEEE 837-2014, IEEE Standard for Qualifying Permanent Connections Used in Substation Grounding.
- .2 CSA International
 - .1 CSA Z462-15, Workplace Electrical Safety.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for grounding equipment and include product characteristics, performance criteria, physical size, finish and limitations.

1.3 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for grounding equipment for incorporation into manual.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Materials and Equipment and with manufacturer's written instructions.
 - .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
 - .3 Storage and Handling Requirements:
 - .1 Store materials indoors and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect grounding equipment from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.
-

- .4 Packaging Waste Management: remove for reuse packaging materials as specified in Construction Waste Management Plan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 EQUIPMENT

- .1 Grounding conductors: bare stranded copper, soft annealed, size as indicated.
- .2 Insulated grounding/bonding: green, copper conductors, RW90, size as indicated. Minimum size #12 AWG.
- .3 Ground bus: copper, size as indicated, complete with insulated supports, fastenings, connectors.
- .4 Non-corroding accessories necessary for grounding system, type, size, material as indicated, including but not necessarily limited to:
 - .1 Grounding and bonding bushings.
 - .2 Protective type clamps.
 - .3 Bolted type conductor connectors.
 - .4 Bonding jumpers, straps.
 - .5 Pressure wire connectors.
 - .6 Compression connectors.

PART 3 - EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for grounding equipment installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.
-

3.2 INSTALLATION GENERAL

- .1 Install complete permanent, continuous grounding system including, electrodes, conductors, connectors, accessories. Run insulated bond wire in each conduit.
- .2 Install connectors in accordance with manufacturer's instructions.
- .3 Protect exposed grounding/bonding conductors from mechanical injury.
- .4 Use mechanical connectors for grounding connections to equipment provided with lugs.
- .5 Soldered joints not permitted.
- .6 Install bonding wire for flexible conduit, connected at both ends to grounding bushing, solderless lug, clamp or cup washer and screw. Neatly cleat bonding wire to exterior of flexible conduit.
- .7 Install flexible ground straps as required.
- .8 Install separate ground conductor to outdoor lighting standards.
- .9 Connect building structural steel and metal siding to ground by compression; copper to steel (#6 AWG). Provide suitable compression tools.
- .10 Make grounding connections in radial configuration only, with connections terminating at single grounding point. Avoid loop connections.

3.3 SYSTEM AND CIRCUIT GROUNDING

- .1 Install system and circuit grounding connections to neutral of secondary 120/208 and 347/600 V systems.

3.4 EQUIPMENT GROUNDING

- .1 Install grounding connections to typical equipment included in, but not necessarily limited to following list. Service equipment, transformers, switchgear, duct systems, frames of motors, motor control centres, starters, control panels, building steel work, fire pumps, distribution panels, outdoor lighting.
-

3.5 GROUNDING BUS

- .1 Install copper grounding bus mounted on insulated supports on wall of electrical room as indicated on drawings.
- .2 Ground items of electrical equipment in electrical room and other areas, as indicated on the drawing(s), to ground bus with individual bare stranded copper connections size #2/0AWG, unless noted otherwise.

3.6 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Perform ground continuity and resistance tests using method appropriate to site conditions and to approval of Departmental Representative and local authority having jurisdiction over installation.
- .3 Perform tests before energizing electrical system.
- .4 Disconnect ground fault indicator during tests.

3.7 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

END OF SECTION

PWGSC	JUNCTION, PULL BOXES	SECTION 26 05 31
BIO WATER UPGRADES	AND CABINETS	PAGE 1
DARTMOUTH, NOVA SCOTIA		
PROJECT NO. R.082155.001		2017-07-24

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 26 05 34 - Conduits, Conduit Fastenings and Conduit Fittings.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CSA C22.1-15, Canadian Electrical Code, Part 1.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Provide shop drawings: in accordance with Section 01 33 00 - Submittal Procedures.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Waste Management and Disposal:
 - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 JUNCTION AND PULL BOXES

- .1 Construction: welded steel enclosure. Enclosure to provide a degree of environmental protection equal to or higher than CSA Type 3R for indoor and 4X for outdoor.
 - .2 Covers Flush Mounted: 25 mm minimum extension all around.
 - .3 Covers Surface Mounted: screw-on turned edge covers.
-

2.2 CABINETS

- .1 Construction: stainless steel 304 welded, hinged door, handle, latch lock 2 keys and catch. Enclosure to provide a degree of environmental protection equal to or higher than CSA Type 3R for indoor and 4X for outdoor.
- .2 All connections in enclosures other than junction boxes to be made with terminals.

PART 3 - EXECUTION

3.1 JUNCTION, PULL BOXES AND CABINETS INSTALLATION

- .1 Install pull boxes in inconspicuous but accessible locations.
- .2 Mount cabinets with top not higher than 2 m above finished floor except where indicated otherwise.
- .3 Install terminal block in cabinets.
- .4 Only main junction and pull boxes are indicated. Install additional pull boxes as required by CSA C22.1.

3.2 IDENTIFICATION

- .1 Equipment Identification: to Section 26 05 00- Common Work Results for Electrical.
- .2 Identification Labels: size 2 indicating system name, voltage and phase or as indicated.
- .3 All junction boxes: indicate panel and circuit number.

END OF SECTION

PART 1 - GENERAL

1.1 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CAN/CSA C22.2 No. 18.1-13, Metallic Outlet Boxes.
 - .2 CSA C22.2 No. 45.1-07(R2012), Rigid Metal Conduit.
 - .3 CSA C22.2 No. 56-13, Flexible Metal Conduit and Liquid-Tight Flexible Metal Conduit.
 - .4 CSA C22.2 No. 83-M1985(R2013), Electrical Metallic Tubing.
 - .5 CSA C22.2 No. 211.2-06(R2016), Rigid PVC (Unplasticized) Conduit.
 - .6 CAN/CSA No. 18.3-12, Conduit, Tubing and Cable Fittings.
 - .7 CSA C22.2 No. 211.1-06(R2016), Rigid Types EB1 and DB2/ES2 PVC Conduit.

1.2 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Place materials defined as hazardous or toxic waste in designated containers.
- .3 Ensure emptied containers are sealed and stored safely for disposal away from children.

PART 2 - PRODUCTS

2.1 CONDUITS

- .1 Rigid metal conduit: to CSA C22.2 No. 45, hot dipped stainless steel 304 threaded.
 - .2 Rigid metal conduit: to CSA C22.2 No. 45, hot dipped galvanized steel threaded.
 - .3 Rigid PVC conduit: to CSA C22.2 No. 211.2. PVC conduits that are not concrete encased shall be Schedule 40.
 - .4 Flexible metal conduit: to CSA C22.2 No. 56, liquid-tight flexible metal.
-

2.2 CONDUIT FASTENINGS

- .1 One hole steel straps to secure surface conduits 53 mm and smaller.
 - .1 Two hole steel straps for conduits larger than 53 mm.
- .2 Beam clamps to secure conduits to exposed steel work.
- .3 Threaded rods, 6 mm diameter, to support suspended channels.
- .4 Material to match conduits.

2.3 CONDUIT FITTINGS

- .1 Fittings: to CAN/CSA C22.2 No. 18, manufactured for use with conduit specified. Coating: same as conduit.
- .2 Ensure factory "ells" (condulets) where 90 degrees bends for 27 mm and larger conduits, except for communications systems.
- .3 Conduit fittings (condulets) are not permitted for communications systems.
- .4 Material to match conduits.

2.4 EXPANSION FITTINGS FOR RIGID CONDUIT

- .1 Watertight expansion fittings with integral bonding jumper suitable for linear expansion and 19 mm deflection.
- .2 Weatherproof expansion fittings for linear expansion at entry to panel.

2.5 FISH CORD

- .1 Polypropylene. Provide in all empty conduits.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.
-

3.2 INSTALLATION

- .1 Install conduits to conserve headroom in exposed locations and cause minimum interference in spaces through which they pass.
- .2 Conceal conduits except in unfinished areas.
- .3 Use rigid hot dipped galvanized steel threaded conduit in doors.
- .4 Use rigid pvc conduit underground.
- .5 Use liquid tight flexible metal conduit for connection to equipment.
- .6 Minimum conduit size for lighting and power circuits: 21 mm. Minimum conduit size for communications systems: 27 mm.
- .7 Bend conduit cold:
 - .1 Replace conduit if kinked or flattened more than 1/10th of its original diameter.
- .8 Mechanically bend steel conduit over 21 mm diameter.
- .9 Field threads on rigid conduit must be of sufficient length to draw conduits up tight.
- .10 Install fish cord in all empty conduits.
- .11 Remove and replace blocked conduit sections.
 - .1 Do not use liquids to clean out conduits.
- .12 Dry conduits out before installing wire.
- .13 Do not secure conduits to mechanical systems piping or ducts, suspended ceiling, etc.
- .14 Provide minimum #12 AWG insulated "green" bonding conductor in all conduits. Provide suitable means to bond ends of metallic conduit.

3.3 SURFACE CONDUITS

- .1 Run parallel or perpendicular to building lines.
 - .2 Locate conduits behind infrared or gas fired heaters with 1.5 m clearance.
-

- .3 Run conduits in flanged portion of structural steel.
- .4 Group conduits wherever possible on suspended or surface channels.
- .5 Do not pass conduits through structural members except as indicated.
- .6 Do not locate conduits less than 75 mm parallel to steam or hot water lines with minimum of 25 mm at crossovers.

3.4 CONDUITS IN CAST-IN-PLACE SLABS ON GRADE

- .1 Run conduits 27 mm and larger below slab and encase in 75 mm concrete envelope.
 - .1 Provide 50 mm of sand over concrete envelope below floor slab.

3.5 CONDUITS UNDERGROUND

- .1 Slope conduits to provide drainage.
- .2 Waterproof joints (PVC excepted) with heavy coat of bituminous paint.

3.6 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

PART 1 - GENERAL

1.1 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for cables and include product characteristics, performance criteria, physical size, finish and limitations.

1.2 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Materials and Equipment and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect cables from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.
- .4 Packaging Waste Management: remove for reuse packaging materials as specified in Construction Waste Management Plan Waste Reduction Workplan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 CABLE PROTECTION

- .1 38 x 140 mm planks pressure treated with copper naphthenate or 5% pentachlorophenol solution, water repellent preservative.
-

2.2 MARKERS

- .1 Concrete type cable markers: 600 x 600 x 100 mm with words: cable, joint or conduit impressed in top surface, with arrows to indicate change in direction of cable and duct runs.
- .2 Polyethylene warning tape over full length of cable (raceway) route. Tape width of 75 mm with 4 mil tape thickness. Test on tape to read "CAUTION BURIED ELECTRIC LINE BELOW".

PART 3 - EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for cable installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
 - .2 Perform tests using qualified personnel.
 - .1 Include necessary instruments and equipment.
 - .3 Check phase rotation and identify each phase conductor of each feeder.
 - .4 Check each feeder for continuity, short circuits and grounds.
 - .1 Ensure resistance to ground of circuits is not less than 50 megohms.
 - .5 Pre-acceptance tests:
 - .1 After installing cable but before splicing and terminating, perform insulation resistance test with 1000 V megger on each phase conductor.
-

.2 Check insulation resistance after each splice and/or termination to ensure that cable system is ready for acceptance testing.

.6 Acceptance Tests:

.1 Ensure that terminations and accessory equipment are disconnected.

.2 Ground shields, ground wires, metallic armour and conductors not under test.

.3 High Potential (Hipot) Testing.

.1 Conduct hipot testing in accordance with manufacturer's recommendations.

.4 Leakage Current Testing:

.1 Raise voltage in steps from zero to maximum values as specified by manufacturer for type of cable being tested.

.2 Hold maximum voltage for specified time period by manufacturer.

.3 Record leakage current at each step.

.7 Provide Departmental Representative with list of test results showing location at which each test was made, circuit tested and result of each test. Departmental Representative should witness test before receiving the results.

.8 Remove and replace entire length of cable if cable fails to meet any of test criteria.

3.3 CLEANING

.1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.

.1 Leave Work area clean at end of each day.

.2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.

.3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

.1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

3.4 PROTECTION

.1 Repair damage to adjacent materials caused by cables installation.

END OF SECTION

PWGSC	MOULDED CASE CIRCUIT	SECTION 26 28 16.02
BIO WATER UPGRADES	BREAKERS	PAGE 1
DARTMOUTH, NOVA SCOTIA		
PROJECT NO. R.082155.001		2017-07-24

PART 1 - GENERAL

1.1 REFERENCES

- .1 CSA International
 - .1 CSA C22.2 No. 5-16, Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures (Tri-national standard with UL 489, and NMX-J-266-ANCE-2013).

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for circuit breakers and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Include time-current characteristic curves for provided breakers.
- .4 Certificates:
 - .1 Prior to installation of circuit breakers in either new or existing installation, Contractor must submit 3 copies of a production certificate of origin from the manufacturer. Production certificate of origin must be duly signed by factory and local manufacturer's representative certifying that circuit breakers come from this manufacturer and are new and meet standards and regulations.
 - .1 Production certificate of origin must be submitted to Departmental Representative for approval.
 - .2 Delay in submitting production of certificate of origin will not justify any extension of contract and additional compensation.
 - .3 Any work of manufacturing, assembly or installation to begin only after acceptance of production certificate of origin by Departmental Representative. Unless complying with this requirement, Departmental Representative reserves the right to mandate manufacturer listed on circuit breakers to authenticate new circuit breakers under the contract, and to Contractor's expense.
 - .4 Production certificate of origin must contain:
 - .1 Manufacturer's name and address and person responsible for authentication. Person responsible must sign and date certificate.
 - .2 Licensed dealer's name and address and person of

distributor responsible for Contractor's account.

.3 Contractor's name and address and person responsible for project.

.4 Local manufacturer's representative name and address. Local manufacturer's representative must sign and date certificate.

.5 Name and address of building where circuit breakers will be installed:

.1 Project title.

.2 End user's reference number.

.3 List of circuit breakers.

1.3 DELIVERY, STORAGE AND HANDLING

.1 Deliver, store and handle materials in accordance with Section 01 61 00 - Materials and Equipment and with manufacturer's written instructions.

.2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.

.3 Storage and Handling Requirements:

.1 Store circuit breakers off ground indoors and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.

.2 Store and protect circuit breakers from nicks, scratches, and blemishes.

.3 Replace defective or damaged materials with new.

.4 Packaging Waste Management: remove for reuse and return of packaging materials as specified in Construction Waste Management Plan Waste Reduction Workplan in accordance with Section 01 74 21 - Construction/ Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 BREAKERS GENERAL

.1 Moulded-case circuit breakers and ground-fault circuit-interrupters to CSA C22.2 No. 5.

- .2 Bolt-on moulded case circuit breaker: quick- make, quick-break type, for manual and automatic operation with temperature compensation for 40 degrees C ambient.
- .3 Common-trip breakers: with single handle for multi-pole applications.
- .4 Magnetic instantaneous trip elements in circuit breakers to operate only when value of current reaches setting.
 - .1 Trip settings on breakers with adjustable trips to range from 3-8 times current rating.
- .5 Circuit breakers with interchangeable trips as indicated.
- .6 Circuit breakers to have minimum symmetrical rms interrupting capacity rating same as associated board. Series rating for breakers is not acceptable.

2.2 THERMAL MAGNETIC BREAKERS

- .1 Moulded case circuit breaker to operate automatically by means of thermal and magnetic tripping devices to provide inverse time current tripping and instantaneous tripping for short circuit protection.

2.3 MOTOR CIRCUIT PROTECTORS (MCP)

- .1 Moulded case circuit breaker to operate automatically by means of solid state tripping devices to provide instantaneous tripping for short circuit protection.
- .2 MCP tripping range to allow for starting motors direct-on-line. Adjustable range from 700% to 1700% of motor full load amps.

2.4 OPTIONAL FEATURES

- .1 Include, as indicated on drawings:
 - .1 Shunt trip.
 - .2 Auxiliary switch.
 - .3 On-off locking device.
 - .4 Handle mechanism.

2.5 ENCLOSURE

- .1 Locate and mount in enclosure as indicated.
-

PART 3 - EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 INSTALLATION

- .1 Install circuit breakers as indicated.

3.3 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

END OF SECTION
