

PIPING SYSTEM IDENTIFICATION COLOURS				
LINE	MAIN MEDIA	MARKING	SPECIFIC MEDIA	COLOUR
	AIR IN VENTILATION SYSTEMS		NATURAL EXHAUST AIR	WH - BN - WH
	AIR IN VENTILATION SYSTEMS		CONDITIONED SUPPLY AIR	WH - VT - WH
ITEM	DESCRIPTION	QUANTITY	REFERENCE	MATERIAL
A1	EXHAUST VENTILATION FAN VENTS US, TT, SILENT M 200, 120 VAC, 60 HZ	2	-	-
A2	VENTILATION GRILLES (INLETS AND OUTLETS) HART & COOKEY 400 ROUND 60 DIFFUSERS WITH DAMPER (OR SIMILAR)	11	-	-


NOTES:

- DUCTING TO BE GALVANIZED RECTANGULAR DUCT OR SIMILAR. CUSTOM DUCTING AND FITTINGS WILL BE REQUIRED IN MANY AREAS DUE TO SPACE CONSTRAINTS OR CONNECTION POINTS.
- DUCTING ROUTES AND SIZING SHOWN ARE EXAMPLE ONLY. ACTUAL ROUTING AND SIZING OF DUCTS TO BE DETERMINED BY THE INSTALLER ON SITE AFTER A FULL LOAD ASSESSMENT HAS BEEN COMPLETED.
- DUCTING PATHS FINALLY INSTALLED ARE TO BE SKETCHED, AND PROVIDED TO THE VESSEL FOR ITS RECORDS.
- NOMINAL DUCTING SIZES LISTED. HVAC CONTRACTOR TO SIZE BASED UPON THEIR OWN CALCULATIONS.
- SUPPLY DUCTING TO BE INSULATED
- EXTRACTION FANS ARE TO BE INSTALLED ON SOFT-MOUNTS AND ARE TO HAVE FLEXIBLE DUCTING CONNECTIONS AT BOTH ENDS. IF ACOUSTIC NOISE IS OBJECTIONABLE, ADDITIONAL ACOUSTIC ENCLOSURES ARE TO BE PROVIDED.
- EXHAUST FAN CONFIGURATION AND LOCATIONS SHOWN ARE PRELIMINARY ONLY. ACTUAL LOCATION AND ARRANGEMENT TO BE DETERMINED AFTER TEAR OUT AND ASSESSEMENT OF DUCTING RUNS.
- AIR HANDLER AND EXHAUST FANS TO BE POWERED FROM PANEL P-422, WITH EMERGENCY SHUTDOWN TIED INTO EXISTING VESSEL VENTILATION SHUTDOWNS.
- SYSTEM TO BE BALANCED DURING COMMISSIONING. ROOM INLET DIFFUSERS TO BE LEFT AT 100% OPEN DURING INITIAL SETTING OF DAMPERS AT THE FRESH AIR PLENUM.


REVISION	REVISION DATE	ISSUED : JUNE 27 2017	DRAWING BY : TH	CHECKED BY : MD
A: RECONFIGURATION OF HVAC SYSTEM	AUG 9 2017			

CCG VECTOR
WET LAB

STATUS	FOR REVIEW	APPROVED BY	REV A
SHEET# 1/2			1146-3-508-01 WET LAB HVAC SYSTEM



THIS DRAWING IS THE PROPERTY OF GREGORY C. MARSHALL NAVAL ARCHITECT LTD. THIS DRAWING MAY BE USED SOLELY FOR THE WORK CONTRACTED. POSSESSION OF THIS DRAWING DOES NOT AUTHORIZE USE FOR CONSTRUCTION OR PLANNING UNLESS AUTHORIZED IN WRITING. ALL DRAWINGS ARE SUBJECT TO DETAIL DEVELOPMENT DURING THE COURSE OF CONSTRUCTION.
COPYING OR REPRODUCTION IN WHOLE OR IN PART IS STRICTLY PROHIBITED WITHOUT THE PRIOR WRITTEN CONSENT OF GREGORY C. MARSHALL NAVAL ARCHITECT LTD.




PIPING SYSTEM IDENTIFICATION COLOURS				
LINE	MAIN MEDIA	MARKING	SPECIFIC MEDIA	COLOUR
	AIR IN VENTILATION SYSTEMS		NATURAL EXHAUST AIR	WH - BN - WH
	AIR IN VENTILATION SYSTEMS		CONDITIONED SUPPLY AIR	WH - VT - WH
ITEM LIST				
ITEM	DESCRIPTION	QUANTITY	REFERENCE	MATERIAL
A3	AIR HANDLER (FRESH AIR MAKUP) 2400 CFM, 440 VAC 3-PH, 60 HZ	1	-	-
A4	CONDENSING UNIT 16-METAL CAPACITY TBD, 440 VAC 3-PH, 60 HZ	1	NOT SHOWN	-

- NOTES:
- DUCTING TO BE GALVANIZED RECTANGULAR DUCT OR SIMILAR. CUSTOM DUCTING AND FITTINGS WILL BE REQUIRED IN MANY AREAS DUE TO SPACE CONSTRAINTS OR CONNECTION POINTS.
 - DUCTING ROUTES AND SIZING SHOWN ARE EXAMPLE ONLY. ACTUAL ROUTING AND SIZING OF DUCTS TO BE DETERMINED BY THE INSTALLER ON SITE AFTER A FULL LOAD ASSESSMENT HAS BEEN COMPLETED.
 - DUCTING PATHS FINALLY INSTALLED ARE TO BE SKETCHED, AND PROVIDED TO THE VESSEL FOR ITS RECORDS.
 - NOMINAL DUCTING SIZES LISTED. HVAC CONTRACTOR TO SIZE BASED UPON THEIR OWN CALCULATIONS.
 - SUPPLY DUCTING TO BE INSULATED
 - EXTRACTION FANS ARE TO BE INSTALLED ON SOFT-MOUNTS AND ARE TO HAVE FLEXIBLE DUCTING CONNECTIONS AT BOTH ENDS. IF ACCOUSTIC NOISE IS OBJECTIONABLE, ADDITIONAL ACCOUSTIC ENCLOSURES ARE TO BE PROVIDED.
 - EXHAUST FAN CONFIGURATION AND LOCATIONS SHOWN ARE PRELIMINARY ONLY. ACTUAL LOCATION AND ARRANGEMENT TO BE DETERMINED AFTER TEAR OUT AND ASSESSEMENT OF DUCTING RUNS.
 - AIR HANDLER AND EXHAUST FANS TO BE POWERED FROM PANEL P-422, WITH EMERGENCY SHUTDOWN TIED INTO EXISTING VESSEL VENTILATION SHUTDOWNS.
 - SYSTEM TO BE BALANCED DURING COMMISSIONING. ROOM INLET DIFFUSERS TO BE LEFT AT 100% OPEN DURING INITIAL SETTING OF DAMPERS AT THE FRESH AIR PLENUM.

REVISION	REVISION DATE	ISSUED : JUNE 27 2017	DRAWING BY : TH	CHECKED BY : MD
A: RECONFIGURATION OF HVAC SYSTEM	AUG 9 2017			

CCG VECTOR WET LAB

STATUS:	APPROVED BY	FOR REVIEW	REV A
SHEET# 2/2			1146-3-508-01 WET LAB HVAC SYSTEM



PLAN VIEW, FORECASTLE DECK
SCALE $\frac{3}{4}" = 1'$