





- NOTES:
- ALL SPACES REFIT WITH NEW DUCTING TO BE FITTED WITH DAMPERS ON DIFFUSER OUTLETS, WHERE CHOSEN DIFFUSERS DO NOT INCLUDE DAMPERS, A SEPARATE ADJUSTABLE DAMPER IS TO BE FITTED
  - DUCTING TO BE INSULATED WITH ARMAFLEX OR EQUAL INSULATION
  - EXISTING DUCTING TO BE INSULATED WITH ARMAFLEX OR EQUAL INSULATION WITH ADDITIONAL HARDCOAT WHERE EXPOSED (E.G. PASSAGEWAYS)
  - INSULATION ON EXTERNAL DUCTS TO BE MINIMUM 1" THICK WITH HARD COVERS WHERE CLOSE TO DECK
  - INSULATION ON INTERNAL DUCTS TO BE MINIMUM 1/4" THICK
  - FIRE DAMPERS TO BE INSTALLED AS NOTED
  - DUCTING ARRANGEMENTS AND BALANCING DAMPERS TO BE ARRANGED BY HVAC SUPPLIER
  - DUCTING SIZES TO BE CONFIRMED BY CONTRACTOR AND ADJUSTED AS REQUIRED FOR FLOW OR SPACIAL CONSTRAINTS

1'0" X 2'4" INSULATED DUCTING AT DECK LEVEL  
(NOTE, DUCTING TO BE RASIED SLIGHTLY OFF DECK TO ALLOW FOR DRAINAGE UNDER)

1'0" X 2'4" DUCT PASSING UP THROUGH DECK

DUCTING TO BE INSTALLED UNDER GANGWAY STORAGE  
RAISED CRADLES FOR GANGWAY STORAGE TO BE FABRICATED AND INSTALLED BY CONTRACTOR




REVISION	REVISION DATE	ISSUED : AUG 9 2017	DRAWING BY : MD	CHECKED BY : MD
A:	RECONFIGURATION OF HVAC SYSTEM CONCEPT	AUG 15 2017		

CCG VECTOR  
HVAC SYSTEM

SHEET# 2/3	PRELIMINARY	APPROVED BY	REV A
1146-4-508-00-	HVAC SYSTEM		

THIS DRAWING IS THE PROPERTY OF GREGORY C. MARSHALL NAVAL ARCHITECT LTD. THIS DRAWING MAY BE USED SCALED FOR THE WORK CONTRACTED. POSSESSION OF THIS DRAWING DOES NOT AUTHORISE USE FOR CONSULTATION OR PLANNING UNDER ANY CIRCUMSTANCES. ALL DRAWINGS ARE SUBJECT TO DETAIL DEVELOPMENT DURING THE COURSE OF CONSTRUCTION.  
COPYING OR REPRODUCTION IN WHOLE OR IN PART IS STRICTLY PROHIBITED WITHOUT THE WRITTEN CONSENT OF GREGORY C. MARSHALL NAVAL ARCHITECT LTD.

- NOTES:
- ALL SPACES REFIT WITH NEW DUCTING TO BE FITTED WITH DAMPERS ON DIFFUSER OUTLETS, WHERE CHOSEN DIFFUSERS DO NOT INCLUDE DAMPERS, A SEPARATE ADJUSTABLE DAMPER IS TO BE FITTED
  - DUCTING TO BE INSULATED WITH ARMAFLEX OR EQUAL INSULATION
  - EXISTING DUCTING TO BE INSULATED WITH ARMAFLEX OR EQUAL INSULATION WITH ADDITIONAL HARDCOAT WHERE EXPOSED (E.G. PASSAGEWAYS)
  - INSULATION ON EXTERNAL DUCTS TO BE MINIMUM 1" THICK WITH HARD COVERS WHERE CLOSE TO DECKS
  - INSULATION ON INTERNAL DUCTS TO BE MINIMUM 3/4" THICK
  - FIRE DAMPERS TO BE INSTALLED AS NOTED
  - DUCTING ARRANGEMENTS AND BALANCING DAMPERS TO BE ARRANGED BY HVAC SUPPLIER
  - DUCTING SIZES TO BE CONFIRMED BY CONTRACTOR AND ADJUSTED AS REQUIRED FOR FLOW OR SPACIAL CONSTRAINTS



REVISION DATE	AUG 15 2017	ISSUED : AUG 9 2017
REVISION	A: RECONFIGURATION OF HVAC SYSTEM CONCEPT	DRAWING BY : MD
		CHECKED BY : MD

CCG VECTOR  
HVAC SYSTEM

APPROVED BY	PRELIMINARY	REV A
SHEET# 3/3	1146-4-508-00- HVAC SYSTEM	

THIS DRAWING IS THE PROPERTY OF GREGORY C. MARSHALL NAVAL ARCHITECT LTD. THIS DRAWING MAY BE USED SOLELY FOR THE WORK CONTRACTED. POSSESSION OF THIS DRAWING DOES NOT AUTHORISE USE FOR CONSTRUCTION OR PLANNING UNLESS AGREED IN WRITING. ALL DRAWINGS ARE SUBJECT TO DETAIL DEVELOPMENT DURING THE COURSE OF CONSTRUCTION.  
COPYING OR REPRODUCTION IN WHOLE OR IN PART IS STRICTLY PROHIBITED WITHOUT THE PRIOR WRITTEN CONSENT OF GREGORY C. MARSHALL NAVAL ARCHITECT LTD.