



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave. Jaspe  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6  
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6

<b>Title - Sujet</b> EMSI HVAC Projects	
<b>Solicitation No. - N° de l'invitation</b> EW038-180587/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> CSC - EW038-180587	<b>Date</b> 2017-08-18
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-066-11142	
<b>File No. - N° de dossier</b> PWU-7-40066 (066)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-08-25</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Mountain Daylight Saving Time MDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Lee, Mony	<b>Buyer Id - Id de l'acheteur</b> pwu066
<b>Telephone No. - N° de téléphone</b> (780) 224-6675 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

## SOLICITATION AMENDMENT No. 003

The following questions and answers are addressed to the specifications for clarification purposes only.

### Site Visit on August 10

1. Doug Z. (CSC contact) stated that the empty CorCan area may be used for tool and material storage by the successful bidder based on approval by the warden. This would shorten daily in and out clearance times during the project.
2. Mike C. (Setanta) asked to clarify main gas supply is in the main mechanical room on the far end of the building. Doug Z. (CSC Contact) stated that the main supply is located in the main mechanical room.
3. Contractors on site requested Doug Z. take several pictures during the walk through.

**1) duct inside room access Unit Offices 2) Second photo of Unit office roof access 3) Third photo of roof space Unit offices 4) Duct in Program building hallway 5) Second view of Program building duct 6) Glycol returns in tunnel**

**See ATTACHMENTS: EW038-180587\_photos**

4. Nordic asked to confirm if surface mounted wiring need to be conduit. The consultant Tony C. (Stantec) stated that any exposed wiring needed to be in conduit for security reasons.
5. For the Unit Offices (R.077217.001) cranes access can be coordinated for both sides of the roof work.
6. Can material be stored in the maintenance tunnel during the project?

**This will follow the same clearance for approval as item 1. Warden to approve the use of the tunnel. The successful bidder will be allowed to discuss the matter with the warden.**

7. Humidity valve shown on drawing not in place for R.077217.001. Stantec to confirm if it still needs to be replaced for current design or can be left out.

**Humidity valves stay in. Already included in design package (specs and drawings). No action required other than a simple yes to include.**

8. Panel "PL" location confirmation was requested. The panel is located in the maintenance tunnel as drawn
9. Roof space for R.077217.001 Unit offices is not a "confined space"
10. Nordic requested the opportunity to submit their controls not Johnson Controls.

**Nordic is accepted. CSC has stated a preference for Johnson Controls regarding future compatibility with the BMS at the EMSI. Whatever Nordic supplies is equal to the Johnson Controls in place.**

See attached site visit attendance register.

All other terms and conditions of the Invitation to Tender remain unchanged.

# PUBLIC SERVICE AND PROCUREMENT CANADA

## SITE VISIT

**PLACE:** Edmonton Maximum Security Institution

**SOLICITATION NO: EW038-180587/A**

PROJECT NO: R.077214.001,  
R.077217.001, R.077218.001

**DATE: Aug 10 at 10:00 am  
MST**

**TITLE: EMSI HVAC Projects Upgrade**

[illegible]

**CHAIRPERSON:**

**PHONE:**