



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Fume Hood Recapitalization	
Solicitation No. - N° de l'invitation EZ899-180611/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client	Date 2017-08-21
GETS Reference No. - N° de référence de SEAG PW-\$PWY-031-8120	
File No. - N° de dossier PWY-7-40106 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-08-28	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leung, Janie	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (778) 919-3273 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: EC - Pacific Environmental Science Centre (PESC) - North Vancouver, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Les documents français seront disponibles sur demande.

This Amendment #003 is raised to address questions.

Questions and Answers

Q1. For AHU 5 they would like blower and motor changed FVR believes we can achieved spec results by changing motor to 20 HP on VFD without changing the blower can you ask consultant if he is okay with just changing motor and adding VFD. Refitting new blower would almost require AHU apart and enlarging housing.

A1. NO CHANGES TO DESIGN AT THIS STAGE. OUR DESIGN WAS COORDINATED WITH ORIGINAL UNIT MANUFACTURER.

Q2. Is all duct cleaning only in Building B?

A2. YES

Q3. Are Air handlers to be cleaned?

A3. YES

Q4. Is escort required for project and if so who pays

A4. Not part of contractor scope. Contractor to adhere to use of premises outlined in Section 01 11 00, 1.6.

Q5. Can all work be done during regular work hours including duct cleaning?

A5. All work that does not adversely impact building occupants may be completed during regular working hours. Construction to adhere to outlined Work Sequence in Section 01 11 00, 1.5. Noise levels to be maintained as per Section 01 14 00, 1.4.

Q6. During site meeting I believe it was indicated no special protocols were required in clean room, am I correct in this?

A6. Construction to proceed as outlined in drawings and specifications.

Q7. Do the two warehouse exhaust systems need to be cleaned?

A7. YES

Q8. The fume hoods to be retrofitted at PESC were manufactured prior to 1995. I believe the current testing standards are ASHRAE 110-1995 and recently updated in 2016 and PWGSC MD 15128-2013. If specs are followed will these fume hoods meet these standards?

A8. The testing of fume hoods to be as per Specifications Section 23 38 16.13. The result of the testing to be documented and presented to the Departmental Representative and the laboratory manager. No further action is required for the fume hoods that may fail.

Q9. On drawing A-200 item D could you clarify mesh quality and sizes of perforations?

A9. As per previously issued Addendum 1.

Q10. Our subtrades are requesting additional site visit and additional time for tender. Can you please let me know if a site visit is acceptable and if a tender extension will be granted.

A10. Additional site visit can be coordinated directly with Nik at nikolas.fehr@canada.ca. Please remember that there will be no questions addressed at the site visit. All questions must go through the Contracting Authority Janie.Leung@pwgsc.gc.ca. The tender has been extended to August 28th, 2017.

All other terms and conditions remain unchanged.