



- LEVEL 65.80 FRAMING PLAN**
- TOP OF STRUCTURAL SLAB AT ELEVATION 65.72 EXCEPT AS CROSSED AND NOTED
 - DESIGN LOADS
LIVE LOAD 4.8KN/M² EAST OF BESSCRIPT AS BELOW.
LIVE LOAD 7.2KN/M² WEST OF BESSCRIPT ENTRY, ALUMINA COLOADE RAMP.
SOIL 4.8KN/M² WEST OF BESS EXCEPT AS NOTED.
SOIL 2.4KN/M² WEST OF BESS.
SOIL 0.5KN/M² MAIN ENTRANCE AND COLOADE RAMP.
CAPITALS EXCEPT AS NOTED.
 - FOR 3000 OR 3300X450 SLAB BEAMS MARKED WITH *** PROVIDE ION STRIPS IN SETS OF FOUR AT 300 FOR 1/4 SPAN FROM EDGE OF CAPITAL AT EACH END. CHAMBER 25 MM.
 - SEE RE-30 GENERAL NOTES AND TYPICAL DETAILS ON DETAILS RE-30, S-421, AND S-422.
 - MINIMUM COVER TO SLAB REINFORCEMENT: 25 MM TOP 25 MM BOTTOM
 - DESIGN STRENGTH OF CONCRETE AT 28 DAYS SHALL BE 30 MPa EXCEPT COLOADES AND MAINWAY SLABS SHALL BE 40 MPa.
 - PROVIDE MAINWAY COVER FOR TOP SLAB REINFORCEMENT AT MAINWAY TYPICAL.
 - SOIL - SUPPLEMENTARY DEAD LOAD.

AS BUILT

BELLAI BROTHERS LTD

CONCRETE STRUCTURE AS-BUILTS

CONTRACT NUMBER 8303-C-05
SHEET FRAMING PLAN
TITLE LEVEL 65.80
SCALE 1:100
SHEET NUMBER 8303-AB-403

DRAWN B. CZYZEWSKI
DATE JUNE 9/1986