



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Steamboat Maintenance Camp	
Solicitation No. - N° de l'invitation EZ897-180732/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client	Date 2017-08-22
GETS Reference No. - N° de référence de SEAG PW-\$PWY-026-8126	
File No. - N° de dossier PWY-7-40132 (026)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-08-25	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Yi (PWY), Patty	Buyer Id - Id de l'acheteur pwy026
Telephone No. - N° de téléphone (778) 919-2578 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC - Steamboat Maintenance Camp, km 537.9 - Alaska Highway, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Amendment 006 is raised to address questions and to extend the closing date.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED

Questions and Answers

1. Please confirm whether the buried cables within the excavation limits are live cables that must be preserved or historical cables that are to be removed.

The Contractor should assume all utilities located within the excavation extents are live, and will be responsible for the shut off, disconnection and reinstallation of utilities.

2. In regards to amendment No. 5 published on August 21, 2017 will the final completion date be extended to correspond with the additional site work?

1.11. Schedule Requirements

1.11.1. Work to be initiated: within 5 Working Days of Contract Award.

1.11.2. Pre-Mobilization Submittals: within 10 Working Days of Contract Award.

1.11.3. Mobilization: within 10 Working Days of Contract Award.

1.11.4. Site Works: Final Completion no later than 2017Oct01.

1.11.5. Offsite Treatment and Disposal Works: Final Completion no later than 2017Dec01.

1.11.6. Completion of the Work: no later than 2018March31. Includes all final Submittals including as-built documents, the Certificate of Completion, and the Statutory Declaration at Final Completion.

The intent is that concrete footings for the new salt shed and the new maintenance garage will be completed by others in the first week of October.

The Contractor must complete all Work associated with preparation of new salt shed by October 01, including: (i) Excavation Areas E5, E6, E7, E8, and H (ii) work shown on Drawings C101 to 104 (including clearing, grubbing, stripping, filling, geomembrane and nonwoven geotextile installation, and drain rock placement).

The Contractor must complete all Work associated with the footprint of the temporary maintenance garage by October 08, including: Excavation Areas F1, F2, F3, and J. The Contractor may, at their own cost and with no increase to schedule, stockpile excavated material onsite in areas identified by the Departmental Representative.

All Work on the Site must be completed by October 15.

EXTENSION TO CLOSING DATE

Solicitation No. - N° de l'invitation

EZ897-180732/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

006

File No. - N° du dossier

PWY-7-40132

Buyer ID - Id de l'acheteur

pw026

CCC No./N° CCC - FMS No./N° VME

EZ897-180732/A

Steamboat Maintenance Camp

KM 537.9, Alaska Highway. BC

Notice is hereby given that the above information notice previously due at 2:00pm PDST on August 24, 2017 is hereby extended to **2:00pm PDST on August 25, 2017.**