

SOLICITATION EZ108-180442/A – STATEMENT OF WORK SUPPLEMENT – REVISION 00

This Supplement is raised to:

- 1) Address questions raised by industry.
- 2) Present comments made by Canada; and
- 3) Revise the Statement of Work document.

This version of the Solicitation EZ108-180442/A – Statement of Work Supplement supersedes all previous versions of the Solicitation EZ108-180442/A – Statement of Work Supplement. If previously raised questions remain unanswered, please resubmit them by e-mail to the Contracting Authority.

Updates to this Supplement since the last version are in green text.

This Supplement affects the content of the Solicitation and its associated documents.

The bid must take into account:

- 1) The Solicitation documents available from the Government Electronic Tendering System at <https://BuyandSell.gc.ca/procurement-data/tenders>;
- 2) This Statement of Work Supplement; and
- 3) The documentation referenced within the Solicitation documents including this Statement of Work Supplement.

A. Questions and Answers

Item	Specification Reference	Question	Answer	Date
1	Section 09 01 90, Clause 5.4	Is it acceptable to use hand and power tools for base preparation in lieu of the 12,000 psi water jetting that is specified?	Yes, if the following procedures and confirmations are completed: Such areas must be thoroughly sanded to produce a surface profile of 2-4 mils. Surface Profile of such prepared areas will be confirmed with Testex Replica Tape prior to the application of any coatings. All areas sanded will require washing or wipe down to remove all dust and contamination (verifiable by clear tape test or white rag wipe)	August 21, 2017

B. Comments

Item	Reference	Comment	Date
1	Drawing 02 of 03	Additional information has been provided, as indicated on the drawings.	August 21, 2017

C. Revisions to the Statement of Work documents

Item	Reference	Remove	Insert	Date
1	Specification section 01 01 90, Maintenance of Paint and Coating	“85 sq.m.”	“110 sq.m”	August 21, 2017

ALL OTHER INSTRUCTIONS, TERMS AND CONDITIONS REMAIN UNCHANGED.