



**ADDENDUM NO. 2
REQUEST FOR BID NO. F0177
QUESTIONS AND ANSWERS PART 02**

August 23, 2017

To: All Bidders

Subject: **Request For Bid # F0177 – Workspace Furniture – Category 1**

Bidders are hereby notified of the following questions raised regarding the above requirement.

Q 1.) Annex B - Product Configurations table describes the panel height as "Work Surface Privacy Add on" which is 42" to 48" high. However, the drawing shows 54" high panels. Considering "Seated Height Privacy" is 50" to 54" height, should the description read "Seated Privacy Height" instead of "Work Surface Privacy Height"

A 1.) The panel heights need to follow WP2.0 guidelines. The different heights represent different seating configurations. Seated Privacy height is accepted.

Q 2.) Appendix C - Typical A shows 48" high storage. If 50" to 54" high panels are required, would 50" high storage be acceptable to be flushed with the panels as it is approved under the SA?

A 2.) Storage products are not a requirement of this solicitation, only Cat. 1 products as listed in Annex B, 3. Product Configurations (p.14-17) of the RFB.

Q 3.) How many power outlets are required, can the location be moved?

A 3.) 2 duplex per station. Yes they can be moved.

Q 4.) Could you please advise the anticipated delivery and install date?

A 4.) As per typical lead time, delivery and installation is anticipated within 6 to 8 weeks after contract award.