



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Fume Hood Recapitalization	
Solicitation No. - N° de l'invitation EZ899-180611/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client	Date 2017-08-24
GETS Reference No. - N° de référence de SEAG PW-\$PWY-031-8120	
File No. - N° de dossier PWY-7-40106 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-08-28	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leung, Janie	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (778) 919-3273 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: EC - Pacific Environmental Science Centre (PESC) - North Vancouver, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-180611/A

Amd. No. - N° de la modif.
006

Buyer ID - Id de l'acheteur
PWY031

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-7-40106

CCC No./N° CCC - FMS No./N° VME

Les documents français seront disponibles sur demande.

This Amendment #006 is raised to address questions.

Questions and Answers

Q1. On the structural drawings – S201 – there is an indication of a general detail for housekeeping pads. Also indicated is a reference to look at the other drawings provided for size and location. Can it be clarified if new pads are required?

A1. New pad as shown on the structural drawing S201 is not required.

Q2. On drawing A-200 item D could you clarify mesh quality and sizes of perforations?

A2. See attached Addendum 1 for clarification.

All other terms and conditions remain unchanged.

ADDENDUM NO. 1

Project:	PESC Fume Hood Recapitalization	Project / File No:	190001
Project Address:	2645 Dollarton Avenue, North Vancouver, BC	Date:	August 17 th , 2017
Tender Issue Date:	2017-07-28		
Tender Close Date:	2017-08-22	No. of Pages:	One written page.

This addendum shall form part of, and be included in, the contract drawings and specifications originally issued for the above named project and no consideration will be given to request for extras to this Contract due to the Contractor not being familiar with the Addendum. Please acknowledge receipt of the Addendum on the Tender Form.

The following attached information forms part of this Addendum:

DRAWINGS:

1. Architectural

a. Refer to Construction Notes on drawing A-200:

i. Revise note D to state:

New perforated metal equipment screen; minimum 24 gauge; suitable for exterior installation in a coastal climate; 30% openings; opening pattern to be chosen from manufacturer's range.